

FD#9

**LBM Engineering, LLC**

11 Hally Lane, Colchester, CT 06415-2133 Phone 860-416-9809 Email [John@LBMEngineering.com](mailto:John@LBMEngineering.com)

CIVIL ENGINEERING - LAND DEVELOPMENT - SITE PLANS - STORMWATER MANAGEMENT

**Engineering Report  
For Land Use Commissions Submittals  
Kineo Estates Subdivision, 939 Long Cove Road  
Ledyard, Connecticut**

November 3, 2025


**EXISTING CONDITIONS:** Reference is made to the following Plan Set: "Plan Showing Kineo Estates Subdivision Prepared for Mt. Kineo Builders Property of John Hale Almy II and Marcy Zerling Almy 939 Long Cove Road, Ledyard, Connecticut" Scales as Shown, September 2025, By Dieter & Gardner, Gales Ferry, CT. The property is located on the east side of Long Cove Road south of Hyde Park Drive. The property is wooded and drains to the south.


**METHODOLOGY:** The Rational Method was used for analyzing runoff rates per Part III of the Town of Ledyard's *Ordinance Regulating the Management of Stormwater Runoff*. The descending leg of the hydrographs are increased by a factor of 2.5 to provide additional stormwater volume. Driveway culverts are designed for a 25-year storm event. Intensity-Duration-Frequency (IDF) Curves were downloaded from the NOAA Atlas 14 web site. The proposed 15-inch and 18-inch driveway culverts were sized by verifying the inlet control headwater was no more than 1.5 times the pipe diameter. (HW/D). Calculations are attached to this report.

**STORMWATER MANAGEMENT:** The proposed development will not change the existing drainage patterns. Proposed house locations for 943 and 963 Long Cove Road are outside of regulated areas. Controls such as silt fence, haybales or are proposed between soil disturbance and environmentally sensitive areas.

**CONCLUSION:** The proposed development will not have adverse effects on down-gradient properties and is in keeping with the policies and goals of the Ledyard Planning and Zoning Commission.

Submitted by:  
LBM Engineering, LLC

  
John R. Martucci, P.E.



RECEIVED  
NOV 06 2025  
Land Use Department

**X-CULVERT 1**

GALESFERRY 25-yr Duration=15 min, Inten=4.88 in/hr

Prepared by LBM Engineering LLC

Printed 11/3/2025

HydroCAD® 10.20-7a s/n 09192 © 2025 HydroCAD Software Solutions LLC

Page 2

**Summary for Subcatchment 1A: 1A**

Runoff = 3.42 cfs @ 0.25 hrs, Volume= 5,373 cf, Depth= 0.34"  
 Routed to Pond 3P : 15" INLET

Runoff by Rational method, Rise/Fall=1.0/2.5 xTc, Time Span= 0.00-3.00 hrs. dt= 0.01 hrs  
 GALESFERRY 25-yr Duration=15 min, Inten=4.88 in/hr

| Area (ac) | C    | Description           | Land Use |
|-----------|------|-----------------------|----------|
| 4.400     | 0.25 | LIGHT UNDERBRUSH      | Meadow   |
| 4.400     |      | 100.00% Pervious Area |          |

| Tc (min) | Length (feet) | Slope (ft/ft) | Velocity (ft/sec) | Capacity (cfs) | Description                                                                                          |
|----------|---------------|---------------|-------------------|----------------|------------------------------------------------------------------------------------------------------|
| 20.8     | 100           | 0.0200        | 0.08              |                | Sheet Flow, SHEET FLOW<br>Woods: Light underbrush n= 0.400 P2= 3.40"                                 |
| 2.4      | 100           | 0.0200        | 0.71              |                | Shallow Concentrated Flow, SHALLOW CONCENTRATED<br>Woodland Kv= 5.0 fps                              |
| 0.6      | 150           | 0.0200        | 4.41              | 13.24          | Channel Flow, CHANNEL FLOW<br>Area= 3.0 sf Perim= 6.0' r= 0.50'<br>n= 0.030 Earth, grassed & winding |
| 23.8     | 350           | Total         |                   |                |                                                                                                      |

**Summary for Pond 3P: 15" INLET**

Inflow Area = 191,664 sf. 0.00% Impervious, Inflow Depth = 0.34" for 25-yr event  
 Inflow = 3.42 cfs @ 0.25 hrs, Volume= 5,373 cf  
 Outflow = 3.42 cfs @ 0.25 hrs, Volume= 5,373 cf, Atten= 0%, Lag= 0.0 min  
 Primary = 3.42 cfs @ 0.25 hrs, Volume= 5,373 cf

Routing by Dyn-Stor-Ind method, Time Span= 0.00-3.00 hrs, dt= 0.01 hrs  
 Peak Elev= 164.15' @ 0.25 hrs

| Device | Routing | Invert  | Outlet Devices                                                                                                                                                                                             |
|--------|---------|---------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| #1     | Primary | 163.00' | 15.0" Round Culvert<br>L= 30.0' CPP, projecting, no headwall, Ke= 0.900<br>Inlet / Outlet Invert= 163.00' / 162.50' S= 0.0167 ' / Cc= 0.900<br>n= 0.012 Corrugated PP, smooth interior, Flow Area= 1.23 sf |

Primary OutFlow Max=3.40 cfs @ 0.25 hrs HW=164.15' (Free Discharge)  
 1=Culvert (Inlet Controls 3.40 cfs @ 2.88 fps)

**X-CULVERT 2.**

GALESFERRY 25-yr Duration=15 min, Inten=4.88 in/hr

Prepared by LBM Engineering LLC

Printed 11/3/2025

HydroCAD® 10.20-7a s/n 09192 © 2025 HydroCAD Software Solutions LLC

Page 3

**Summary for Subcatchment 2A: 1A**

Runoff = 8.43 cfs @ 0.25 hrs, Volume= 13,268 cf, Depth= 0.35"  
 Routed to Pond 3P : 18" INLET

Runoff by Rational method, Rise/Fall=1.0/2.5 xTc, Time Span= 0.00-3.00 hrs, dt= 0.01 hrs  
 GALESFERRY 25-yr Duration=15 min, Inten=4.88 in/hr

| Area (ac) | C    | Description           | Land Use |
|-----------|------|-----------------------|----------|
| 10.500    | 0.25 | LIGHT UNDERBRUSH      | Meadow   |
| 10.500    |      | 100.00% Pervious Area |          |

| Tc (min) | Length (feet) | Slope (ft/ft) | Velocity (ft/sec) | Capacity (cfs) | Description                                            |
|----------|---------------|---------------|-------------------|----------------|--------------------------------------------------------|
| 19.1     | 100           | 0.0250        | 0.09              |                | <b>Sheet Flow, SHEET FLOW</b>                          |
|          |               |               |                   |                | Woods: Light underbrush n= 0.400 P2= 3.40"             |
| 2.4      | 100           | 0.0200        | 0.71              |                | <b>Shallow Concentrated Flow, SHALLOW CONCENTRATED</b> |
|          |               |               |                   |                | Woodland Kv= 5.0 fps                                   |
| 1.5      | 400           | 0.0200        | 4.41              | 13.24          | <b>Channel Flow, CHANNEL FLOW</b>                      |
|          |               |               |                   |                | Area= 3.0 sf Perim= 6.0' r= 0.50'                      |
|          |               |               |                   |                | n= 0.030 Earth, grassed & winding                      |
| 23.0     | 600           | Total         |                   |                |                                                        |

**Summary for Pond 3P: 18" INLET**

Inflow Area = 457,380 sf, 0.00% Impervious, Inflow Depth = 0.35" for 25-yr event  
 Inflow = 8.43 cfs @ 0.25 hrs, Volume= 13,268 cf  
 Outflow = 8.43 cfs @ 0.25 hrs, Volume= 13,268 cf Atten= 0%, Lag= 0.0 min  
 Primary = 8.43 cfs @ 0.25 hrs, Volume= 13,268 cf

Routing by Dyn-Stor-Ind method, Time Span= 0.00-3.00 hrs, dt= 0.01 hrs  
 Peak Elev= 145.33' @ 0.25 hrs

| Device | Routing | Invert  | Outlet Devices                                                                                                                                                                                                    |
|--------|---------|---------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| #1     | Primary | 143.00' | <b>18.0" Round Culvert</b><br>L= 30.0' CPP, projecting, no headwall, Ke= 0.900<br>Inlet / Outlet Invert= 143.00' / 142.00' S= 0.0333 '/' Cc= 0.900<br>n= 0.012 Corrugated PP, smooth interior, Flow Area= 1.77 sf |

Primary OutFlow Max=8.40 cfs @ 0.25 hrs HW=145.31' (Free Discharge)  
 1=Culvert (Inlet Controls 8.40 cfs @ 4.75 fps)





939 Long Cove Rd. Gales...

Search result

Legend

Layer List

C T M u n i c i p a l i t i e s C T D O T R o a d W a y B a s e m a p B o u n d a

HYDE PARK PR

Long Cove Rd

DRAINAGE  
AREA  
4.4 AC

170

165

CULVERT 1

CULVERT 1 DRAINAGE  
AREA

PAGE 4

1" = 200'

200 ft

Esri NAS JSGS FEMA | Esri Community Maps Contrib... Powered by Esri

Double  
click to



