

The following correspondence was received from Groton Utilities regarding high water usage at 1026 Long Cove Road (Mark Lopez);

History:

June – Usage 11,000 gallons – Did recheck read and called customer about high usage, left voicemail to call me back, no return call.

July – Usage 83,650 gallons – Did recheck read and called customer about high usage, Customer stated probably a running toilet again.

- Recheck was only 100 gallons for 5 days, whatever was leaking stopped.

The transmitter on this meter is not able to be data logged, I will request that the transmitter be replaced.