

APPROVED BY THE LEDYARD PLANNING AND ZONING COMMISSION AS TO THE COMPLIANCE WITH THE REGULATIONS GOVERNING THE SUBDIVISION OF LAND. ALL IMPROVEMENTS SHALL BE COMPLETED BY \_\_\_\_\_ DATE \_\_\_\_\_

CHAIRMAN OR SECRETARY \_\_\_\_\_ DATE \_\_\_\_\_

LOT NUMBERS ASSIGNED BY THE ASSESSOR \_\_\_\_\_

ASSESSOR \_\_\_\_\_ DATE \_\_\_\_\_

IWVC APPLICATION# \_\_\_\_\_

APPROVED, \_\_\_\_\_

NO PERMIT NECESSARY. (NOT WITHIN A REGULATED AREA)

NOT APPLICABLE AT THIS TIME. (WITHIN A REGULATED AREA; NO REGULATED ACTIVITY PROPOSED AT THIS TIME.)

ZONING/WETLANDS OFFICER \_\_\_\_\_ DATE \_\_\_\_\_

APPROVED BY THE DIRECTOR OF PUBLIC WORKS OR THE TOWN ENGINEER FOR PUBLIC WAY LAYOUT. \_\_\_\_\_ DATE \_\_\_\_\_

PUBLIC WORKS DIRECTOR/TOWN ENGINEER \_\_\_\_\_ DATE \_\_\_\_\_

EROSION AND SEDIMENT CONTROL PLAN CERTIFIED BY VOTE OF THE LEDYARD PLANNING AND ZONING COMMISSION

CHAIRMAN OR SECRETARY OF THE LEDYARD PLANNING AND ZONING COMMISSION \_\_\_\_\_ DATE \_\_\_\_\_

PERCOLATION TESTING PRESOAK 1 TO 2 HOURS BEFORE PERCOLATION TEST

PERFORMED ON FEBRUARY 7, 8, 14, 15 & 16 & APRIL 21, 2018.

PERC P-47 DEPTH 24" TIME READING 10:40 11" 10:45 12 3/4" 10:50 13 1/2" 10:55 14 1/4" 11:00 14 3/4" 11:05 15 1/2" 11:10 16 1/4" 11:15 17" 11:20 17 3/4" PERC RATE: 6.7 MINS/INCH	PERC P-48 DEPTH 24" TIME READING 10:42 8 1/4" 10:47 9 1/2" 10:52 10 1/2" 10:57 11 1/2" 11:02 12 1/4" 11:07 12 1/2" 11:12 13 1/4" 11:17 14" 11:22 15 1/4" PERC RATE: 6.7 MINS/INCH	PERC P-1 DEPTH 24" TIME READING 9:05 6 3/4" 9:10 8 1/2" 9:15 10" 9:20 11 1/2" 9:25 12 1/2" 9:30 13 1/4" 9:35 14 1/4" 9:40 15 1/4" 9:45 16 3/4" PERC RATE: 10.0 MINS/INCH	PERC P-2 DEPTH 24" TIME READING 9:06 8 3/4" 9:11 12" 9:16 13 1/4" 9:21 14" 9:26 14 1/2" 9:31 15" 9:36 15 3/4" 9:41 16 1/4" 9:46 16 3/4" PERC RATE: 10.0 MINS/INCH	PERC P-45 DEPTH 24" TIME READING 12:16 10 1/2" 12:21 13 1/2" 12:26 15 1/4" 12:31 16 1/2" 12:36 17 3/4" 12:41 19 1/4" 12:46 20 1/4" 12:51 20 3/4" 12:56 21 1/4" PERC RATE: 10.0 MINS/INCH	PERC P-46 DEPTH 24" TIME READING 12:18 12 1/4" 12:23 13 3/4" 12:28 14 1/4" 12:33 15" 12:38 15 1/2" 12:43 16" 12:48 16 1/2" 12:53 17" 12:58 17 1/2" PERC RATE: 10.0 MINS/INCH	PERC P-3 DEPTH 24" TIME READING 12:20 10" 12:25 11 1/4" 12:30 12 1/2" 12:35 13 1/4" 12:40 13 3/4" 12:45 14" 12:50 14 1/2" 12:55 15" 1:00 15 1/2" PERC RATE: 10.0 MINS/INCH	PERC P-4 DEPTH 24" TIME READING 11:30 10" 11:35 10 1/2" 11:40 11 1/4" 11:45 12" 11:50 12 3/4" 11:55 13 1/2" 12:00 15" 12:05 15 1/2" 12:10 16 1/4" PERC RATE: 10.0 MINS/INCH
---	---	--	---	--	--	--	---

PERC P-43 DEPTH 24" TIME READING 1:01 9 1/2" 1:06 12 1/4" 1:11 14 3/4" 1:16 16" 1:21 17 1/4" 1:26 18 1/2" 1:31 20 1/4" 1:36 23" 1:41 DRY PERC RATE: 5.0 MINS/INCH	PERC P-44 DEPTH 24" TIME READING 1:00 13 1/2" 1:05 15 3/4" 1:10 17 1/2" 1:15 18 1/2" 1:20 19 1/2" 1:25 20 1/4" 1:30 21" 1:35 23" 1:40 DRY PERC RATE: 6.7 MINS/INCH	PERC P-5 DEPTH 24" TIME READING 1:40 8" 1:45 13 1/2" 1:50 15 1/4" 1:55 16 1/2" 2:00 18" 2:05 18 3/4" 2:10 19 1/4" 2:15 20" 2:20 21 1/4" PERC RATE: 10.0 MINS/INCH	PERC P-6 DEPTH 24" TIME READING 1:42 10" 1:47 13" 1:52 14 1/4" 1:57 15 1/4" 2:02 16" 2:07 16 1/2" 2:12 17 1/2" 2:17 18" 2:22 18 1/2" PERC RATE: 10.0 MINS/INCH	PERC P-41 DEPTH 24" TIME READING 1:45 12 1/4" 1:50 17 3/4" 1:55 18 1/2" 2:00 19 1/2" 2:05 20" 2:10 14 1/4" 2:15 14 1/2" 2:20 14 3/4" 2:25 15 1/2" PERC RATE: 20.0 MINS/INCH	PERC P-42 DEPTH 24" TIME READING 1:47 11 3/4" 1:52 14 1/2" 1:57 17 1/2" 2:02 18 1/4" 2:07 20 1/2" 2:12 21 3/4" 2:17 DRY PERC RATE: 4.0 MINS/INCH	PERC P-39 DEPTH 24" TIME READING 10:50 7 1/2" 10:55 9 1/2" 11:00 10 3/4" 11:05 11 1/2" 11:10 12 3/4" 11:15 13 3/4" 11:20 14 1/2" 11:25 15 1/4" 11:30 16" PERC RATE: 6.7 MINS/INCH	PERC P-40 DEPTH 24" TIME READING 1:40 12" 1:45 14 1/4" 1:50 15 1/2" 1:55 16 1/2" 2:00 17 1/2" 2:05 18 1/2" 2:10 19 1/4" 2:15 19 3/4" 2:20 20 1/2" PERC RATE: 5.0 MINS/INCH
---	--	---	--	---	--	---	--

PERC P-38B DEPTH 24" TIME READING 2:35 10 1/2" 2:40 15 3/4" 2:45 17 1/4" 2:50 19 1/2" 2:55 20 1/4" 3:00 21 1/2" 3:05 22 1/4" 3:10 23" 3:15 23 1/2" PERC RATE: 10.0 MINS/INCH	PERC P-38 DEPTH 24" TIME READING 2:37 10" 2:42 12 1/2" 2:47 15 3/4" 2:52 17 1/4" 2:57 19" 3:02 20 3/4" 3:07 21 3/4" 3:12 22 1/2" 3:17 23" PERC RATE: 10.0 MINS/INCH	PERC P-56 DEPTH 24" TIME READING 10:05 9" 10:10 12 3/4" 10:15 14 3/4" 10:20 16 1/2" 10:25 18" 10:30 19" 10:35 19 3/4" 10:40 20 1/2" 10:45 DRY PERC RATE: 6.7 MINS/INCH	PERC P-28 DEPTH 24" TIME READING 11:00 8 1/4" 11:05 12" 11:10 14 1/4" 11:15 15 1/2" 11:20 16 3/4" 11:25 17 3/4" 11:30 18 3/4" 11:35 19 1/2" 11:40 20 1/2" PERC RATE: 6.7 MINS/INCH	PERC P-25 DEPTH 24" TIME READING 9:20 10 1/2" 9:25 11 1/2" 9:30 12" 9:35 12 3/4" 9:40 13 1/4" 9:45 13 1/2" 9:50 14" 9:55 14 1/2" 10:00 14 3/4" PERC RATE: 20.0 MINS/INCH	PERC P-25A DEPTH 24" TIME READING 9:22 9" 9:27 11 1/4" 9:32 12 1/2" 9:37 13 3/4" 9:42 15" 9:47 15 3/4" 9:52 16 3/4" 9:57 17 1/4" 10:02 18 1/4" PERC RATE: 10.0 MINS/INCH	PERC P-58 DEPTH 24" TIME READING 9:21 6 3/4" 9:26 9 3/4" 9:31 11 1/4" 9:36 12 1/2" 9:41 13 1/4" 9:46 14 1/4" 9:51 14 3/4" 9:56 15 1/2" 10:01 16 1/4" PERC RATE: 6.7 MINS/INCH	PERC P-16 DEPTH 24" TIME READING 12:48 7 1/4" 12:53 9 1/4" 12:58 10 3/4" 1:03 11 3/4" 1:08 13 1/4" 1:13 13 3/4" 1:18 14 3/4" 1:23 15 1/2" 1:28 16" PERC RATE: 10.0 MINS/INCH	PERC P-8 DEPTH 24" TIME READING 2:30 9 3/4" 2:35 13 1/2" 2:40 14 3/4" 2:45 15 1/2" 2:50 16 1/4" 2:55 17" 3:00 17 1/2" 3:05 18" 3:10 18 1/2" PERC RATE: 10.0 MINS/INCH
--	---	--	--	--	--	---	--	---

PERC P-36 DEPTH 24" TIME READING 9:23 7 3/4" 9:28 8 3/4" 9:33 10 1/4" 9:38 10 1/2" 9:43 11 1/2" 9:48 11 3/4" 9:53 12" 9:58 12 1/2" 10:03 13" PERC RATE: 20.0 MINS/INCH	PERC P-36B DEPTH 24" TIME READING 9:22 10 3/4" 9:27 12 1/4" 9:32 12 3/4" 9:37 13 1/2" 9:42 14" 9:47 14 1/4" 9:52 14 1/2" 9:57 15" 10:02 15 1/2" PERC RATE: 10.0 MINS/INCH	PERC P-11 DEPTH 24" TIME READING 11:05 10 1/4" 11:10 12 1/2" 11:15 14" 11:20 15" 11:25 16 1/4" 11:30 17 1/4" 11:35 17 1/4" 11:40 17 3/4" 11:45 18 1/2" PERC RATE: 10.0 MINS/INCH	PERC P-12 DEPTH 24" TIME READING 11:06 5 1/2" 11:11 7 1/2" 11:16 8 1/4" 11:21 9 1/4" 11:26 9 3/4" 11:31 10 1/4" 11:36 11" 11:41 11 1/2" 11:46 12" PERC RATE: 10.0 MINS/INCH	PERC P-34 DEPTH 24" TIME READING 9:20 8 1/2" 9:25 10 3/4" 9:30 11 3/4" 9:35 12 1/2" 9:40 13 1/4" 9:45 14 1/2" 9:50 15" 9:55 15 1/2" 10:00 15 3/4" PERC RATE: 10.0 MINS/INCH	PERC P-35 DEPTH 24" TIME READING 9:21 5" 9:26 6 3/4" 9:31 8" 9:36 8 3/4" 9:41 9 3/4" 9:46 10 1/4" 9:51 10 3/4" 9:56 11" 10:01 11 1/2" PERC RATE: 10.0 MINS/INCH	PERC P-31 DEPTH 24" TIME READING 12:06 7 3/4" 12:11 12 3/4" 12:16 15 1/4" 12:21 16 3/4" 12:26 17 3/4" 12:31 18 1/2" 12:36 20" 12:41 DRY 12:47 16 1/4" PERC RATE: 6.7 MINS/INCH	PERC P-49 DEPTH 24" TIME READING 12:07 7" 12:12 9 3/4" 12:17 11 1/4" 12:22 12 1/4" 12:27 13 1/2" 12:32 14" 12:37 15" 12:42 15 1/2" 12:47 16 1/4" PERC RATE: 10.0 MINS/INCH	PERC P-33 DEPTH 24" TIME READING 12:13 11 3/4" 12:18 13" 12:23 14" 12:28 14 3/4" 12:33 15 1/2" 12:38 16 1/4" 12:43 16 1/2" 12:48 17 1/4" PERC RATE: 6.7 MINS/INCH
--	---	--	---	---	---	--	--	--

PERC P-17 DEPTH 24" TIME READING 9:37 5" 9:42 9 3/4" 9:47 13 1/4" 9:52 16 1/4" 9:58 17 1/4" 10:02 18 1/4" 10:07 20" 10:12 21" 10:17 22" PERC RATE: 5.0 MINS/INCH	PERC P-18 DEPTH 24" TIME READING 9:38 5 3/4" 9:43 10" 9:48 12 1/2" 9:53 13 3/4" 9:58 15" 10:03 16" 10:08 16 3/4" 10:13 17 1/2" 10:18 18 1/2" PERC RATE: 6.7 MINS/INCH	PERC P-32 DEPTH 24" TIME READING 12:07 7" 12:12 9 3/4" 12:17 11 1/4" 12:22 12 1/4" 12:27 13 1/2" 12:32 14" 12:37 15" 12:42 15 1/2" 12:47 16 1/4" PERC RATE: 6.7 MINS/INCH	PERC P-30 DEPTH 24" TIME READING 12:05 10" 12:10 14 1/4" 12:15 15 1/2" 12:20 16 1/2" 12:25 17 3/4" 12:30 18 1/4" 12:35 19 1/2" 12:40 19 3/4" 12:45 20 1/2" PERC RATE: 10.0 MINS/INCH	PERC P-59 DEPTH 26" TIME READING 10:40 3 1/4" 10:45 6" 10:50 7 1/2" 10:55 8 1/2" 11:00 9 3/8" 11:05 10 1/8" 11:10 11" 11:15 10 5/8" 11:20 12 1/2" PERC RATE: 8.0 MINS/INCH	PERC P-60 DEPTH 26" TIME READING 10:42 3 1/2" 10:47 5 3/8" 10:52 6 5/8" 10:57 7 3/8" 11:02 8 1/8" 11:07 9" 11:12 9 7/8" 11:17 10 5/8" 11:22 11 1/8" PERC RATE: 10.0 MINS/INCH	PERC P-23 DEPTH 24" TIME READING 12:26 9" 12:31 12 3/4" 12:36 14 1/4" 12:41 15 1/4" 12:46 16 1/2" 12:51 17 1/4" 12:56 17 3/4" 1:01 18" 1:06 18 1/2" PERC RATE: 20.0 MINS/INCH	PERC P-24 DEPTH 24" TIME READING 12:25 8 3/4" 12:30 10 1/2" 12:35 11" 12:40 11 1/2" 12:45 12" 12:50 12 1/2" 12:55 12 3/4" 1:00 13 1/4" 1:05 13 1/2" PERC RATE: 20.0 MINS/INCH	PERC P-61 DEPTH 26" TIME READING 9:42 3" 9:47 5 1/2" 9:52 6 5/8" 9:57 7 1/4" 10:02 8 1/8" 10:07 9" 10:12 9 7/8" 10:17 10 3/4" 10:22 11 5/8" PERC RATE: 5.7 MINS/INCH	PERC P-62 DEPTH 26" TIME READING 9:38 2" 9:43 4" 9:48 5 1/4" 9:53 6 1/8" 9:58 7" 10:03 7 3/4" 10:08 8 5/8" 10:13 9 1/2" 10:18 10 1/4" PERC RATE: 5.7 MINS/INCH
--	---	---	--	--	---	---	---	--	--

PERC P-21 DEPTH 24" TIME READING 8:11 10 1/2" 8:16 15 3/4" 8:21 17 1/4" 8:26 19 1/2" 8:31 20 1/4" 8:36 21 1/2" 8:41 22 1/4" 8:46 23" 8:51 23 1/2" PERC RATE: 10.0 MINS/INCH	PERC P-55 DEPTH 24" TIME READING 9:05 10 1/2" 9:10 14 3/4" 9:15 16" 9:20 17" 9:25 18 1/4" 9:30 19 3/4" 9:35 20 1/2" 9:40 21 1/4" 9:45 21 3/4" PERC RATE: 10.0 MINS/INCH	PERC P-58 DEPTH 24" TIME READING 9:07 10" 9:12 12 1/4" 9:17 13 1/2" 9:22 14 3/4" 9:27 16" 9:32 16 3/4" 9:37 17 3/4" 9:42 18 1/4" 9:47 19 1/4" PERC RATE: 10.0 MINS/INCH	PERC P-19 DEPTH 24" TIME READING 10:45 9 1/4" 10:50 12 1/2" 10:55 15 1/2" 11:00 16 3/4" 11:05 17 1/2" 11:10 18 3/4" 11:15 19 3/4" 11:20 20 1/2" 11:25 21" PERC RATE: 10.0 MINS/INCH	PERC P-19A DEPTH 24" TIME READING 10:46 5 3/4" 10:51 7" 10:56 7 3/4" 11:01 8 1/4" 11:06 9 1/2" 11:11 9 3/4" 11:16 10 1/4" 11:21 10 3/4" 11:26 11 1/4" PERC RATE: 10.0 MINS/INCH	PERC P-51 DEPTH 24" TIME READING 9:35 8" 9:40 13 3/4" 9:45 16 1/2" 9:50 18 1/4" 9:55 20 1/4" 10:00 21 1/4" 10:05 21 1/2" 10:10 22 1/4" 10:15 DRY PERC RATE: 4.0 MINS/INCH	PERC P-52 DEPTH 24" TIME READING 9:36 5 3/4" 9:41 15 1/4" 9:46 18 1/4" 9:51 18 3/4" 9:56 20" 10:01 20 3/4" 10:06 21" 10:11 21 1/2" 10:16 22" PERC RATE: 4.0 MINS/INCH
---	---	---	---	---	---	---

PERCOLATION TEST DATA  
EAGLES LANDING  
AN OPEN SPACE SUBDIVISION  
PROPERTY OF  
MR G 1 LLC  
79 VINEGAR HILL ROAD  
LEDYARD, CONNECTICUT  
JUNE 2022



THIS DRAWING IS THE PROPERTY OF THE LAND SURVEYOR. THIS PLAN AND REPRODUCTIONS, ADDITIONS OR REVISIONS OF THIS PLAN ARE NOT VALID WITHOUT THE EMBOSSED SEAL AND SIGNATURE OF THE LAND SURVEYOR WHO PREPARED THIS PLAN. JOB#17-04740SCALE.DWG FBK#300/301