

# Change Order Request - #02

John Iacobucci  
95 Bysiewicz Dr



Juliet Long School - Roof Replacement and Photovoltaic Project: 0024

Middletown, CT 06457

To: Kyle Rongey  
STV, Inc.

**COR #:** 0002

**Revision:** 01

**Date:** 6/17/2024

**Author:** Matt Roberts / John Iacobucci

**Reason** COR #02 - Revise Roof Assembly

- Description:**
1. Coverboard - Adhered in Low Rise Foam
  2. Base Sheet - Installed with GreenLock Adhesive
  3. Cap Sheet - Spatter Spray Low Rise Foam

**Detailed Description** By accepting this method the finish product will ensure a cleaner , safer conditions/workmanship , and no "mole runs".  
Performances and Warranty will be equal.

## SUMMARY ITEM

	Cost / Unit	Unit Type	Subtotal
Change Order #02	\$178,531.00	Full	\$178,531.00
Credit for Hot Assembly	-\$33,000.00	Full	-\$33,000.00
Bonding Cost	\$2,910.62	Full	\$2,910.62
		<b>Grand Total:</b>	<b>\$148,441.62</b>