

## TOWN OF LEDYARD

# Memorandum:

**To:** Liz Burdick, Director of Land Use & Planning  
**From:** Steve Masalin, Public Works Director/Town Engineer *sm*  
**Date:** November 18, 2025  
**Re:** 939 Long Cove Rd (Appl. PZ #25-22SUB)

---

I have reviewed the plans and stormwater management report for the subject application. I have the following comment:

The Engineering Report cites an 18"-diameter at the lower driveway crossing, but the plans show a 15"-diameter pipe.

I find that the application is otherwise acceptable in managing stormwater impacts.

RECEIVED

NOV 18 2025

Land Use Department