

From: [Odalys Reyes Morales](#)
To: [Peter Gardner](#)
Cc: [Elizabeth Burdick](#); [Rosanne Kotowski](#)
Subject: Re: 5A Lorenz Industrial Parkway Ledyard
Date: Tuesday, December 17, 2024 11:44:25 AM
Attachments: [Outlook-1497617713.png](#)
[2931_001.pdf](#)

Good morning,

I have reviewed your comments.

There are still two test pits under the column deep test pits data called "test pit 2" I highlighted it in blue for reference. Please add which test hole is number 4 so I can confirm the soil data for test hole 2.

Thank you,

Odalys Reyes Morales

Sanitarian I

main phone. 860.448.4882 ext. 1383

direct dial. 860.321.4476

f. 860.448.4885

oreyes@llhd.org

www.llhd.org

Promoting healthy communities



[Out of the office from 11/25/2024 -12/1/2024](#)

From: Peter Gardner <dieter.gardner@yahoo.com>
Sent: Thursday, December 12, 2024 8:50 AM
To: Odalys Reyes Morales <oreyes@llhd.org>
Cc: planner@ledyardct.org <planner@ledyardct.org>
Subject: 5A Lorenz Industrial Parkway Ledyard

Odalys,

Re: 5A Lorenz Industrial Parkway Ledyard, Ct.

Plan has been revised to address your comments of 12/4/2024

1. No comment.
2. Perc tests are 30 feet apart, readings are correct.
3. System has been raised, see sanitary elevation data.
4. Pit will be dug as requested.
5. No comment.
6. Corrected pit numbers.
7. No comment.
8. I am sure the reference to 10' to 15' refers to vertical distance not horizontal. As is the case in really
all septic systems, the area around the system, probably up to 20 feet in most cases will be stripped of

vegetation, therefore setting a benchmark 10' to 15' horizontally from system is of no value.

9. No comment.