

**Laboratory Report - PbCu - Dist**

**Groton Utilities WTP Lab**

Samples from Template: **Ledyard Pb/Cu 2024 Fall**

1268 Poquonnock Road

Sample Set ID: **4212** Create Date: 10/23/2024 9:49:21 AM

Groton, CT 06340

(860) 446-4080

Sample ID Sample Location	Collection Date	1022 COPPER (DISTRIBUTION) mg/L	1030 LEAD (DISTRIBUTION) mg/L			
<b>40453</b> LEDYARD CENTER 13 CARTRIDGE TRAIL LC110	8/27/2024	0.014	0.090			
<b>40454</b> LEDYARD CENTER 5 TOWN FARM RD LC137	8/29/2024	0.011	0.0015			
<b>40455</b> LEDYARD CENTER 163 GALLUP HILL RD LC143	8/28/2024	0.013	ND <0.0010			
<b>40456</b> LEDYARD CENTER 3 PENNYWISE LANE LC130	8/29/2024	0.019	ND <0.0010			
<b>40457</b> LEDYARD CENTER 2 FIFERS LANE LC112	8/29/2024	0.020	ND <0.0010			
<b>40458</b> LEDYARD CENTER 1 THOMPSON ST LC135	8/30/2024	0.011	ND <0.0010			
<b>40459</b> LEDYARD CENTER 149 GALLUP HILL RD LC142	8/30/2024	0015	ND <0.0010			
<b>40460</b> LEDYARD CENTER 46 BLACKSMITH DR LC126	8/28/2024	0.0031	ND <0.0010			
<b>40461</b> LEDYARD CENTER 32 BLACKSMITH DR LC125	8/28/2024	0.012	ND <0.0010			
<b>40462</b> LEDYARD CENTER 12 MUSTER LANE LC134	8/27/2024	0.0084	ND <0.0010			
<b>40463</b> LEDYARD CENTER 82 MEETINGHOUSE LC155	8/27/2024	0.0061	ND <0.0010			
<b>40464</b> LEDYARD CENTER 12 BLACKWATCH LA LC128	8/28/2024	0.0077	ND <0.0010			
<b>40465</b> LEDYARD CENTER 139 GALLUP HILL RD LC141	8/28/2024	0.012	ND <0.0010			
<b>40466</b> LEDYARD CENTER 21 CARTRIDGE TRAIL LC111	8/28/2024	0.0089	ND <0.0010			
<b>40467</b> LEDYARD CENTER 42 HIGHLAND DR LC147	8/28/2024	0.0065	ND <0.0010			

**Laboratory Report - PbCu - Dist**

**Groton Utilities WTP Lab**

Samples from Template: **Ledyard Pb/Cu 2024 Fall**

1268 Poquonnock Road

Sample Set ID: **4212** Create Date: 10/23/2024 9:49:21 AM

Groton, CT 06340

(860) 446-4080

Sample ID Sample Location	Collection Date	1022 COPPER (DISTRIBUTION) mg/L	1030 LEAD (DISTRIBUTION) mg/L			
<b>40468</b> LEDYARD CENTER 57 MEETINGHOUSE LC153	8/28/2024	0.0092	ND <0.0010			
<b>40469</b> LEDYARD CENTER 1 SACHEM LANE LC103	8/28/2024	0.011	ND <0.0010			
<b>40470</b> LEDYARD CENTER 13 PENNYWISE LANE LC132	8/27/2024	0.045	ND <0.0010			
<b>40471</b> LEDYARD CENTER 122 MEETINGHOUSE LC157	8/27/2024	0.012	ND <0.0010			
<b>40472</b> LEDYARD CENTER 18 COUNTRY CLUB LC120	8/27/2024	0.0076	ND <0.0010			
<b>40473</b> LEDYARD CENTER 11 CARRIAGE TRAIL LC109	8/27/2024	0.0097	ND <0.0010			
<b>40474</b> LEDYARD CENTER 139 MEETINGHOUSE LC158	8/27/2024	0.0055	ND <0.0010			
<b>40475</b> LEDYARD CENTER 101 MEETINGHOUSE LC156	8/27/2024	0.0061	ND <0.0010			
<b>40476</b> LEDYARD CENTER 5 COUNTRY CLUB LC119	8/27/2024	0.0077	ND <0.0010			
<b>40477</b> LEDYARD CENTER 8 POWDER HORN DR LC100	8/27/2024	0.0062	ND <0.0010			
<b>40478</b> LEDYARD CENTER 15 TOWN FARM RD LC138	8/27/2024	0.0056	ND <0.0010			
<b>40479</b> LEDYARD CENTER 6 BLACKWATCH LA LC127	8/27/2024	0.015	ND <0.0010			
<b>40480</b> LEDYARD CENTER 23 TOWN FARM RD LC139	8/27/2024	0.013	ND <0.0010			
<b>40481</b> LEDYARD CENTER 12 WHITEWOOD LANE LC105	8/27/2024	0.0086	ND <0.0010			
<b>40482</b> LEDYARD CENTER 11 BLACKSMITH DR LC122	8/26/2024	0.0096	ND <0.0010			

**Laboratory Report - PbCu - Dist**Samples from Template: **Ledyard Pb/Cu 2024 Fall**Sample Set ID: **4212** Create Date: 10/23/2024 9:49:21 AM**Groton Utilities WTP Lab**

1268 Poquonnock Road

Groton, CT 06340

(860) 446-4080

Sample ID Sample Location	Collection Date	1022 COPPER (DISTRIBUTION) mg/L	1030 LEAD (DISTRIBUTION) mg/L			
<b>40483</b> LEDYARD CENTER 4 ASPEN LANE LC106	8/27/2024	0.0081	ND <0.0010			
<b>40484</b> LEDYARD CENTER 14 ROBIN LANE LC102	8/27/2024	0.015	ND <0.0010			
<b>40485</b> LEDYARD CENTER 9 PENNYWISE LANE LC131	8/27/2024	0.021	ND <0.0010			
<b>40486</b> LEDYARD CENTER 3 CHESTNUT LANE LC107	8/27/2024	0.0028	ND <0.0010			
<b>40487</b> LEDYARD CENTER 10 OLD FORT LANE LC129	8/27/2024	0.006	ND <0.0010			
<b>40488</b> LEDYARD CENTER 11 VILLAGE DRIVE LC117	8/26/2024	0.0075	ND <0.0010			
<b>40489</b> LEDYARD CENTER 25 HICKORY DRIVE LC116	8/27/2024	0.0046	ND <0.0010			
<b>40490</b> LEDYARD CENTER 20 VILLAGE DRIVE LC118	9/10/2024	0.013	ND <0.0010			
<b>40491</b> LEDYARD CENTER 13 VILLAGE DRIVE LC160	9/12/2024	0.0099	ND <0.0010			
<b>40492</b> LEDYARD CENTER 5 CARRIAGE TRAIL LC108	9/18/2024	0.013	ND <0.0010			

NOTES: All analyses performed by Complete Environmental Testing lab CT DPH registration #PH-0116.

Respectfully submitted,  
Groton Utilities WTP Lab

  
Stephen Dietrich  
Laboratory Director  
CT Lab# PH-0409