

# Stormwater Management Report

## Industrial Site Preparation Gales Ferry, Connecticut

September 28, 2023  
Revised September 24, 2024

Prepared for  
Gales Ferry Intermodal, LLC  
549 South Street  
Quincy, MA 02169



**Loureiro Engineering Associates, Inc.**

100 Northwest Drive • Plainville, CT 06062 • 860.747.6181 • Fax 860.747.8822 • [www.Loureiro.com](http://www.Loureiro.com)  
An Employee-Owned Company

Comm. No. 045JC2.06

---

**Stormwater Management Report**

**Industrial Site Preparation  
Gales Ferry, Connecticut**

**September 28, 2023  
Revised September 24, 2024**

**Prepared for**

**Gales Ferry Intermodal LLC  
549 South Street  
Quincy, MA 02169**

**Prepared by**

**LOUREIRO ENGINEERING ASSOCIATES, INC.  
100 Northwest Drive  
Plainville, Connecticut 06062**

*An Employee Owned Company*

**Comm. No. 045JC2.06**

---

---

## Table of Contents

	<b>Page</b>
<b>1. INTRODUCTION</b>	<b>1-1</b>
1.1 Physical Setting	1-1
1.2 Flood Plain and Soil Conditions	1-1
<b>2. EVALUATION OF EXISTING CONDITIONS</b>	<b>2-2</b>
2.1 Overview	2-2
2.2 Existing Stormwater Management	2-2
2.3 Existing Subcatchment Areas	2-2
<b>3. PROPOSED DEVELOPMENT</b>	<b>3-3</b>
3.1 Overview	3-3
3.2 Proposed Subcatchment Areas	3-3
3.3 Design Criteria & Proposed Stormwater Management Systems	3-3
<b>4. STORMWATER MANAGEMENT EVALUATION</b>	<b>4-5</b>
4.1 Stormwater Runoff Calculations	4-5
4.1.1 Design Methodology	4-5
4.1.2 Curve Numbers	4-5
4.2 Existing and Proposed Peak-Flow Comparison	4-6
4.3 Water Quality	4-6
4.3.1 Temporary Sediment Basin Design	4-7
4.4 Stormwater System Maintenance Program	4-7
<b>5. CONCLUSION</b>	<b>5-1</b>

## **DRAWINGS**

Drawing 1 – Existing Drainage Areas

Drawing 2 – Proposed Drainage Areas

## **APPENDICIES**

Appendix A – USGS Site Location Map

Appendix B – FEMA FIRMETTE Map

Appendix C – Natural Resources Conservation Service – Web Soil Survey

Appendix D – HydroCAD Reports

Appendix E – Water Quality Volume and Water Quality Flow Calculations

Appendix F – Temporary Sediment Basin Calculations

Appendix G – Stormwater Management Maintenance Program and Inspection Checklist

## **1. INTRODUCTION**

This stormwater management report has been prepared by Loureiro Engineering Associates, Inc. (Loureiro) on behalf of Gales Ferry Intermodal LLC to provide a description and calculations for the stormwater management for site regrading and preparation for future industrial development at 1761 Route 12 in Gales Ferry, Connecticut. The property is 165 acres with the proposed work encompassing approximately 38 acres of the property (hereinafter referred to as the “Site”). It is noteworthy that the drainage system designed for the project is an interim system that meets with the requirements included in the 2023 Drainage Manual. The use of this system is expected to be short-term, as the grading proposed is specifically designed to facilitate the development of building plots for industrial use in the future, which would follow shortly after the grading is complete.

### **1.1 Physical Setting**

The subject property is approximately 165 acres (ac) and is located in the Industrial zone (I). The property is the site of the former DOW Chemical manufacturing facility and has been an industrial use for years. A portion of the property is currently used for the manufacturing of Styrofoam products by Americas Styrenics, a tenant of the property. The DOW Chemical facilities at the property terminated their manufacturing existence in 2011 and the former DOW Chemical manufacturing buildings have been removed from the property. The property has rail service with a rail siding and waterfront with an existing pier.

The property has inland wetlands as well as Allyn’s Pond. One wetland referenced as the Z series wetland located to the east of the proposed grading activities will be eliminated. Wetlands referenced as the X and Y series may be impacted by the proposed activities due to the removal of a portion of the contributing watershed due to the proposed grading. Wetland mitigation was proposed and approved by the Town of Ledyard Inland Wetlands and Watercourses Commission.

The eastern boundary is bordered by Route 12 as well as some smaller industrial lots and a church that is in the R-40 zone. The western boundary is the Thames River. The northern boundary are residential lots in the R-40 zone. The southern boundary is bordered by properties zoned Commercial Marine (CM) and R-20.

### **1.2 Flood Plain and Soil Conditions**

Federal Emergency Management Agency’s (FEMA) National Flood Insurance Program (NFIP) Flood Insurance Rate Map (FIRM) Number 09011C0354G, effective July 18, 2011, for Town of

Ledyard identifies a portion of the property within the Zone AE (EL11) and Zone X. The only construction activities in areas of flood hazard are wetland mitigation activities. Appendix B includes the FEMA FIRM map for the Site.

The National Resource Conservation Service (NRCS) Soil Survey for the State of Connecticut identified soils within the Site area as Hinckley loamy sand (38E), Hollis-Chatfield-Rock Outcrop complex (75C, 75E, 76E), and as Urban Land (307). Hinckley loamy sand corresponds with the Hydrologic Soil Group (HSG) rating A, and Hollis-Chatfield-Rock outcrop complex corresponds with HSG rating D. Urban Land corresponds with the Hydrologic Soil Group (HSG) rating D. HSG A soils have high runoff potential, HSG B soils have moderately low runoff potential, and HSG D soils generally have slow or unpredictable infiltration rates correlating to high runoff potential. Appendix C includes the NRCS soil map for the site and surrounding area.

## **2. EVALUATION OF EXISTING CONDITIONS**

### **2.1 Overview**

The portion of the Site upon which the activities are proposed is currently undeveloped, with unpaved roads provided the only access to higher elevations of the Site. A transmission line and easement exist through the southern portion of the Site. The area of the Site is currently wooded or densely brushed, with zero percent (%) impervious coverage.

### **2.2 Existing Stormwater Management**

The majority of the Site currently has no existing drainage or stormwater management features. The wetlands to the northeast and west are connected by metal or concrete culverts, flowing to the south and then to the west towards the Thames River. The wooded area of the Site currently is a hill that flows north or south from its peak. Flow downslope to the south flows offsite, while flow downslope to the north flows towards the wetland system or Thames River.

Through available survey information and field visitation, the wetland system has no ultimate outlet discharge to the Thames River.

### **2.3 Existing Subcatchment Areas**

The total analyzed drainage area for the property is approximately 3,285,150 sf or 75.50 ac. The Site is divided into four (4) subcatchment areas. Subcatchment area 1 is comprised of the eastern wooded portion of the site, which flows downslope to the north into the northeastern wetland. Subcatchment area 2 is heavily wooded and flows north through surface flow into the wetland

system. Subcatchment area 3 includes the transmission line easement and flows south offsite. Subcatchment area 4 is the wooded western portion of the site and flows to the north towards the railroad tracks. Drawing 1, Existing Drainage Areas, depicts the existing drainage areas on the property. The four (4) points of compliance (POC) (West Wetlands, Northeast Wetland, South Off-Site, and West Off-Site) are utilized in HydroCAD to evaluate peak-flow leaving the property.

### **3. PROPOSED DEVELOPMENT**

#### **3.1 Overview**

The proposed work includes approximately 42 acres of regrading and rock blasting of the Site to provide space for future industrial development. No new structures are included in the construction activities proposed in this plan. An overall small percentage of disconnected impervious areas will be added by the exposure of bedrock. Final conditions will include grassed open space, vegetated rock benches, and a new stormwater management system.

#### **3.2 Proposed Subcatchment Areas**

The redeveloped Site and overall property is divided into eleven (11) subcatchment areas. Subcatchments 1, 2, 5, 7, and 11 will remain unchanged under new conditions. All other subcatchments will include open grass and graded rock areas that will drain to new stormwater basins. These basins will be connected with a pipe and manhole system that will discharge to the western wetlands. The Site work will result in an increase in impervious area for the property, increasing from zero percent (%) to 5.2 percent impervious for the Site. Drawing 2, Proposed Drainage Areas, depicts the new drainage areas on the property.

#### **3.3 Design Criteria & Proposed Stormwater Management Systems**

The post-development stormwater runoff analysis was based on the 2-, 10-, 25-, 50-, and 100-year 24-hour storm events. The removal of wooded areas requires on-site attenuation to meet the existing runoff rates as closely as possible.

The drainage improvements for the site will include a manhole and swale network to collect most of the newly graded areas. To attenuate and reduce peak flows, infiltration basins will be included in the drainage system. The system is designed to fully retain runoff up to the 100-year storm event. Any runoff that outlets from the system will flow into the existing wetland system north of the Site.

To improve stormwater quality discharging from the Site, the basins have been sized to hold and infiltrate the full water quality volume (WQV) for each basin's respective subcatchment. WQV calculations are provided in Appendix E.

## **4. STORMWATER MANAGEMENT EVALUATION**

### **4.1 Stormwater Runoff Calculations**

The following evaluation was prepared to identify the qualitative and quantitative stormwater runoff characteristics for the existing and proposed conditions at the site. The stormwater management system was designed for the 2-year, 10-year, 25-year, 50-year, and 100-year design storms.

#### **4.1.1 Design Methodology**

Site specific point precipitation frequency estimates used to generate peak stormwater flow were obtained from the National Oceanic and Atmospheric Administration (NOAA) Atlas 14, Volume 10 Version 3: Precipitation-Frequency Atlas of the United States, Northeastern States (rev. 2015). Precipitation-frequency estimates are based upon frequency analysis of partial duration series with a 90% confidence interval of data largely from the National Centers for Environmental Information (NCEI).

The methods described in Urban Hydrology for Small Watersheds, 2nd Edition, (Technical Release Number 55 [TR-55]) from the Natural Resources Conservation Service formerly the Soil Conservation Service – [SCS], 1986) were used to calculate stormwater peak-flow generated from pre- and post-redevelopment conditions. These methods, which are incorporated into the HydroCAD computer software program, use well documented procedures to calculate stormwater runoff volume, peak-flow rate of discharge, hydrographs and storage volumes required for floodwater reservoirs in small watersheds. The method uses the SCS Runoff Curve Number method to estimate runoff volume, calculates times of concentration, produces tabular hydrographs and estimates basin storage capacity.

#### **4.1.2 Curve Numbers**

The curve numbers (CN) values utilized for the analysis of the existing and proposed conditions included:

New grassed area, CN = 39 (Good grass cover, HSG A)

New grassed area, CN = 80 (Good grass cover, HSG D)

Brush, CN = 30 (good condition, HSG A)

Brush, CN = 56 (good condition, HSG B)

Brush, CN = 77 (good condition, HSG D)

Dirt roads, CN = 72 (HSG A)



- Dirt roads, CN = 89 (HSG D)
- Gravel roads, CN = 76 (HSG A)
- Gravel roads, CN = 91 (HSG D)
- Gravel surface (represents new access road), CN = 96 (HSG A, D)
- Unconnected pavement (represents exposed bedrock), CN = 98 (HSG A, D)
- Woods, CN = 30 (Good condition, HSG A)
- Woods, CN = 55 (Good condition, HSG B)
- Woods, CN = 77 (Good condition, HSG D)
- Woods/grass combo (represents new rock bench plantings), CN = 86 (HSG D)

The weighted CN of the existing property is 56. The weighted CN of the property with the new development is 62. This is due to the removal of wooded areas.

#### 4.2 Existing and Proposed Peak-Flow Comparison

With the use of detention, total peak flows are reduced during all analyzed storm events.

**Table 1 – Peak-Flow Comparison, Cubic Feet per Second**

	2-Year Event		10-Year Event		25-Year Event		50-year Event		100-year Event	
	Existing	Proposed	Existing	Proposed	Existing	Proposed	Existing	Proposed	Existing	Proposed
West Wetlands (POC 1)	0.69	0.56	7.91	2.88	17.51	11.26	26.55	22.29	37.44	35.89
West Off-Site (POC 2)	0.31	0.17	3.92	1.92	7.82	4.14	11.18	6.16	15.08	8.53
South Off-Site (POC 3)	15.37	10.95	30.07	21.38	39.67	28.19	46.96	33.4	54.78	38.98
Total	16.37	11.68	41.9	26.18	65	43.59	84.69	61.85	107.3	83.4

The table shows decreasing total peak flow runoff during all analyzed storm events. This is due to the robust infiltration basins capturing and retaining the Site’s runoff. Overall, new drainage conditions should function similarly to those of existing conditions. Appendix D includes the HydroCAD report for the existing and new Site analysis.

#### 4.3 Water Quality

The methods described in the 2023 Connecticut Stormwater Quality Manual (“the Manual”) were utilized to calculate the WQV of the redevelopment. The WQV for the site is equivalent to the runoff generated with the first 1.3 inches of rainfall. As flow from rock benches will enter grassed areas with low slopes before reaching infiltration basins, exposed impervious rock areas meet impervious disconnection criteria defined in the Manual. Each subcatchment was analyzed to determine its respective WQV. Low-level outlets were then designed to be above the WQV storage

elevation, meaning that WQVs will be fully retained and infiltrated on-site without discharging to the POCs.

As the basins will have a loam surface following completion of construction, an infiltration rate of 0.5 inches per hour (in/hr) was used in drainage calculations, in accordance with the Manual. The infiltration basins have also been designed to fully drain within 48 hours following a storm event, meeting State requirements.

The drainage system leads to a hydrodynamic separator before discharge to the wetlands. The basins will also allow suspended sediment to be settled and captured before stormwater is discharged.

#### 4.3.1 Temporary Sediment Basin Design

Each separate phase of this project will be equipped with a phase specific sediment basin serving the respective area. The sediment basins have been designed in accordance with the 2023 Connecticut Guidelines for Soil Erosion and Sediment Control. Each sediment basin will be equipped with adequate storage for a full-year of sediment and an outlet system designed to maximize the efficiency of the basin and pass the 25-year recurrence interval storm event. The related computations for the basin sizing, outlet system and outlet protection are included in Appendix F.

#### 4.4 Stormwater System Maintenance Program



To help facilitate the function and longevity of the stormwater management system, a maintenance program and inspection checklist has been developed for the components and surrounding areas. The maintenance includes periodic inspections, scheduled cleanings and details on identifying signs of failures in the system. A full checklist of system features shall be completed to provide a log of inspections, cleanings, repairs, and any important information regarding the system. The program will be implemented after installation with more frequent inspections early and fewer inspections after a year or when the system function becomes more predictable. The program, checklist, and past inspection/maintenance logs will be provided to the current or future owners and necessary facility personnel. The maintenance program and checklist are included as Appendix G.

## 5. CONCLUSION

The new Site work includes a new stormwater management system for the primary conveyance of the stormwater discharging from the Site. The proposed system provides attenuation and treatment of all stormwater events leaving the Site, managing post-development runoff rates. The stormwater basins include sufficient storage capacity for the WQV to offer treatment of Site stormwater. Overall, the new drainage system will improve water quality discharging from the property while providing lower flow rates to receiving areas.

## **DRAWINGS**

**Drawing 1 –Existing Drainage Areas**




<p><b>EXISTING DRAINAGE AREAS</b></p> <p><b>GALES FERRY INTERMODAL</b> 1737 &amp; 1761 ROUTE 12, GALES FERRY, CT 06335</p> <p><b>GALES FERRY INTERMODAL LLC</b> 349 SOUTH STREET, GALESFERRY, MA 02169</p>		<p>SCALE: 1" = 100'</p> <p>CONV. NO. 0451C2.06</p> <p>DATE: 9/28/2023</p> <p>DRAWN BY: APH</p> <p>APPROVED BY: GFA</p>	<p>DATE: 9/28/2023</p> <p>DATE: 9/28/2023</p>						
<p><b>1</b></p> <p>SHEET NO. 1 NO. OF SHEETS 2</p>		<p>STAMP</p> <p><b>Loureiro</b> Engineering &amp; Construction • EIT/ASA • EIT/ASA 100 Northwood Drive • Plainville, Connecticut 06062 Tel: 860-742-8822 • Fax: 860-742-8822 www.loureiro.com © Loureiro Engineering Associates, Inc. All rights reserved 2021.</p>	<p>DESCRIPTION OF REVISION</p> <table border="1"> <tr> <th>REV.</th> <th>DATE</th> <th>DESCRIPTION</th> </tr> <tr> <td> </td> <td> </td> <td> </td> </tr> </table>	REV.	DATE	DESCRIPTION			
REV.	DATE	DESCRIPTION							

**Drawing 2 – Proposed Drainage Areas**




<p><b>Loureiro</b> Engineering &amp; Construction • Energy • Surveying • Environmental • Geotechnical • Construction • Forestry</p> <p>100 Northwood Drive • Fairfield, Connecticut 06424          Phone: 860-247-9618 • Fax: 860-247-8822          All rights reserved 2021.</p>	
SCALE 1" = 100' CONN. NO. 0451C2.06	DATE 9/28/2023 DRAWN BY APH APPROVED BY GFA
<b>NEW DRAINAGE AREAS</b> <b>GALES FERRY INTERMODAL</b> 1737 & 1761 ROUTE 12, GALES FERRY, CT 06335 <b>GALES FERRY INTERMODAL LLC</b> 349 SOUTH STREET, QUINCY, MA 02169	
SHEET NO. 2	NO. OF SHEETS 2
REV.	DESCRIPTION OF REVISION
DATE	APPR.





**APPENDIX A**

**USGS Site Location Map**



**MAP REFERENCE:**

SECTION OF THE USGS 7.5 MINUTE SERIES TOPOGRAPHIC MAP FOR UNCASVILLE, CT; MAP VERSION DATE 2021.



**Loureiro**  
Engineering • Construction • EH&S • Energy  
Waste • Facility Services • Laboratory

**Loureiro Engineering Associates, Inc.**  
100 Fort Hill Road • Groton, Connecticut 06340  
Phone: 860-448-0400 • Fax: 860-448-0899  
An Employee Owned Company • www.Loureiro.com

©Loureiro Engineering Associates, Inc.  
All rights reserved 2023

**DRAINAGE REPORT  
ATTACHMENT A  
SITE LOCATION MAP**

---

**INDUSTRIAL SITE PREPARATION PLAN**  
1761 ROUTE 12, GALES FERRY, CT

PREPARED FOR:  
**GALES FERRY INTERMODAL LLC**  
549 SOUTH STREET, QUINCY, MA

SCALE	<b>1</b>
<b>1" = 2,000' ±</b>	
COMM. NO. <b>045JC2.06</b>	
DATE <b>9/28/2023</b>	



**APPENDIX B**

**FEMA FIREMETTE Map**

# National Flood Hazard Layer FIRMMette



72°5'22"W 41°26'35"N



1:6,000

72°4'44"W 41°26'8"N

Basemap Imagery Source: USGS National Map 2023

## Legend

SEE FIS REPORT FOR DETAILED LEGEND AND INDEX MAP FOR FIRM PANEL LAYOUT

SPECIAL FLOOD HAZARD AREAS	Without Base Flood Elevation (BFE) Zone A, V, A99	With BFE or Depth Zone AE, AO, AH, VE, AR
		Regulatory Floodway

OTHER AREAS OF FLOOD HAZARD	0.2% Annual Chance Flood Hazard, Areas of 1% annual chance flood with average depth less than one foot or with drainage areas of less than one square mile Zone X
	Future Conditions 1% Annual Chance Flood Hazard Zone X
	Area with Reduced Flood Risk due to Levee. See Notes. Zone X
	Area with Flood Risk due to Levee Zone D

OTHER AREAS	NO SCREEN Area of Minimal Flood Hazard Zone X
	Effective LOMRs
	Area of Undetermined Flood Hazard Zone D

GENERAL STRUCTURES	Channel, Culvert, or Storm Sewer
	Levee, Dike, or Floodwall

OTHER FEATURES	Cross Sections with 1% Annual Chance Water Surface Elevation
	20.2
	17.5
	Coastal Transect
	Base Flood Elevation Line (BFE)
	Limit of Study
	Jurisdiction Boundary
	Coastal Transect Baseline
	Profile Baseline
	Hydrographic Feature

MAP PANELS	Digital Data Available
	No Digital Data Available
	Unmapped

The pin displayed on the map is an approximate point selected by the user and does not represent an authoritative property location.

This map complies with FEMA's standards for the use of digital flood maps if it is not void as described below. The basemap shown complies with FEMA's basemap accuracy standards.

The flood hazard information is derived directly from the authoritative NFHL web services provided by FEMA. This map was exported on **9/25/2023 at 11:34 AM** and does not reflect changes or amendments subsequent to this date and time. The NFHL and effective information may change or become superseded by new data over time.

This map image is void if the one or more of the following map elements do not appear: basemap imagery, flood zone labels, legend, scale bar, map creation date, community identifiers, FIRM panel number, and FIRM effective date. Map images for unmapped and unmodernized areas cannot be used for regulatory purposes.

## **APPENDIX C**

### **Natural Resources Conservation Service – Web Soil Survey**



United States  
Department of  
Agriculture

NRCS

Natural  
Resources  
Conservation  
Service

A product of the National  
Cooperative Soil Survey,  
a joint effort of the United  
States Department of  
Agriculture and other  
Federal agencies, State  
agencies including the  
Agricultural Experiment  
Stations, and local  
participants

# Custom Soil Resource Report for State of Connecticut, Eastern Part



# Preface

---

Soil surveys contain information that affects land use planning in survey areas. They highlight soil limitations that affect various land uses and provide information about the properties of the soils in the survey areas. Soil surveys are designed for many different users, including farmers, ranchers, foresters, agronomists, urban planners, community officials, engineers, developers, builders, and home buyers. Also, conservationists, teachers, students, and specialists in recreation, waste disposal, and pollution control can use the surveys to help them understand, protect, or enhance the environment.

Various land use regulations of Federal, State, and local governments may impose special restrictions on land use or land treatment. Soil surveys identify soil properties that are used in making various land use or land treatment decisions. The information is intended to help the land users identify and reduce the effects of soil limitations on various land uses. The landowner or user is responsible for identifying and complying with existing laws and regulations.

Although soil survey information can be used for general farm, local, and wider area planning, onsite investigation is needed to supplement this information in some cases. Examples include soil quality assessments (<http://www.nrcs.usda.gov/wps/portal/nrcs/main/soils/health/>) and certain conservation and engineering applications. For more detailed information, contact your local USDA Service Center (<https://offices.sc.egov.usda.gov/locator/app?agency=nrcs>) or your NRCS State Soil Scientist ([http://www.nrcs.usda.gov/wps/portal/nrcs/detail/soils/contactus/?cid=nrcs142p2\\_053951](http://www.nrcs.usda.gov/wps/portal/nrcs/detail/soils/contactus/?cid=nrcs142p2_053951)).

Great differences in soil properties can occur within short distances. Some soils are seasonally wet or subject to flooding. Some are too unstable to be used as a foundation for buildings or roads. Clayey or wet soils are poorly suited to use as septic tank absorption fields. A high water table makes a soil poorly suited to basements or underground installations.

The National Cooperative Soil Survey is a joint effort of the United States Department of Agriculture and other Federal agencies, State agencies including the Agricultural Experiment Stations, and local agencies. The Natural Resources Conservation Service (NRCS) has leadership for the Federal part of the National Cooperative Soil Survey.

Information about soils is updated periodically. Updated information is available through the NRCS Web Soil Survey, the site for official soil survey information.

The U.S. Department of Agriculture (USDA) prohibits discrimination in all its programs and activities on the basis of race, color, national origin, age, disability, and where applicable, sex, marital status, familial status, parental status, religion, sexual orientation, genetic information, political beliefs, reprisal, or because all or a part of an individual's income is derived from any public assistance program. (Not all prohibited bases apply to all programs.) Persons with disabilities who require

alternative means for communication of program information (Braille, large print, audiotape, etc.) should contact USDA's TARGET Center at (202) 720-2600 (voice and TDD). To file a complaint of discrimination, write to USDA, Director, Office of Civil Rights, 1400 Independence Avenue, S.W., Washington, D.C. 20250-9410 or call (800) 795-3272 (voice) or (202) 720-6382 (TDD). USDA is an equal opportunity provider and employer.



# Contents

---

<b>Preface</b> .....	2
<b>Soil Map</b> .....	5
Soil Map.....	6
Legend.....	7
Map Unit Legend.....	8
Map Unit Descriptions.....	8
State of Connecticut, Eastern Part.....	11
3—Ridgebury, Leicester, and Whitman soils, 0 to 8 percent slopes, extremely stony.....	11
18—Catden and Freetown soils, 0 to 2 percent slopes.....	13
34B—Merrimac fine sandy loam, 3 to 8 percent slopes.....	16
38E—Hinckley loamy sand, 15 to 45 percent slopes.....	17
50B—Sutton fine sandy loam, 3 to 8 percent slopes.....	19
61C—Canton and Charlton fine sandy loams, 8 to 15 percent slopes, very stony.....	21
62D—Canton and Charlton fine sandy loams, 15 to 35 percent slopes, extremely stony.....	23
73C—Charlton-Chatfield complex, 0 to 15 percent slopes, very rocky.....	26
75C—Hollis-Chatfield-Rock outcrop complex, 3 to 15 percent slopes.....	28
75E—Hollis-Chatfield-Rock outcrop complex, 15 to 45 percent slopes.....	31
76E—Rock outcrop-Hollis complex, 3 to 45 percent slopes.....	33
306—Udorthents-Urban land complex.....	35
307—Urban land.....	37
702B—Tisbury silt loam, 3 to 8 percent slopes.....	37
W—Water.....	39
<b>Soil Information for All Uses</b> .....	40
Soil Properties and Qualities.....	40
Soil Qualities and Features.....	40
Hydrologic Soil Group.....	40

# Soil Map


---

The soil map section includes the soil map for the defined area of interest, a list of soil map units on the map and extent of each map unit, and cartographic symbols displayed on the map. Also presented are various metadata about data used to produce the map, and a description of each soil map unit.

# Custom Soil Resource Report Soil Map




Map Scale: 1:8,020 if printed on A portrait (8.5" x 11") sheet.




Map projection: Web Mercator Corner coordinates: WGS84 Edge tics: UTM Zone 18N WGS84

### MAP LEGEND

**Area of Interest (AOI)**

 Area of Interest (AOI)

**Soils**

 Soil Map Unit Polygons

 Soil Map Unit Lines


 Soil Map Unit Points

**Special Point Features**






-  Blowout
-  Borrow Pit
-  Clay Spot
-  Closed Depression
-  Gravel Pit
-  Gravelly Spot
-  Landfill
-  Lava Flow
-  Marsh or swamp
-  Mine or Quarry
-  Miscellaneous Water
-  Perennial Water
-  Rock Outcrop
-  Saline Spot
-  Sandy Spot
-  Severely Eroded Spot
-  Sinkhole
-  Slide or Slip
-  Sodic Spot

-  Spoil Area
-  Stony Spot
-  Very Stony Spot
-  Wet Spot
-  Other
-  Special Line Features

**Water Features**

 Streams and Canals

**Transportation**

-  Rails
-  Interstate Highways
-  US Routes
-  Major Roads
-  Local Roads

**Background**

 Aerial Photography

### MAP INFORMATION

The soil surveys that comprise your AOI were mapped at 1:12,000.

Please rely on the bar scale on each map sheet for map measurements.

Source of Map: Natural Resources Conservation Service  
 Web Soil Survey URL:  
 Coordinate System: Web Mercator (EPSG:3857)

Maps from the Web Soil Survey are based on the Web Mercator projection, which preserves direction and shape but distorts distance and area. A projection that preserves area, such as the Albers equal-area conic projection, should be used if more accurate calculations of distance or area are required.

This product is generated from the USDA-NRCS certified data as of the version date(s) listed below.

Soil Survey Area: State of Connecticut, Eastern Part  
 Survey Area Data: Version 1, Sep 15, 2023

Soil map units are labeled (as space allows) for map scales 1:50,000 or larger.

Date(s) aerial images were photographed: Jun 14, 2022—Oct 6, 2022

The orthophoto or other base map on which the soil lines were compiled and digitized probably differs from the background imagery displayed on these maps. As a result, some minor shifting of map unit boundaries may be evident.

## Map Unit Legend

Map Unit Symbol	Map Unit Name	Acres in AOI	Percent of AOI
3	Ridgebury, Leicester, and Whitman soils, 0 to 8 percent slopes, extremely stony	3.9	1.9%
18	Catden and Freetown soils, 0 to 2 percent slopes	0.1	0.0%
34B	Merrimac fine sandy loam, 3 to 8 percent slopes	1.8	0.9%
38E	Hinckley loamy sand, 15 to 45 percent slopes	40.5	20.2%
50B	Sutton fine sandy loam, 3 to 8 percent slopes	3.2	1.6%
61C	Canton and Charlton fine sandy loams, 8 to 15 percent slopes, very stony	4.1	2.1%
62D	Canton and Charlton fine sandy loams, 15 to 35 percent slopes, extremely stony	3.6	1.8%
73C	Charlton-Chatfield complex, 0 to 15 percent slopes, very rocky	2.5	1.3%
75C	Hollis-Chatfield-Rock outcrop complex, 3 to 15 percent slopes	19.3	9.6%
75E	Hollis-Chatfield-Rock outcrop complex, 15 to 45 percent slopes	51.3	25.6%
76E	Rock outcrop-Hollis complex, 3 to 45 percent slopes	16.2	8.1%
306	Udorthents-Urban land complex	22.8	11.4%
307	Urban land	8.8	4.4%
702B	Tisbury silt loam, 3 to 8 percent slopes	0.1	0.1%
W	Water	21.9	10.9%
<b>Totals for Area of Interest</b>		<b>200.3</b>	<b>100.0%</b>

## Map Unit Descriptions

The map units delineated on the detailed soil maps in a soil survey represent the soils or miscellaneous areas in the survey area. The map unit descriptions, along with the maps, can be used to determine the composition and properties of a unit.

A map unit delineation on a soil map represents an area dominated by one or more major kinds of soil or miscellaneous areas. A map unit is identified and named according to the taxonomic classification of the dominant soils. Within a taxonomic

## Custom Soil Resource Report

class there are precisely defined limits for the properties of the soils. On the landscape, however, the soils are natural phenomena, and they have the characteristic variability of all natural phenomena. Thus, the range of some observed properties may extend beyond the limits defined for a taxonomic class. Areas of soils of a single taxonomic class rarely, if ever, can be mapped without including areas of other taxonomic classes. Consequently, every map unit is made up of the soils or miscellaneous areas for which it is named and some minor components that belong to taxonomic classes other than those of the major soils.

Most minor soils have properties similar to those of the dominant soil or soils in the map unit, and thus they do not affect use and management. These are called noncontrasting, or similar, components. They may or may not be mentioned in a particular map unit description. Other minor components, however, have properties and behavioral characteristics divergent enough to affect use or to require different management. These are called contrasting, or dissimilar, components. They generally are in small areas and could not be mapped separately because of the scale used. Some small areas of strongly contrasting soils or miscellaneous areas are identified by a special symbol on the maps. If included in the database for a given area, the contrasting minor components are identified in the map unit descriptions along with some characteristics of each. A few areas of minor components may not have been observed, and consequently they are not mentioned in the descriptions, especially where the pattern was so complex that it was impractical to make enough observations to identify all the soils and miscellaneous areas on the landscape.

The presence of minor components in a map unit in no way diminishes the usefulness or accuracy of the data. The objective of mapping is not to delineate pure taxonomic classes but rather to separate the landscape into landforms or landform segments that have similar use and management requirements. The delineation of such segments on the map provides sufficient information for the development of resource plans. If intensive use of small areas is planned, however, onsite investigation is needed to define and locate the soils and miscellaneous areas.

An identifying symbol precedes the map unit name in the map unit descriptions. Each description includes general facts about the unit and gives important soil properties and qualities.

Soils that have profiles that are almost alike make up a *soil series*. Except for differences in texture of the surface layer, all the soils of a series have major horizons that are similar in composition, thickness, and arrangement.

Soils of one series can differ in texture of the surface layer, slope, stoniness, salinity, degree of erosion, and other characteristics that affect their use. On the basis of such differences, a soil series is divided into *soil phases*. Most of the areas shown on the detailed soil maps are phases of soil series. The name of a soil phase commonly indicates a feature that affects use or management. For example, Alpha silt loam, 0 to 2 percent slopes, is a phase of the Alpha series.

Some map units are made up of two or more major soils or miscellaneous areas. These map units are complexes, associations, or undifferentiated groups.

A *complex* consists of two or more soils or miscellaneous areas in such an intricate pattern or in such small areas that they cannot be shown separately on the maps. The pattern and proportion of the soils or miscellaneous areas are somewhat similar in all areas. Alpha-Beta complex, 0 to 6 percent slopes, is an example.

## Custom Soil Resource Report

An *association* is made up of two or more geographically associated soils or miscellaneous areas that are shown as one unit on the maps. Because of present or anticipated uses of the map units in the survey area, it was not considered practical or necessary to map the soils or miscellaneous areas separately. The pattern and relative proportion of the soils or miscellaneous areas are somewhat similar. Alpha-Beta association, 0 to 2 percent slopes, is an example.

An *undifferentiated group* is made up of two or more soils or miscellaneous areas that could be mapped individually but are mapped as one unit because similar interpretations can be made for use and management. The pattern and proportion of the soils or miscellaneous areas in a mapped area are not uniform. An area can be made up of only one of the major soils or miscellaneous areas, or it can be made up of all of them. Alpha and Beta soils, 0 to 2 percent slopes, is an example.

Some surveys include *miscellaneous areas*. Such areas have little or no soil material and support little or no vegetation. Rock outcrop is an example.

## State of Connecticut, Eastern Part

### 3—Ridgebury, Leicester, and Whitman soils, 0 to 8 percent slopes, extremely stony

#### Map Unit Setting

*National map unit symbol:* 2t2qt  
*Elevation:* 0 to 1,480 feet  
*Mean annual precipitation:* 36 to 71 inches  
*Mean annual air temperature:* 39 to 55 degrees F  
*Frost-free period:* 140 to 240 days  
*Farmland classification:* Not prime farmland

#### Map Unit Composition

*Ridgebury, extremely stony, and similar soils:* 40 percent  
*Leicester, extremely stony, and similar soils:* 35 percent  
*Whitman, extremely stony, and similar soils:* 17 percent  
*Minor components:* 8 percent  
*Estimates are based on observations, descriptions, and transects of the mapunit.*

#### Description of Ridgebury, Extremely Stony

##### Setting

*Landform:* Drumlins, ground moraines, hills, drainageways, depressions  
*Landform position (two-dimensional):* Toeslope, footslope  
*Landform position (three-dimensional):* Base slope, head slope  
*Down-slope shape:* Concave  
*Across-slope shape:* Concave  
*Parent material:* Coarse-loamy lodgment till derived from gneiss, granite, and/or schist

##### Typical profile

*Oe - 0 to 1 inches:* moderately decomposed plant material  
*A - 1 to 6 inches:* fine sandy loam  
*Bw - 6 to 10 inches:* sandy loam  
*Bg - 10 to 19 inches:* gravelly sandy loam  
*Cd - 19 to 66 inches:* gravelly sandy loam

##### Properties and qualities

*Slope:* 0 to 8 percent  
*Surface area covered with cobbles, stones or boulders:* 9.0 percent  
*Depth to restrictive feature:* 15 to 35 inches to densic material  
*Drainage class:* Poorly drained  
*Runoff class:* Very high  
*Capacity of the most limiting layer to transmit water (Ksat):* Very low to moderately low (0.00 to 0.14 in/hr)  
*Depth to water table:* About 0 to 6 inches  
*Frequency of flooding:* None  
*Frequency of ponding:* None  
*Maximum salinity:* Nonsaline (0.0 to 1.9 mmhos/cm)  
*Available water supply, 0 to 60 inches:* Low (about 3.0 inches)

##### Interpretive groups

*Land capability classification (irrigated):* None specified  
*Land capability classification (nonirrigated):* 7s



## Custom Soil Resource Report

*Hydrologic Soil Group:* D  
*Ecological site:* F144AY009CT - Wet Till Depressions  
*Hydric soil rating:* Yes

### Description of Leicester, Extremely Stony

#### Setting

*Landform:* Ground moraines, hills, drainageways, depressions  
*Landform position (two-dimensional):* Toeslope, footslope  
*Landform position (three-dimensional):* Base slope  
*Down-slope shape:* Concave, linear  
*Across-slope shape:* Concave  
*Parent material:* Coarse-loamy melt-out till derived from gneiss, granite, and/or schist

#### Typical profile

*Oe - 0 to 1 inches:* moderately decomposed plant material  
*A - 1 to 7 inches:* fine sandy loam  
*Bg - 7 to 18 inches:* fine sandy loam  
*BC - 18 to 24 inches:* fine sandy loam  
*C1 - 24 to 39 inches:* gravelly fine sandy loam  
*C2 - 39 to 65 inches:* gravelly fine sandy loam

#### Properties and qualities

*Slope:* 0 to 8 percent  
*Surface area covered with cobbles, stones or boulders:* 9.0 percent  
*Depth to restrictive feature:* More than 80 inches  
*Drainage class:* Poorly drained  
*Runoff class:* Very high  
*Capacity of the most limiting layer to transmit water (Ksat):* Moderately low to high (0.14 to 14.17 in/hr)  
*Depth to water table:* About 0 to 6 inches  
*Frequency of flooding:* None  
*Frequency of ponding:* None  
*Maximum salinity:* Nonsaline (0.0 to 1.9 mmhos/cm)  
*Available water supply, 0 to 60 inches:* High (about 9.0 inches)

#### Interpretive groups

*Land capability classification (irrigated):* None specified  
*Land capability classification (nonirrigated):* 7s  
*Hydrologic Soil Group:* B/D  
*Ecological site:* F144AY009CT - Wet Till Depressions  
*Hydric soil rating:* Yes

### Description of Whitman, Extremely Stony

#### Setting

*Landform:* Drumlins, ground moraines, hills, drainageways, depressions  
*Landform position (two-dimensional):* Toeslope  
*Landform position (three-dimensional):* Base slope  
*Down-slope shape:* Concave  
*Across-slope shape:* Concave  
*Parent material:* Coarse-loamy lodgment till derived from gneiss, granite, and/or schist

#### Typical profile

*Oi - 0 to 1 inches:* peat

## Custom Soil Resource Report

*A - 1 to 10 inches: fine sandy loam*  
*Bg - 10 to 17 inches: gravelly fine sandy loam*  
*Cdg - 17 to 61 inches: fine sandy loam*

### Properties and qualities

*Slope: 0 to 3 percent*  
*Surface area covered with cobbles, stones or boulders: 9.0 percent*  
*Depth to restrictive feature: 7 to 38 inches to densic material*  
*Drainage class: Very poorly drained*  
*Runoff class: Negligible*  
*Capacity of the most limiting layer to transmit water (Ksat): Very low to moderately low (0.00 to 0.14 in/hr)*  
*Depth to water table: About 0 to 6 inches*  
*Frequency of flooding: None*  
*Frequency of ponding: Frequent*  
*Maximum salinity: Nonsaline (0.0 to 1.9 mmhos/cm)*  
*Available water supply, 0 to 60 inches: Low (about 3.0 inches)*

### Interpretive groups

*Land capability classification (irrigated): None specified*  
*Land capability classification (nonirrigated): 7s*  
*Hydrologic Soil Group: D*  
*Ecological site: F144AY009CT - Wet Till Depressions*  
*Hydric soil rating: Yes*

### Minor Components

#### Woodbridge, extremely stony

*Percent of map unit: 6 percent*  
*Landform: Hills, drumlins, ground moraines*  
*Landform position (two-dimensional): Backslope, footslope, summit*  
*Landform position (three-dimensional): Side slope, crest*  
*Down-slope shape: Concave*  
*Across-slope shape: Linear*  
*Hydric soil rating: No*

#### Swansea

*Percent of map unit: 2 percent*  
*Landform: Bogs, swamps*  
*Down-slope shape: Concave*  
*Across-slope shape: Concave*  
*Hydric soil rating: Yes*

## 18—Catden and Freetown soils, 0 to 2 percent slopes

### Map Unit Setting

*National map unit symbol: 2t2r2*  
*Elevation: 0 to 1,390 feet*

## Custom Soil Resource Report

*Mean annual precipitation:* 36 to 71 inches  
*Mean annual air temperature:* 39 to 55 degrees F  
*Frost-free period:* 140 to 240 days  
*Farmland classification:* Not prime farmland

### Map Unit Composition

*Catden and similar soils:* 45 percent  
*Freetown and similar soils:* 35 percent  
*Minor components:* 20 percent  
*Estimates are based on observations, descriptions, and transects of the mapunit.*

### Description of Catden

#### Setting

*Landform:* Depressions, bogs, fens, depressions, depressions, kettles, marshes, swamps  
*Landform position (three-dimensional):* Base slope, tread  
*Down-slope shape:* Concave  
*Across-slope shape:* Concave  
*Parent material:* Highly decomposed herbaceous organic material and/or highly decomposed woody organic material

#### Typical profile

*Oa1 - 0 to 2 inches:* muck  
*Oa2 - 2 to 79 inches:* muck

#### Properties and qualities

*Slope:* 0 to 2 percent  
*Surface area covered with cobbles, stones or boulders:* 0.0 percent  
*Depth to restrictive feature:* More than 80 inches  
*Drainage class:* Very poorly drained  
*Runoff class:* Negligible  
*Capacity of the most limiting layer to transmit water (Ksat):* Moderately low to high (0.14 to 14.17 in/hr)  
*Depth to water table:* About 0 to 6 inches  
*Frequency of flooding:* Rare  
*Frequency of ponding:* Frequent  
*Maximum salinity:* Nonsaline (0.0 to 1.9 mmhos/cm)  
*Available water supply, 0 to 60 inches:* Very high (about 26.9 inches)

#### Interpretive groups

*Land capability classification (irrigated):* None specified  
*Land capability classification (nonirrigated):* 5w  
*Hydrologic Soil Group:* B/D  
*Ecological site:* F144AY042NY - Semi-Rich Organic Wetlands  
*Hydric soil rating:* Yes

### Description of Freetown

#### Setting

*Landform:* Depressions, marshes, depressions, bogs, swamps, kettles  
*Landform position (three-dimensional):* Tread, dip  
*Down-slope shape:* Concave  
*Across-slope shape:* Concave  
*Parent material:* Highly decomposed organic material

## Custom Soil Resource Report

### Typical profile

*Oe - 0 to 2 inches:* mucky peat  
*Oa - 2 to 79 inches:* muck

### Properties and qualities

*Slope:* 0 to 2 percent  
*Surface area covered with cobbles, stones or boulders:* 0.0 percent  
*Depth to restrictive feature:* More than 80 inches  
*Drainage class:* Very poorly drained  
*Runoff class:* Negligible  
*Capacity of the most limiting layer to transmit water (Ksat):* Moderately low to high  
(0.14 to 14.17 in/hr)  
*Depth to water table:* About 0 to 6 inches  
*Frequency of flooding:* Rare  
*Frequency of ponding:* Frequent  
*Available water supply, 0 to 60 inches:* Very high (about 26.9 inches)

### Interpretive groups

*Land capability classification (irrigated):* None specified  
*Land capability classification (nonirrigated):* 5w  
*Hydrologic Soil Group:* B/D  
*Ecological site:* F144AY043MA - Acidic Organic Wetlands  
*Hydric soil rating:* Yes

### Minor Components

#### Natchaug

*Percent of map unit:* 7 percent  
*Landform:* Depressions, depressions, depressions  
*Landform position (three-dimensional):* Base slope, tread  
*Down-slope shape:* Concave  
*Across-slope shape:* Concave  
*Hydric soil rating:* Yes

#### Whitman

*Percent of map unit:* 6 percent  
*Landform:* Drainageways, depressions  
*Landform position (three-dimensional):* Base slope  
*Down-slope shape:* Concave  
*Across-slope shape:* Concave  
*Hydric soil rating:* Yes

#### Timakwa

*Percent of map unit:* 5 percent  
*Landform:* Depressions  
*Landform position (three-dimensional):* Base slope  
*Down-slope shape:* Concave  
*Across-slope shape:* Concave  
*Hydric soil rating:* Yes

#### Scarboro

*Percent of map unit:* 2 percent  
*Landform:* Depressions, drainageways, outwash deltas, outwash terraces  
*Landform position (three-dimensional):* Base slope, tread, dip  
*Down-slope shape:* Concave  
*Across-slope shape:* Concave, linear  
*Hydric soil rating:* Yes

## 34B—Merrimac fine sandy loam, 3 to 8 percent slopes

### Map Unit Setting

*National map unit symbol:* 2tyqs

*Elevation:* 0 to 1,290 feet

*Mean annual precipitation:* 36 to 71 inches

*Mean annual air temperature:* 39 to 55 degrees F

*Frost-free period:* 140 to 240 days

*Farmland classification:* All areas are prime farmland

### Map Unit Composition

*Merrimac and similar soils:* 85 percent

*Minor components:* 15 percent

*Estimates are based on observations, descriptions, and transects of the mapunit.*

### Description of Merrimac

#### Setting

*Landform:* Outwash plains, outwash terraces, moraines, eskers, kames

*Landform position (two-dimensional):* Backslope, footslope, summit, shoulder

*Landform position (three-dimensional):* Side slope, crest, riser, tread

*Down-slope shape:* Convex

*Across-slope shape:* Convex

*Parent material:* Loamy glaciofluvial deposits derived from granite, schist, and gneiss over sandy and gravelly glaciofluvial deposits derived from granite, schist, and gneiss

#### Typical profile

*Ap - 0 to 10 inches:* fine sandy loam

*Bw1 - 10 to 22 inches:* fine sandy loam

*Bw2 - 22 to 26 inches:* stratified gravel to gravelly loamy sand

*2C - 26 to 65 inches:* stratified gravel to very gravelly sand

#### Properties and qualities

*Slope:* 3 to 8 percent

*Depth to restrictive feature:* More than 80 inches

*Drainage class:* Somewhat excessively drained

*Runoff class:* Very low

*Capacity of the most limiting layer to transmit water (Ksat):* Moderately high to very high (1.42 to 99.90 in/hr)

*Depth to water table:* More than 80 inches

*Frequency of flooding:* None

*Frequency of ponding:* None

*Calcium carbonate, maximum content:* 2 percent

*Maximum salinity:* Nonsaline (0.0 to 1.4 mmhos/cm)

*Sodium adsorption ratio, maximum:* 1.0

*Available water supply, 0 to 60 inches:* Low (about 4.6 inches)

**Interpretive groups**

*Land capability classification (irrigated):* None specified  
*Land capability classification (nonirrigated):* 2s  
*Hydrologic Soil Group:* A  
*Ecological site:* F145XY008MA - Dry Outwash  
*Hydric soil rating:* No

**Minor Components**

**Sudbury**

*Percent of map unit:* 5 percent  
*Landform:* Deltas, terraces, outwash plains  
*Landform position (two-dimensional):* Footslope  
*Landform position (three-dimensional):* Tread, dip  
*Down-slope shape:* Concave  
*Across-slope shape:* Linear  
*Hydric soil rating:* No

**Hinckley**

*Percent of map unit:* 5 percent  
*Landform:* Deltas, kames, eskers, outwash plains  
*Landform position (two-dimensional):* Summit, shoulder, backslope  
*Landform position (three-dimensional):* Nose slope, side slope, crest, head slope, rise  
*Down-slope shape:* Convex  
*Across-slope shape:* Convex, linear  
*Hydric soil rating:* No

**Windsor**

*Percent of map unit:* 3 percent  
*Landform:* Outwash terraces, dunes, deltas, outwash plains  
*Landform position (two-dimensional):* Shoulder  
*Landform position (three-dimensional):* Tread, riser  
*Down-slope shape:* Linear, convex  
*Across-slope shape:* Linear, convex  
*Hydric soil rating:* No

**Agawam**

*Percent of map unit:* 2 percent  
*Landform:* Outwash plains, outwash terraces, moraines, stream terraces, eskers, kames  
*Landform position (three-dimensional):* Rise  
*Down-slope shape:* Convex  
*Across-slope shape:* Convex  
*Hydric soil rating:* No

**38E—Hinckley loamy sand, 15 to 45 percent slopes**

**Map Unit Setting**

*National map unit symbol:* 2svmj

## Custom Soil Resource Report

*Elevation:* 0 to 1,280 feet  
*Mean annual precipitation:* 36 to 71 inches  
*Mean annual air temperature:* 39 to 55 degrees F  
*Frost-free period:* 140 to 240 days  
*Farmland classification:* Not prime farmland

### Map Unit Composition

*Hinckley and similar soils:* 85 percent  
*Minor components:* 15 percent  
*Estimates are based on observations, descriptions, and transects of the mapunit.*

### Description of Hinckley

#### Setting

*Landform:* Eskers, kames, outwash deltas, outwash terraces, moraines, outwash plains, kame terraces  
*Landform position (two-dimensional):* Backslope  
*Landform position (three-dimensional):* Nose slope, side slope, crest, head slope, riser  
*Down-slope shape:* Concave, convex, linear  
*Across-slope shape:* Convex, linear, concave  
*Parent material:* Sandy and gravelly glaciofluvial deposits derived from gneiss and/or granite and/or schist

#### Typical profile

*Oe - 0 to 1 inches:* moderately decomposed plant material  
*A - 1 to 8 inches:* loamy sand  
*Bw1 - 8 to 11 inches:* gravelly loamy sand  
*Bw2 - 11 to 16 inches:* gravelly loamy sand  
*BC - 16 to 19 inches:* very gravelly loamy sand  
*C - 19 to 65 inches:* very gravelly sand

#### Properties and qualities

*Slope:* 15 to 45 percent  
*Depth to restrictive feature:* More than 80 inches  
*Drainage class:* Excessively drained  
*Runoff class:* Low  
*Capacity of the most limiting layer to transmit water (Ksat):* Moderately high to very high (1.42 to 99.90 in/hr)  
*Depth to water table:* More than 80 inches  
*Frequency of flooding:* None  
*Frequency of ponding:* None  
*Maximum salinity:* Nonsaline (0.0 to 1.9 mmhos/cm)  
*Available water supply, 0 to 60 inches:* Low (about 3.1 inches)

#### Interpretive groups

*Land capability classification (irrigated):* None specified  
*Land capability classification (nonirrigated):* 7e  
*Hydrologic Soil Group:* A  
*Ecological site:* F144AY022MA - Dry Outwash  
*Hydric soil rating:* No

### Minor Components

#### Merrimac

*Percent of map unit:* 5 percent  
*Landform:* Outwash plains, outwash terraces, moraines, eskers, kames

## Custom Soil Resource Report

*Landform position (two-dimensional):* Backslope

*Landform position (three-dimensional):* Side slope, crest, head slope, nose slope, riser

*Down-slope shape:* Convex

*Across-slope shape:* Convex

*Hydric soil rating:* No

### **Windsor**

*Percent of map unit:* 5 percent

*Landform:* Eskers, kames, moraines, outwash deltas, outwash terraces, outwash plains, kame terraces

*Landform position (two-dimensional):* Backslope

*Landform position (three-dimensional):* Nose slope, side slope, crest, head slope, riser

*Down-slope shape:* Concave, convex, linear

*Across-slope shape:* Convex, linear, concave

*Hydric soil rating:* No

### **Agawam**

*Percent of map unit:* 3 percent

*Landform:* Eskers, kame terraces, outwash deltas, outwash terraces, moraines, kames, outwash plains

*Landform position (two-dimensional):* Backslope

*Landform position (three-dimensional):* Nose slope, side slope, crest, head slope, riser

*Down-slope shape:* Concave, convex, linear

*Across-slope shape:* Convex, linear, concave

*Hydric soil rating:* No

### **Sudbury**

*Percent of map unit:* 2 percent

*Landform:* Kames, eskers, outwash deltas, outwash plains, kame terraces, outwash terraces, moraines

*Landform position (two-dimensional):* Footslope, backslope

*Landform position (three-dimensional):* Base slope, tread

*Down-slope shape:* Concave, linear

*Across-slope shape:* Linear, concave

*Hydric soil rating:* No

## **50B—Sutton fine sandy loam, 3 to 8 percent slopes**

### **Map Unit Setting**

*National map unit symbol:* 2w69j

*Elevation:* 0 to 1,410 feet

*Mean annual precipitation:* 36 to 71 inches

*Mean annual air temperature:* 39 to 55 degrees F

*Frost-free period:* 140 to 240 days

*Farmland classification:* All areas are prime farmland



**Map Unit Composition**

*Sutton and similar soils:* 80 percent

*Minor components:* 20 percent

*Estimates are based on observations, descriptions, and transects of the mapunit.*

**Description of Sutton**

**Setting**

*Landform:* Ridges, ground moraines, hills

*Landform position (two-dimensional):* Footslope

*Landform position (three-dimensional):* Base slope

*Down-slope shape:* Concave

*Across-slope shape:* Linear

*Parent material:* Coarse-loamy melt-out till derived from gneiss, granite, and/or schist

**Typical profile**

*Ap - 0 to 5 inches:* fine sandy loam

*Bw1 - 5 to 17 inches:* fine sandy loam

*Bw2 - 17 to 25 inches:* sandy loam

*C1 - 25 to 39 inches:* gravelly sandy loam

*C2 - 39 to 60 inches:* gravelly sandy loam

**Properties and qualities**

*Slope:* 3 to 8 percent

*Depth to restrictive feature:* More than 80 inches

*Drainage class:* Moderately well drained

*Runoff class:* Very high

*Capacity of the most limiting layer to transmit water (Ksat):* Moderately low to high (0.14 to 14.17 in/hr)

*Depth to water table:* About 12 to 27 inches

*Frequency of flooding:* None

*Frequency of ponding:* None

*Maximum salinity:* Nonsaline to very slightly saline (0.0 to 2.0 mmhos/cm)

*Available water supply, 0 to 60 inches:* Moderate (about 8.3 inches)

**Interpretive groups**

*Land capability classification (irrigated):* None specified

*Land capability classification (nonirrigated):* 2w

*Hydrologic Soil Group:* B/D

*Ecological site:* F144AY008CT - Moist Till Uplands

*Hydric soil rating:* No

**Minor Components**

**Charlton**

*Percent of map unit:* 9 percent

*Landform:* Ridges, ground moraines, hills

*Landform position (two-dimensional):* Backslope, shoulder, summit

*Landform position (three-dimensional):* Crest, side slope

*Down-slope shape:* Convex, linear

*Across-slope shape:* Convex

*Hydric soil rating:* No

**Leicester**

*Percent of map unit:* 5 percent

## Custom Soil Resource Report

*Landform:* Ground moraines, hills, drainageways, depressions  
*Landform position (two-dimensional):* Toeslope, footslope  
*Landform position (three-dimensional):* Base slope  
*Down-slope shape:* Concave, linear  
*Across-slope shape:* Concave  
*Hydric soil rating:* Yes

### **Woodbridge**

*Percent of map unit:* 5 percent  
*Landform:* Hills, drumlins, ground moraines  
*Landform position (two-dimensional):* Backslope, footslope, summit  
*Landform position (three-dimensional):* Side slope, crest  
*Down-slope shape:* Concave  
*Across-slope shape:* Linear  
*Hydric soil rating:* No

### **Whitman**

*Percent of map unit:* 1 percent  
*Landform:* Drumlins, ground moraines, hills, drainageways, depressions  
*Landform position (two-dimensional):* Toeslope  
*Landform position (three-dimensional):* Base slope  
*Down-slope shape:* Concave  
*Across-slope shape:* Concave  
*Hydric soil rating:* Yes

## **61C—Canton and Charlton fine sandy loams, 8 to 15 percent slopes, very stony**

### **Map Unit Setting**

*National map unit symbol:* 2w820  
*Elevation:* 0 to 1,540 feet  
*Mean annual precipitation:* 36 to 71 inches  
*Mean annual air temperature:* 39 to 55 degrees F  
*Frost-free period:* 140 to 240 days  
*Farmland classification:* Farmland of statewide importance

### **Map Unit Composition**

*Canton, very stony, and similar soils:* 50 percent  
*Charlton, very stony, and similar soils:* 35 percent  
*Minor components:* 15 percent  
*Estimates are based on observations, descriptions, and transects of the mapunit.*

### **Description of Canton, Very Stony**

#### **Setting**

*Landform:* Moraines, hills, ridges  
*Landform position (two-dimensional):* Backslope, summit, shoulder  
*Landform position (three-dimensional):* Side slope, crest, nose slope  
*Down-slope shape:* Convex, linear  
*Across-slope shape:* Convex

## Custom Soil Resource Report

*Parent material:* Coarse-loamy over sandy melt-out till derived from gneiss, granite, and/or schist

### Typical profile

*Oi - 0 to 2 inches:* slightly decomposed plant material  
*A - 2 to 5 inches:* fine sandy loam  
*Bw1 - 5 to 16 inches:* fine sandy loam  
*Bw2 - 16 to 22 inches:* gravelly fine sandy loam  
*2C - 22 to 67 inches:* gravelly loamy sand

### Properties and qualities

*Slope:* 8 to 15 percent  
*Surface area covered with cobbles, stones or boulders:* 1.6 percent  
*Depth to restrictive feature:* 19 to 39 inches to strongly contrasting textural stratification  
*Drainage class:* Well drained  
*Runoff class:* Low  
*Capacity of the most limiting layer to transmit water (Ksat):* Moderately low to high (0.14 to 14.17 in/hr)  
*Depth to water table:* More than 80 inches  
*Frequency of flooding:* None  
*Frequency of ponding:* None  
*Maximum salinity:* Nonsaline (0.0 to 1.9 mmhos/cm)  
*Available water supply, 0 to 60 inches:* Low (about 3.4 inches)

### Interpretive groups

*Land capability classification (irrigated):* None specified  
*Land capability classification (nonirrigated):* 6s  
*Hydrologic Soil Group:* B  
*Ecological site:* F144AY034CT - Well Drained Till Uplands  
*Hydric soil rating:* No

## Description of Charlton, Very Stony

### Setting

*Landform:* Ridges, ground moraines, hills  
*Landform position (two-dimensional):* Backslope  
*Landform position (three-dimensional):* Side slope  
*Down-slope shape:* Convex, linear  
*Across-slope shape:* Convex  
*Parent material:* Coarse-loamy melt-out till derived from granite, gneiss, and/or schist

### Typical profile

*Oe - 0 to 2 inches:* moderately decomposed plant material  
*A - 2 to 4 inches:* fine sandy loam  
*Bw - 4 to 27 inches:* gravelly fine sandy loam  
*C - 27 to 65 inches:* gravelly fine sandy loam

### Properties and qualities

*Slope:* 8 to 15 percent  
*Surface area covered with cobbles, stones or boulders:* 1.6 percent  
*Depth to restrictive feature:* More than 80 inches  
*Drainage class:* Well drained  
*Runoff class:* Low  
*Capacity of the most limiting layer to transmit water (Ksat):* Moderately low to high (0.14 to 14.17 in/hr)

## Custom Soil Resource Report

*Depth to water table:* More than 80 inches  
*Frequency of flooding:* None  
*Frequency of ponding:* None  
*Maximum salinity:* Nonsaline (0.0 to 1.9 mmhos/cm)  
*Available water supply, 0 to 60 inches:* Moderate (about 8.7 inches)

### Interpretive groups

*Land capability classification (irrigated):* None specified  
*Land capability classification (nonirrigated):* 6s  
*Hydrologic Soil Group:* B  
*Ecological site:* F144AY034CT - Well Drained Till Uplands  
*Hydric soil rating:* No

### Minor Components

#### Chatfield, very stony

*Percent of map unit:* 5 percent  
*Landform:* Ridges, hills  
*Landform position (two-dimensional):* Backslope, shoulder, summit  
*Landform position (three-dimensional):* Crest, side slope, nose slope  
*Down-slope shape:* Convex  
*Across-slope shape:* Linear, convex  
*Hydric soil rating:* No

#### Sutton, very stony

*Percent of map unit:* 5 percent  
*Landform:* Ground moraines, hills  
*Landform position (two-dimensional):* Footslope  
*Landform position (three-dimensional):* Base slope  
*Down-slope shape:* Concave  
*Across-slope shape:* Linear  
*Hydric soil rating:* No

#### Leicester, very stony

*Percent of map unit:* 5 percent  
*Landform:* Hills, drainageways, depressions, ground moraines  
*Landform position (two-dimensional):* Toeslope, footslope  
*Landform position (three-dimensional):* Base slope  
*Down-slope shape:* Concave, linear  
*Across-slope shape:* Concave  
*Hydric soil rating:* Yes

## 62D—Canton and Charlton fine sandy loams, 15 to 35 percent slopes, extremely stony

### Map Unit Setting

*National map unit symbol:* 2w81r  
*Elevation:* 0 to 1,640 feet  
*Mean annual precipitation:* 36 to 71 inches

## Custom Soil Resource Report

*Mean annual air temperature:* 39 to 55 degrees F  
*Frost-free period:* 145 to 240 days  
*Farmland classification:* Not prime farmland

### Map Unit Composition

*Canton, extremely stony, and similar soils:* 55 percent  
*Charlton, extremely stony, and similar soils:* 30 percent  
*Minor components:* 15 percent  
*Estimates are based on observations, descriptions, and transects of the mapunit.*

### Description of Canton, Extremely Stony

#### Setting

*Landform:* Moraines, hills, ridges  
*Landform position (two-dimensional):* Backslope, summit, shoulder  
*Landform position (three-dimensional):* Side slope, nose slope, crest  
*Down-slope shape:* Convex, linear  
*Across-slope shape:* Convex  
*Parent material:* Coarse-loamy over sandy melt-out till derived from gneiss, granite, and/or schist

#### Typical profile

*O<sub>i</sub> - 0 to 2 inches:* slightly decomposed plant material  
*A - 2 to 5 inches:* fine sandy loam  
*Bw<sub>1</sub> - 5 to 16 inches:* fine sandy loam  
*Bw<sub>2</sub> - 16 to 22 inches:* gravelly fine sandy loam  
*2C - 22 to 67 inches:* gravelly loamy sand

#### Properties and qualities

*Slope:* 15 to 35 percent  
*Surface area covered with cobbles, stones or boulders:* 9.0 percent  
*Depth to restrictive feature:* 19 to 39 inches to strongly contrasting textural stratification  
*Drainage class:* Well drained  
*Runoff class:* Medium  
*Capacity of the most limiting layer to transmit water (K<sub>sat</sub>):* Moderately low to high (0.14 to 14.17 in/hr)  
*Depth to water table:* More than 80 inches  
*Frequency of flooding:* None  
*Frequency of ponding:* None  
*Maximum salinity:* Nonsaline (0.0 to 1.9 mmhos/cm)  
*Available water supply, 0 to 60 inches:* Low (about 3.4 inches)

#### Interpretive groups

*Land capability classification (irrigated):* None specified  
*Land capability classification (nonirrigated):* 7s  
*Hydrologic Soil Group:* B  
*Ecological site:* F144AY034CT - Well Drained Till Uplands  
*Hydric soil rating:* No

### Description of Charlton, Extremely Stony

#### Setting

*Landform:* Ridges, ground moraines, hills  
*Landform position (two-dimensional):* Backslope  
*Landform position (three-dimensional):* Side slope  
*Down-slope shape:* Convex, linear

## Custom Soil Resource Report

*Across-slope shape:* Convex

*Parent material:* Coarse-loamy melt-out till derived from granite, gneiss, and/or schist

### Typical profile

*Oe - 0 to 2 inches:* moderately decomposed plant material

*A - 2 to 4 inches:* fine sandy loam

*Bw - 4 to 27 inches:* gravelly fine sandy loam

*C - 27 to 65 inches:* gravelly fine sandy loam

### Properties and qualities

*Slope:* 15 to 35 percent

*Surface area covered with cobbles, stones or boulders:* 9.0 percent

*Depth to restrictive feature:* More than 80 inches

*Drainage class:* Well drained

*Runoff class:* Low

*Capacity of the most limiting layer to transmit water (Ksat):* Moderately low to high  
(0.14 to 14.17 in/hr)

*Depth to water table:* More than 80 inches

*Frequency of flooding:* None

*Frequency of ponding:* None

*Maximum salinity:* Nonsaline (0.0 to 1.9 mmhos/cm)

*Available water supply, 0 to 60 inches:* Moderate (about 8.7 inches)

### Interpretive groups

*Land capability classification (irrigated):* None specified

*Land capability classification (nonirrigated):* 7s

*Hydrologic Soil Group:* B

*Ecological site:* F144AY034CT - Well Drained Till Uplands

*Hydric soil rating:* No

### Minor Components

#### Sutton, extremely stony

*Percent of map unit:* 5 percent

*Landform:* Ground moraines, hills

*Landform position (two-dimensional):* Footslope

*Landform position (three-dimensional):* Base slope

*Down-slope shape:* Concave

*Across-slope shape:* Linear

*Hydric soil rating:* No

#### Chatfield, extremely stony

*Percent of map unit:* 5 percent

*Landform:* Ridges, hills

*Landform position (two-dimensional):* Summit, backslope, shoulder

*Landform position (three-dimensional):* Crest, side slope, nose slope

*Down-slope shape:* Convex

*Across-slope shape:* Linear, convex

*Hydric soil rating:* No

#### Hollis, extremely stony

*Percent of map unit:* 5 percent

*Landform:* Ridges, hills

*Landform position (two-dimensional):* Shoulder, backslope, summit

*Landform position (three-dimensional):* Crest, side slope, nose slope

*Down-slope shape:* Convex

## Custom Soil Resource Report

*Across-slope shape:* Linear, convex  
*Hydric soil rating:* No

### 73C—Charlton-Chatfield complex, 0 to 15 percent slopes, very rocky

#### Map Unit Setting

*National map unit symbol:* 2w698  
*Elevation:* 0 to 1,550 feet  
*Mean annual precipitation:* 36 to 71 inches  
*Mean annual air temperature:* 39 to 55 degrees F  
*Frost-free period:* 140 to 240 days  
*Farmland classification:* Not prime farmland

#### Map Unit Composition

*Charlton, very stony, and similar soils:* 50 percent  
*Chatfield, very stony, and similar soils:* 30 percent  
*Minor components:* 20 percent  
*Estimates are based on observations, descriptions, and transects of the mapunit.*

#### Description of Charlton, Very Stony

##### Setting

*Landform:* Ridges, hills  
*Landform position (two-dimensional):* Backslope, shoulder, summit  
*Landform position (three-dimensional):* Side slope, crest, nose slope  
*Down-slope shape:* Convex, linear  
*Across-slope shape:* Convex  
*Parent material:* Coarse-loamy melt-out till derived from granite, gneiss, and/or schist

##### Typical profile

*Oe - 0 to 2 inches:* moderately decomposed plant material  
*A - 2 to 4 inches:* fine sandy loam  
*Bw - 4 to 27 inches:* gravelly fine sandy loam  
*C - 27 to 65 inches:* gravelly fine sandy loam

##### Properties and qualities

*Slope:* 3 to 15 percent  
*Surface area covered with cobbles, stones or boulders:* 1.6 percent  
*Depth to restrictive feature:* More than 80 inches  
*Drainage class:* Well drained  
*Runoff class:* Low  
*Capacity of the most limiting layer to transmit water (Ksat):* Moderately low to high (0.14 to 14.17 in/hr)  
*Depth to water table:* More than 80 inches  
*Frequency of flooding:* None  
*Frequency of ponding:* None  
*Maximum salinity:* Nonsaline (0.0 to 1.9 mmhos/cm)  
*Available water supply, 0 to 60 inches:* Moderate (about 8.7 inches)

**Interpretive groups**

*Land capability classification (irrigated):* None specified  
*Land capability classification (nonirrigated):* 6s  
*Hydrologic Soil Group:* B  
*Ecological site:* F144AY034CT - Well Drained Till Uplands  
*Hydric soil rating:* No

**Description of Chatfield, Very Stony**

**Setting**

*Landform:* Hills, ridges  
*Landform position (two-dimensional):* Backslope, summit, shoulder  
*Landform position (three-dimensional):* Crest, side slope, nose slope  
*Down-slope shape:* Convex  
*Across-slope shape:* Linear, convex  
*Parent material:* Coarse-loamy melt-out till derived from granite, gneiss, and/or schist

**Typical profile**

*O<sub>i</sub> - 0 to 1 inches:* slightly decomposed plant material  
*A - 1 to 2 inches:* fine sandy loam  
*B<sub>w</sub> - 2 to 30 inches:* gravelly fine sandy loam  
*2R - 30 to 40 inches:* bedrock

**Properties and qualities**

*Slope:* 3 to 15 percent  
*Surface area covered with cobbles, stones or boulders:* 1.6 percent  
*Depth to restrictive feature:* 20 to 41 inches to lithic bedrock  
*Drainage class:* Well drained  
*Runoff class:* High  
*Capacity of the most limiting layer to transmit water (K<sub>sat</sub>):* Very low (0.00 to 0.00 in/hr)  
*Depth to water table:* More than 80 inches  
*Frequency of flooding:* None  
*Frequency of ponding:* None  
*Maximum salinity:* Nonsaline (0.0 to 1.9 mmhos/cm)  
*Available water supply, 0 to 60 inches:* Low (about 4.3 inches)

**Interpretive groups**

*Land capability classification (irrigated):* None specified  
*Land capability classification (nonirrigated):* 6s  
*Hydrologic Soil Group:* B  
*Ecological site:* F144AY034CT - Well Drained Till Uplands  
*Hydric soil rating:* No

**Minor Components**

**Sutton, very stony**

*Percent of map unit:* 5 percent  
*Landform:* Ground moraines, hills  
*Landform position (two-dimensional):* Footslope  
*Landform position (three-dimensional):* Base slope  
*Down-slope shape:* Concave  
*Across-slope shape:* Linear  
*Hydric soil rating:* No



**Rock outcrop**

*Percent of map unit:* 5 percent  
*Hydric soil rating:* No

**Hollis, very stony**

*Percent of map unit:* 5 percent  
*Landform:* Hills, ridges  
*Landform position (two-dimensional):* Backslope, shoulder, summit  
*Landform position (three-dimensional):* Crest, side slope, nose slope  
*Down-slope shape:* Convex  
*Across-slope shape:* Linear, convex  
*Hydric soil rating:* No

**Leicester, very stony**

*Percent of map unit:* 5 percent  
*Landform:* Drainageways, depressions  
*Down-slope shape:* Linear  
*Across-slope shape:* Concave  
*Hydric soil rating:* Yes

**75C—Hollis-Chatfield-Rock outcrop complex, 3 to 15 percent slopes**

**Map Unit Setting**

*National map unit symbol:* 9lqn  
*Elevation:* 0 to 1,200 feet  
*Mean annual precipitation:* 43 to 56 inches  
*Mean annual air temperature:* 45 to 55 degrees F  
*Frost-free period:* 140 to 185 days  
*Farmland classification:* Not prime farmland

**Map Unit Composition**

*Hollis and similar soils:* 35 percent  
*Chatfield and similar soils:* 30 percent  
*Rock outcrop:* 15 percent  
*Minor components:* 20 percent  
*Estimates are based on observations, descriptions, and transects of the mapunit.*

**Description of Hollis**

**Setting**

*Landform:* Ridges, hills  
*Down-slope shape:* Convex  
*Across-slope shape:* Convex  
*Parent material:* Loamy melt-out till derived from granite and/or schist and/or gneiss

**Typical profile**

*Oa - 0 to 1 inches:* highly decomposed plant material  
*A - 1 to 6 inches:* gravelly fine sandy loam

## Custom Soil Resource Report

*Bw1 - 6 to 9 inches:* channery fine sandy loam  
*Bw2 - 9 to 15 inches:* gravelly fine sandy loam  
*2R - 15 to 80 inches:* bedrock

### Properties and qualities

*Slope:* 3 to 15 percent  
*Surface area covered with cobbles, stones or boulders:* 9.0 percent  
*Depth to restrictive feature:* 10 to 20 inches to lithic bedrock  
*Drainage class:* Somewhat excessively drained  
*Runoff class:* Low  
*Capacity of the most limiting layer to transmit water (Ksat):* Low to high (0.01 to 5.95 in/hr)  
*Depth to water table:* More than 80 inches  
*Frequency of flooding:* None  
*Frequency of ponding:* None  
*Available water supply, 0 to 60 inches:* Very low (about 1.8 inches)

### Interpretive groups

*Land capability classification (irrigated):* None specified  
*Land capability classification (nonirrigated):* 6s  
*Hydrologic Soil Group:* D  
*Ecological site:* F144AY033MA - Shallow Dry Till Uplands  
*Hydric soil rating:* No

## Description of Chatfield

### Setting

*Landform:* Ridges, hills  
*Down-slope shape:* Convex  
*Across-slope shape:* Linear  
*Parent material:* Coarse-loamy melt-out till derived from granite and/or schist and/or gneiss

### Typical profile

*Oa - 0 to 1 inches:* highly decomposed plant material  
*A - 1 to 6 inches:* gravelly fine sandy loam  
*Bw1 - 6 to 15 inches:* gravelly fine sandy loam  
*Bw2 - 15 to 29 inches:* gravelly fine sandy loam  
*2R - 29 to 80 inches:* unweathered bedrock

### Properties and qualities

*Slope:* 3 to 15 percent  
*Surface area covered with cobbles, stones or boulders:* 1.6 percent  
*Depth to restrictive feature:* 20 to 40 inches to lithic bedrock  
*Drainage class:* Well drained  
*Runoff class:* Low  
*Capacity of the most limiting layer to transmit water (Ksat):* Low to high (0.01 to 5.95 in/hr)  
*Depth to water table:* More than 80 inches  
*Frequency of flooding:* None  
*Frequency of ponding:* None  
*Available water supply, 0 to 60 inches:* Low (about 3.3 inches)

### Interpretive groups

*Land capability classification (irrigated):* None specified  
*Land capability classification (nonirrigated):* 6s  
*Hydrologic Soil Group:* B

## Custom Soil Resource Report

*Ecological site:* F144AY034CT - Well Drained Till Uplands  
*Hydric soil rating:* No

### Description of Rock Outcrop

#### Typical profile

*R - 0 to 0 inches:* bedrock

#### Properties and qualities

*Slope:* 3 to 15 percent

*Depth to restrictive feature:* 0 inches to lithic bedrock

*Runoff class:* Very high

#### Interpretive groups

*Land capability classification (irrigated):* None specified

*Land capability classification (nonirrigated):* 8

*Hydrologic Soil Group:* D

*Hydric soil rating:* Unranked

### Minor Components

#### Charlton

*Percent of map unit:* 7 percent

*Landform:* Hills

*Down-slope shape:* Linear

*Across-slope shape:* Linear

*Hydric soil rating:* No

#### Sutton, very stony

*Percent of map unit:* 5 percent

*Landform:* Drainageways, depressions

*Down-slope shape:* Concave

*Across-slope shape:* Linear

*Hydric soil rating:* No

#### Leicester

*Percent of map unit:* 5 percent

*Landform:* Drainageways, depressions

*Down-slope shape:* Linear

*Across-slope shape:* Concave

*Hydric soil rating:* Yes

#### Brimfield

*Percent of map unit:* 1 percent

*Landform:* Ridges, hills

*Down-slope shape:* Convex

*Across-slope shape:* Convex

*Hydric soil rating:* No

#### Unnamed, red parent material

*Percent of map unit:* 1 percent

*Hydric soil rating:* No

#### Unnamed, sandy subsoil

*Percent of map unit:* 1 percent

*Hydric soil rating:* No

## 75E—Hollis-Chatfield-Rock outcrop complex, 15 to 45 percent slopes

### Map Unit Setting

*National map unit symbol:* 9lqp  
*Elevation:* 0 to 1,200 feet  
*Mean annual precipitation:* 43 to 56 inches  
*Mean annual air temperature:* 45 to 55 degrees F  
*Frost-free period:* 140 to 185 days  
*Farmland classification:* Not prime farmland

### Map Unit Composition

*Hollis and similar soils:* 35 percent  
*Chatfield and similar soils:* 30 percent  
*Rock outcrop:* 15 percent  
*Minor components:* 20 percent  
*Estimates are based on observations, descriptions, and transects of the mapunit.*

### Description of Hollis

#### Setting

*Landform:* Ridges, hills  
*Down-slope shape:* Convex  
*Across-slope shape:* Convex  
*Parent material:* Loamy melt-out till derived from granite and/or schist and/or gneiss

#### Typical profile

*Oa - 0 to 1 inches:* highly decomposed plant material  
*A - 1 to 6 inches:* gravelly fine sandy loam  
*Bw1 - 6 to 9 inches:* channery fine sandy loam  
*Bw2 - 9 to 15 inches:* gravelly fine sandy loam  
*2R - 15 to 80 inches:* bedrock

#### Properties and qualities

*Slope:* 15 to 45 percent  
*Surface area covered with cobbles, stones or boulders:* 9.0 percent  
*Depth to restrictive feature:* 10 to 20 inches to lithic bedrock  
*Drainage class:* Somewhat excessively drained  
*Runoff class:* High  
*Capacity of the most limiting layer to transmit water (Ksat):* Low to high (0.01 to 5.95 in/hr)  
*Depth to water table:* More than 80 inches  
*Frequency of flooding:* None  
*Frequency of ponding:* None  
*Available water supply, 0 to 60 inches:* Very low (about 1.8 inches)

**Interpretive groups**

*Land capability classification (irrigated):* None specified  
*Land capability classification (nonirrigated):* 7s  
*Hydrologic Soil Group:* D  
*Ecological site:* F144AY033MA - Shallow Dry Till Uplands  
*Hydric soil rating:* No

**Description of Chatfield**

**Setting**

*Landform:* Ridges, hills  
*Down-slope shape:* Convex  
*Across-slope shape:* Linear  
*Parent material:* Coarse-loamy melt-out till derived from granite and/or schist and/or gneiss

**Typical profile**

*Oa - 0 to 1 inches:* highly decomposed plant material  
*A - 1 to 6 inches:* gravelly fine sandy loam  
*Bw1 - 6 to 15 inches:* gravelly fine sandy loam  
*Bw2 - 15 to 29 inches:* gravelly fine sandy loam  
*2R - 29 to 80 inches:* unweathered bedrock

**Properties and qualities**

*Slope:* 15 to 45 percent  
*Surface area covered with cobbles, stones or boulders:* 1.6 percent  
*Depth to restrictive feature:* 20 to 40 inches to lithic bedrock  
*Drainage class:* Well drained  
*Runoff class:* High  
*Capacity of the most limiting layer to transmit water (Ksat):* Low to high (0.01 to 5.95 in/hr)  
*Depth to water table:* More than 80 inches  
*Frequency of flooding:* None  
*Frequency of ponding:* None  
*Available water supply, 0 to 60 inches:* Low (about 3.3 inches)

**Interpretive groups**

*Land capability classification (irrigated):* None specified  
*Land capability classification (nonirrigated):* 7s  
*Hydrologic Soil Group:* B  
*Ecological site:* F144AY034CT - Well Drained Till Uplands  
*Hydric soil rating:* No

**Description of Rock Outcrop**

**Typical profile**

*R - 0 to 0 inches:* bedrock

**Properties and qualities**

*Slope:* 15 to 45 percent  
*Depth to restrictive feature:* 0 inches to lithic bedrock  
*Runoff class:* Very high

**Interpretive groups**

*Land capability classification (irrigated):* None specified  
*Land capability classification (nonirrigated):* 8  
*Hydrologic Soil Group:* D

*Hydric soil rating:* Unranked

**Minor Components**

**Charlton**

*Percent of map unit:* 7 percent

*Landform:* Hills

*Down-slope shape:* Linear

*Across-slope shape:* Linear

*Hydric soil rating:* No

**Leicester**

*Percent of map unit:* 5 percent

*Landform:* Drainageways, depressions

*Down-slope shape:* Linear

*Across-slope shape:* Concave

*Hydric soil rating:* Yes

**Sutton, very stony**

*Percent of map unit:* 5 percent

*Landform:* Drainageways, depressions

*Down-slope shape:* Concave

*Across-slope shape:* Linear

*Hydric soil rating:* No

**Unnamed, red parent material**

*Percent of map unit:* 1 percent

*Hydric soil rating:* No

**Unnamed, sandy subsoil**

*Percent of map unit:* 1 percent

*Hydric soil rating:* No

**Brimfield**

*Percent of map unit:* 1 percent

*Landform:* Ridges, hills

*Down-slope shape:* Convex

*Across-slope shape:* Convex

*Hydric soil rating:* No

**76E—Rock outcrop-Hollis complex, 3 to 45 percent slopes**

**Map Unit Setting**

*National map unit symbol:* 9lqq

*Elevation:* 0 to 1,200 feet

*Mean annual precipitation:* 43 to 56 inches

*Mean annual air temperature:* 45 to 55 degrees F

*Frost-free period:* 140 to 185 days

*Farmland classification:* Not prime farmland

**Map Unit Composition**

*Rock outcrop: 55 percent*

*Hollis and similar soils: 25 percent*

*Minor components: 20 percent*

*Estimates are based on observations, descriptions, and transects of the mapunit.*

**Description of Rock Outcrop**

**Setting**

*Landform: Ridges, hills*

**Typical profile**

*R - 0 to 0 inches: bedrock*

**Properties and qualities**

*Slope: 3 to 45 percent*

*Depth to restrictive feature: 0 inches to lithic bedrock*

*Runoff class: Very high*

**Interpretive groups**

*Land capability classification (irrigated): None specified*

*Land capability classification (nonirrigated): 8*

*Hydrologic Soil Group: D*

*Hydric soil rating: Unranked*

**Description of Hollis**

**Setting**

*Landform: Ridges, hills*

*Down-slope shape: Convex*

*Across-slope shape: Convex*

*Parent material: Loamy melt-out till derived from granite and/or schist and/or gneiss*

**Typical profile**

*Oa - 0 to 1 inches: highly decomposed plant material*

*A - 1 to 6 inches: gravelly fine sandy loam*

*Bw1 - 6 to 9 inches: channery fine sandy loam*

*Bw2 - 9 to 15 inches: gravelly fine sandy loam*

*2R - 15 to 80 inches: bedrock*

**Properties and qualities**

*Slope: 3 to 45 percent*

*Surface area covered with cobbles, stones or boulders: 9.0 percent*

*Depth to restrictive feature: 10 to 20 inches to lithic bedrock*

*Drainage class: Somewhat excessively drained*

*Runoff class: Medium*

*Capacity of the most limiting layer to transmit water (Ksat): Low to high (0.01 to 5.95 in/hr)*

*Depth to water table: More than 80 inches*

*Frequency of flooding: None*

*Frequency of ponding: None*

*Available water supply, 0 to 60 inches: Very low (about 1.8 inches)*

**Interpretive groups**

*Land capability classification (irrigated): None specified*

*Land capability classification (nonirrigated): 7s*

## Custom Soil Resource Report

*Hydrologic Soil Group:* D  
*Ecological site:* F144AY033MA - Shallow Dry Till Uplands  
*Hydric soil rating:* No

### Minor Components

#### **Chatfield**

*Percent of map unit:* 10 percent  
*Landform:* Ridges, hills  
*Down-slope shape:* Convex  
*Across-slope shape:* Linear  
*Hydric soil rating:* No

#### **Charlton**

*Percent of map unit:* 6 percent  
*Landform:* Hills  
*Down-slope shape:* Linear  
*Across-slope shape:* Linear  
*Hydric soil rating:* No

#### **Leicester**

*Percent of map unit:* 2 percent  
*Landform:* Drainageways, depressions  
*Down-slope shape:* Linear  
*Across-slope shape:* Concave  
*Hydric soil rating:* Yes

#### **Brimfield**

*Percent of map unit:* 1 percent  
*Landform:* Ridges, hills  
*Down-slope shape:* Convex  
*Across-slope shape:* Convex  
*Hydric soil rating:* No

#### **Sutton, very stony**

*Percent of map unit:* 1 percent  
*Landform:* Drainageways, depressions  
*Down-slope shape:* Concave  
*Across-slope shape:* Linear  
*Hydric soil rating:* No

## 306—Udorthents-Urban land complex

### Map Unit Setting

*National map unit symbol:* 9lmg  
*Elevation:* 0 to 2,000 feet  
*Mean annual precipitation:* 43 to 56 inches  
*Mean annual air temperature:* 45 to 55 degrees F  
*Frost-free period:* 120 to 185 days  
*Farmland classification:* Not prime farmland



**Map Unit Composition**

*Udorthents and similar soils: 50 percent*

*Urban land: 39 percent*

*Minor components: 11 percent*

*Estimates are based on observations, descriptions, and transects of the mapunit.*

**Description of Udorthents**

**Setting**

*Parent material: Human-transported material*

**Typical profile**

*^A - 0 to 5 inches: loam*

*^C1 - 5 to 21 inches: gravelly loam*

*^C2 - 21 to 79 inches: very gravelly sandy loam*

**Properties and qualities**

*Slope: 0 to 25 percent*

*Depth to restrictive feature: More than 80 inches*

*Drainage class: Well drained*

*Runoff class: Medium*

*Capacity of the most limiting layer to transmit water (Ksat): Very low to high (0.00 to 1.98 in/hr)*

*Depth to water table: More than 80 inches*

*Frequency of flooding: None*

*Frequency of ponding: None*

*Available water supply, 0 to 60 inches: Moderate (about 6.8 inches)*

**Interpretive groups**

*Land capability classification (irrigated): None specified*

*Land capability classification (nonirrigated): 4e*

*Hydrologic Soil Group: B*

*Hydric soil rating: No*

**Description of Urban Land**

**Typical profile**

*M - 0 to 6 inches: cemented material*

**Interpretive groups**

*Land capability classification (irrigated): None specified*

*Land capability classification (nonirrigated): 8*

*Hydrologic Soil Group: D*

*Hydric soil rating: Unranked*

**Minor Components**

**Udorthents, wet substratum**

*Percent of map unit: 9 percent*

*Hydric soil rating: No*

**Rock outcrop**

*Percent of map unit: 2 percent*

*Landform: Hills*

*Down-slope shape: Convex*

*Across-slope shape: Convex*

*Hydric soil rating: No*

### 307—Urban land

#### Map Unit Setting

*National map unit symbol:* 9lmh  
*Elevation:* 0 to 2,000 feet  
*Mean annual precipitation:* 43 to 56 inches  
*Mean annual air temperature:* 45 to 55 degrees F  
*Frost-free period:* 120 to 185 days  
*Farmland classification:* Not prime farmland

#### Map Unit Composition

*Urban land:* 80 percent  
*Minor components:* 20 percent  
*Estimates are based on observations, descriptions, and transects of the mapunit.*

#### Description of Urban Land

##### Typical profile

*H - 0 to 6 inches:* material

##### Interpretive groups

*Land capability classification (irrigated):* None specified  
*Land capability classification (nonirrigated):* 8  
*Hydrologic Soil Group:* D  
*Hydric soil rating:* Unranked

#### Minor Components

##### Unnamed, undisturbed soils

*Percent of map unit:* 10 percent  
*Hydric soil rating:* No

##### Udorthents, wet substratum

*Percent of map unit:* 10 percent  
*Down-slope shape:* Convex  
*Across-slope shape:* Linear  
*Hydric soil rating:* No

### 702B—Tisbury silt loam, 3 to 8 percent slopes

#### Map Unit Setting

*National map unit symbol:* 2y07h  
*Elevation:* 0 to 1,260 feet

## Custom Soil Resource Report

*Mean annual precipitation:* 43 to 54 inches  
*Mean annual air temperature:* 45 to 55 degrees F  
*Frost-free period:* 140 to 185 days  
*Farmland classification:* All areas are prime farmland

### Map Unit Composition

*Tisbury and similar soils:* 85 percent  
*Minor components:* 15 percent  
*Estimates are based on observations, descriptions, and transects of the mapunit.*

### Description of Tisbury

#### Setting

*Landform:* Outwash terraces, outwash plains, valley trains, deltas  
*Landform position (three-dimensional):* Tread  
*Down-slope shape:* Concave  
*Across-slope shape:* Concave  
*Parent material:* Coarse-silty eolian deposits over sandy and gravelly glaciofluvial deposits derived from granite, schist, and/or gneiss

#### Typical profile

*Ap - 0 to 8 inches:* silt loam  
*Bw1 - 8 to 18 inches:* silt loam  
*Bw2 - 18 to 26 inches:* silt loam  
*2C - 26 to 65 inches:* extremely gravelly sand

#### Properties and qualities

*Slope:* 3 to 8 percent  
*Depth to restrictive feature:* 24 to 36 inches to strongly contrasting textural stratification  
*Drainage class:* Moderately well drained  
*Runoff class:* Low  
*Capacity of the most limiting layer to transmit water (Ksat):* Moderately low to high (0.14 to 14.17 in/hr)  
*Depth to water table:* About 16 to 30 inches  
*Frequency of flooding:* None  
*Frequency of ponding:* None  
*Maximum salinity:* Nonsaline (0.0 to 1.9 mmhos/cm)  
*Available water supply, 0 to 60 inches:* Low (about 4.3 inches)

#### Interpretive groups

*Land capability classification (irrigated):* None specified  
*Land capability classification (nonirrigated):* 2e  
*Hydrologic Soil Group:* B/D  
*Ecological site:* F144AY026CT - Moist Silty Outwash  
*Hydric soil rating:* No

### Minor Components

#### Agawam

*Percent of map unit:* 5 percent  
*Landform:* Kame terraces, outwash plains, outwash terraces, moraines, kames  
*Landform position (two-dimensional):* Footslope, backslope, shoulder, summit, toeslope  
*Landform position (three-dimensional):* Head slope, nose slope, side slope, crest, tread  
*Down-slope shape:* Convex

## Custom Soil Resource Report

*Across-slope shape:* Convex  
*Hydric soil rating:* No

### **Merrimac**

*Percent of map unit:* 5 percent  
*Landform:* Outwash terraces, moraines, eskers, kames, outwash plains  
*Landform position (two-dimensional):* Summit, toeslope, backslope, footslope, shoulder  
*Landform position (three-dimensional):* Crest, head slope, nose slope, side slope, tread  
*Down-slope shape:* Convex  
*Across-slope shape:* Convex  
*Hydric soil rating:* No

### **Ninigret**

*Percent of map unit:* 3 percent  
*Landform:* Kame terraces, outwash plains, kames, outwash terraces, moraines  
*Landform position (two-dimensional):* Footslope, backslope, toeslope  
*Landform position (three-dimensional):* Base slope, tread  
*Down-slope shape:* Convex, linear  
*Across-slope shape:* Convex, concave  
*Hydric soil rating:* No

### **Raypol**

*Percent of map unit:* 2 percent  
*Landform:* Drainageways, depressions  
*Down-slope shape:* Concave  
*Across-slope shape:* Concave  
*Hydric soil rating:* Yes

## **W—Water**

### **Map Unit Composition**

*Water:* 100 percent  
*Estimates are based on observations, descriptions, and transects of the mapunit.*

# Soil Information for All Uses

---

## Soil Properties and Qualities

The Soil Properties and Qualities section includes various soil properties and qualities displayed as thematic maps with a summary table for the soil map units in the selected area of interest. A single value or rating for each map unit is generated by aggregating the interpretive ratings of individual map unit components. This aggregation process is defined for each property or quality.

## Soil Qualities and Features

Soil qualities are behavior and performance attributes that are not directly measured, but are inferred from observations of dynamic conditions and from soil properties. Example soil qualities include natural drainage, and frost action. Soil features are attributes that are not directly part of the soil. Example soil features include slope and depth to restrictive layer. These features can greatly impact the use and management of the soil.

## Hydrologic Soil Group

Hydrologic soil groups are based on estimates of runoff potential. Soils are assigned to one of four groups according to the rate of water infiltration when the soils are not protected by vegetation, are thoroughly wet, and receive precipitation from long-duration storms.

The soils in the United States are assigned to four groups (A, B, C, and D) and three dual classes (A/D, B/D, and C/D). The groups are defined as follows:

Group A. Soils having a high infiltration rate (low runoff potential) when thoroughly wet. These consist mainly of deep, well drained to excessively drained sands or gravelly sands. These soils have a high rate of water transmission.

Group B. Soils having a moderate infiltration rate when thoroughly wet. These consist chiefly of moderately deep or deep, moderately well drained or well drained soils that have moderately fine texture to moderately coarse texture. These soils have a moderate rate of water transmission.


## Custom Soil Resource Report

Group C. Soils having a slow infiltration rate when thoroughly wet. These consist chiefly of soils having a layer that impedes the downward movement of water or soils of moderately fine texture or fine texture. These soils have a slow rate of water transmission.


Group D. Soils having a very slow infiltration rate (high runoff potential) when thoroughly wet. These consist chiefly of clays that have a high shrink-swell potential, soils that have a high water table, soils that have a claypan or clay layer at or near the surface, and soils that are shallow over nearly impervious material. These soils have a very slow rate of water transmission.

If a soil is assigned to a dual hydrologic group (A/D, B/D, or C/D), the first letter is for drained areas and the second is for undrained areas. Only the soils that in their natural condition are in group D are assigned to dual classes.

# Custom Soil Resource Report Map—Hydrologic Soil Group




Map Scale: 1:8,020 if printed on A portrait (8.5" x 11") sheet.



Map projection: Web Mercator Corner coordinates: WGS84 Edge tics: UTM Zone 18N WGS84

### MAP LEGEND

**Area of Interest (AOI)**









 Area of Interest (AOI)

**Soils**

**Soil Rating Polygons**





-  A
-  A/D
-  B
-  B/D
-  C
-  C/D
-  D
-  Not rated or not available

**Soil Rating Lines**


-  A
-  A/D
-  B
-  B/D
-  C
-  C/D
-  D
-  Not rated or not available

**Soil Rating Points**






-  A
-  A/D
-  B
-  B/D

-  C
-  C/D
-  D
-  Not rated or not available


**Water Features**

 Streams and Canals

**Transportation**

-  Rails
-  Interstate Highways
-  US Routes
-  Major Roads
-  Local Roads

**Background**

 Aerial Photography

### MAP INFORMATION

The soil surveys that comprise your AOI were mapped at 1:12,000.

Please rely on the bar scale on each map sheet for map measurements.

Source of Map: Natural Resources Conservation Service  
 Web Soil Survey URL:  
 Coordinate System: Web Mercator (EPSG:3857)

Maps from the Web Soil Survey are based on the Web Mercator projection, which preserves direction and shape but distorts distance and area. A projection that preserves area, such as the Albers equal-area conic projection, should be used if more accurate calculations of distance or area are required.

This product is generated from the USDA-NRCS certified data as of the version date(s) listed below.

Soil Survey Area: State of Connecticut, Eastern Part  
 Survey Area Data: Version 1, Sep 15, 2023

Soil map units are labeled (as space allows) for map scales 1:50,000 or larger.

Date(s) aerial images were photographed: Jun 14, 2022—Oct 6, 2022

The orthophoto or other base map on which the soil lines were compiled and digitized probably differs from the background imagery displayed on these maps. As a result, some minor shifting of map unit boundaries may be evident.



**Table—Hydrologic Soil Group**

Map unit symbol	Map unit name	Rating	Acres in AOI	Percent of AOI
3	Ridgebury, Leicester, and Whitman soils, 0 to 8 percent slopes, extremely stony	D	3.9	1.9%
18	Catden and Freetown soils, 0 to 2 percent slopes	B/D	0.1	0.0%
34B	Merrimac fine sandy loam, 3 to 8 percent slopes	A	1.8	0.9%
38E	Hinckley loamy sand, 15 to 45 percent slopes	A	40.5	20.2%
50B	Sutton fine sandy loam, 3 to 8 percent slopes	B/D	3.2	1.6%
61C	Canton and Charlton fine sandy loams, 8 to 15 percent slopes, very stony	B	4.1	2.1%
62D	Canton and Charlton fine sandy loams, 15 to 35 percent slopes, extremely stony	B	3.6	1.8%
73C	Charlton-Chatfield complex, 0 to 15 percent slopes, very rocky	B	2.5	1.3%
75C	Hollis-Chatfield-Rock outcrop complex, 3 to 15 percent slopes	D	19.3	9.6%
75E	Hollis-Chatfield-Rock outcrop complex, 15 to 45 percent slopes	D	51.3	25.6%
76E	Rock outcrop-Hollis complex, 3 to 45 percent slopes	D	16.2	8.1%
306	Udorthents-Urban land complex	B	22.8	11.4%
307	Urban land	D	8.8	4.4%
702B	Tisbury silt loam, 3 to 8 percent slopes	B/D	0.1	0.1%
W	Water		21.9	10.9%
<b>Totals for Area of Interest</b>			<b>200.3</b>	<b>100.0%</b>

**Rating Options—Hydrologic Soil Group**

*Aggregation Method: Dominant Condition*




*Component Percent Cutoff: None Specified*

## Custom Soil Resource Report

*Tie-break Rule:* Higher

## **APPENDIX D**

### **HydroCAD Reports**



**Routing Diagram for Existing Conditions**  
 Prepared by Loureiro Engineering Assoc, Inc, Printed 9/25/2024  
 HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

## **Existing Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

Printed 9/25/2024

Page 2

---

## **Project Notes**

Defined 5 rainfall events from CT-Gales Ferry-1761 Route 12\_DEPTHS IDF

Defined 5 rainfall events from CT-Gales Ferry-1761 Route 12\_DEPTHS IDF

## Existing Conditions

Prepared by Loureiro Engineering Assoc, Inc  
HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

Printed 9/25/2024

Page 3

### Rainfall Events Listing

Event#	Event Name	Storm Type	Curve	Mode	Duration (hours)	B/B	Depth (inches)	AMC
1	2-yr	NOAA 24-hr	D	Default	24.00	1	3.46	2
2	10-yr	NOAA 24-hr	D	Default	24.00	1	5.12	2
3	25-yr	NOAA 24-hr	D	Default	24.00	1	6.15	2
4	50-yr	NOAA 24-hr	D	Default	24.00	1	6.92	2
5	100-yr	NOAA 24-hr	D	Default	24.00	1	7.74	2

## Existing Conditions

Prepared by Loureiro Engineering Assoc, Inc  
HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

Printed 9/25/2024

Page 4

### Area Listing (all nodes)

Area (sq-ft)	CN	Description (subcatchment-numbers)
76,636	30	Brush, Good, HSG A (1, 2, 4)
4,103	48	Brush, Good, HSG B (1, 2)
120,327	73	Brush, Good, HSG D (2, 3, 4)
14,375	72	Dirt roads, HSG A (1, 2)
3,886	89	Dirt roads, HSG D (2, 3)
11,764	76	Gravel roads, HSG A (2, 4)
81,857	91	Gravel roads, HSG D (2, 3, 4)
2	0	Woods, Good (4)
1,411,426	30	Woods, Good, HSG A (1, 2, 4)
16,034	55	Woods, Good, HSG B (1)
1,544,730	77	Woods, Good, HSG D (1, 2, 3, 4)
<b>3,285,140</b>	<b>56</b>	<b>TOTAL AREA</b>

## Existing Conditions

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

Printed 9/25/2024

Page 5

### Soil Listing (all nodes)

Area (sq-ft)	Soil Group	Subcatchment Numbers
1,514,200	HSG A	1, 2, 4
20,137	HSG B	1, 2
0	HSG C	
1,750,801	HSG D	1, 2, 3, 4
2	Other	4
<b>3,285,140</b>		<b>TOTAL AREA</b>



**Existing Conditions**

Prepared by Loureiro Engineering Assoc, Inc

Printed 9/25/2024

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

Page 6

**Ground Covers (all nodes)**

HSG-A (sq-ft)	HSG-B (sq-ft)	HSG-C (sq-ft)	HSG-D (sq-ft)	Other (sq-ft)	Total (sq-ft)	Ground Cover	Subcatchment Numbers
76,636	4,103	0	120,327	0	201,065	Brush, Good	1 , 2 , 3 , 4
14,375	0	0	3,886	0	18,261	Dirt roads	1 , 2 , 3
11,764	0	0	81,857	0	93,621	Gravel roads	2 , 3 , 4
1,411,426	16,034	0	1,544,730	2	2,972,192	Woods, Good	1 , 2 , 3 , 4
<b>1,514,200</b>	<b>20,137</b>	<b>0</b>	<b>1,750,801</b>	<b>2</b>	<b>3,285,140</b>	<b>TOTAL AREA</b>	

## Existing Conditions

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 2-yr Rainfall=3.46"

Printed 9/25/2024

Page 7

Time span=0.00-96.00 hrs, dt=0.01 hrs, 9601 points  
Runoff by SCS TR-20 method, UH=SCS, Weighted-CN  
Reach routing by Stor-Ind+Trans method - Pond routing by Stor-Ind method

### Subcatchment1: Subcat 1

Runoff Area=680,739 sf 0.00% Impervious Runoff Depth=0.12"  
Flow Length=1,302' Tc=47.6 min CN=47 Runoff=0.23 cfs 6,596 cf

### Subcatchment2: Subcat 2

Runoff Area=1,328,730 sf 0.00% Impervious Runoff Depth=0.12"  
Flow Length=1,011' Tc=33.6 min CN=47 Runoff=0.47 cfs 12,875 cf

### Subcatchment3: Subcat 3

Runoff Area=899,497 sf 0.00% Impervious Runoff Depth=1.47"  
Flow Length=691' Tc=42.4 min CN=78 Runoff=15.37 cfs 109,967 cf

### Subcatchment4: Subcat 4

Runoff Area=376,174 sf 0.00% Impervious Runoff Depth=0.19"  
Flow Length=846' Tc=13.2 min CN=50 Runoff=0.31 cfs 5,831 cf

### Link 2L: Northeast Wetland

Inflow=0.23 cfs 6,596 cf  
Primary=0.23 cfs 6,596 cf

### Link 3L: South Off-Site (POC 3)

Inflow=15.37 cfs 109,967 cf  
Primary=15.37 cfs 109,967 cf

### Link 4L: West Wetlands (POC 1)

Inflow=0.69 cfs 19,471 cf  
Primary=0.69 cfs 19,471 cf

### Link 5L: West Off-Site (POC 2)

Inflow=0.31 cfs 5,831 cf  
Primary=0.31 cfs 5,831 cf

**Total Runoff Area = 3,285,140 sf Runoff Volume = 135,268 cf Average Runoff Depth = 0.49"**  
**100.00% Pervious = 3,285,140 sf 0.00% Impervious = 0 sf**

## Existing Conditions

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 10-yr Rainfall=5.12"

Printed 9/25/2024

Page 8

Time span=0.00-96.00 hrs, dt=0.01 hrs, 9601 points  
Runoff by SCS TR-20 method, UH=SCS, Weighted-CN  
Reach routing by Stor-Ind+Trans method - Pond routing by Stor-Ind method

### Subcatchment1: Subcat 1

Runoff Area=680,739 sf 0.00% Impervious Runoff Depth=0.58"  
Flow Length=1,302' Tc=47.6 min CN=47 Runoff=2.55 cfs 32,920 cf

### Subcatchment2: Subcat 2

Runoff Area=1,328,730 sf 0.00% Impervious Runoff Depth=0.58"  
Flow Length=1,011' Tc=33.6 min CN=47 Runoff=5.74 cfs 64,257 cf

### Subcatchment3: Subcat 3

Runoff Area=899,497 sf 0.00% Impervious Runoff Depth=2.81"  
Flow Length=691' Tc=42.4 min CN=78 Runoff=30.07 cfs 210,922 cf

### Subcatchment4: Subcat 4

Runoff Area=376,174 sf 0.00% Impervious Runoff Depth=0.74"  
Flow Length=846' Tc=13.2 min CN=50 Runoff=3.92 cfs 23,259 cf

### Link 2L: Northeast Wetland

Inflow=2.55 cfs 32,920 cf  
Primary=2.55 cfs 32,920 cf

### Link 3L: South Off-Site (POC 3)

Inflow=30.07 cfs 210,922 cf  
Primary=30.07 cfs 210,922 cf

### Link 4L: West Wetlands (POC 1)

Inflow=7.91 cfs 97,177 cf  
Primary=7.91 cfs 97,177 cf

### Link 5L: West Off-Site (POC 2)

Inflow=3.92 cfs 23,259 cf  
Primary=3.92 cfs 23,259 cf

**Total Runoff Area = 3,285,140 sf Runoff Volume = 331,357 cf Average Runoff Depth = 1.21"**  
**100.00% Pervious = 3,285,140 sf 0.00% Impervious = 0 sf**

## Existing Conditions

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 25-yr Rainfall=6.15"

Printed 9/25/2024

Page 9

Time span=0.00-96.00 hrs, dt=0.01 hrs, 9601 points  
Runoff by SCS TR-20 method, UH=SCS, Weighted-CN  
Reach routing by Stor-Ind+Trans method - Pond routing by Stor-Ind method

### Subcatchment1: Subcat 1

Runoff Area=680,739 sf 0.00% Impervious Runoff Depth=1.00"  
Flow Length=1,302' Tc=47.6 min CN=47 Runoff=5.50 cfs 56,718 cf

### Subcatchment2: Subcat 2

Runoff Area=1,328,730 sf 0.00% Impervious Runoff Depth=1.00"  
Flow Length=1,011' Tc=33.6 min CN=47 Runoff=12.83 cfs 110,708 cf

### Subcatchment3: Subcat 3

Runoff Area=899,497 sf 0.00% Impervious Runoff Depth=3.71"  
Flow Length=691' Tc=42.4 min CN=78 Runoff=39.67 cfs 278,224 cf

### Subcatchment4: Subcat 4

Runoff Area=376,174 sf 0.00% Impervious Runoff Depth=1.22"  
Flow Length=846' Tc=13.2 min CN=50 Runoff=7.82 cfs 38,155 cf

### Link 2L: Northeast Wetland

Inflow=5.50 cfs 56,718 cf  
Primary=5.50 cfs 56,718 cf

### Link 3L: South Off-Site (POC 3)

Inflow=39.67 cfs 278,224 cf  
Primary=39.67 cfs 278,224 cf

### Link 4L: West Wetlands (POC 1)

Inflow=17.51 cfs 167,426 cf  
Primary=17.51 cfs 167,426 cf

### Link 5L: West Off-Site (POC 2)

Inflow=7.82 cfs 38,155 cf  
Primary=7.82 cfs 38,155 cf

**Total Runoff Area = 3,285,140 sf Runoff Volume = 483,804 cf Average Runoff Depth = 1.77"**  
**100.00% Pervious = 3,285,140 sf 0.00% Impervious = 0 sf**

## Existing Conditions

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 50-yr Rainfall=6.92"

Printed 9/25/2024

Page 10

Time span=0.00-96.00 hrs, dt=0.01 hrs, 9601 points  
Runoff by SCS TR-20 method, UH=SCS, Weighted-CN  
Reach routing by Stor-Ind+Trans method - Pond routing by Stor-Ind method

### Subcatchment1: Subcat 1

Runoff Area=680,739 sf 0.00% Impervious Runoff Depth=1.36"  
Flow Length=1,302' Tc=47.6 min CN=47 Runoff=8.28 cfs 77,432 cf

### Subcatchment2: Subcat 2

Runoff Area=1,328,730 sf 0.00% Impervious Runoff Depth=1.36"  
Flow Length=1,011' Tc=33.6 min CN=47 Runoff=19.44 cfs 151,139 cf

### Subcatchment3: Subcat 3

Runoff Area=899,497 sf 0.00% Impervious Runoff Depth=4.40"  
Flow Length=691' Tc=42.4 min CN=78 Runoff=46.96 cfs 329,989 cf

### Subcatchment4: Subcat 4

Runoff Area=376,174 sf 0.00% Impervious Runoff Depth=1.62"  
Flow Length=846' Tc=13.2 min CN=50 Runoff=11.18 cfs 50,859 cf

### Link 2L: Northeast Wetland

Inflow=8.28 cfs 77,432 cf  
Primary=8.28 cfs 77,432 cf

### Link 3L: South Off-Site (POC 3)

Inflow=46.96 cfs 329,989 cf  
Primary=46.96 cfs 329,989 cf

### Link 4L: West Wetlands (POC 1)

Inflow=26.55 cfs 228,571 cf  
Primary=26.55 cfs 228,571 cf

### Link 5L: West Off-Site (POC 2)

Inflow=11.18 cfs 50,859 cf  
Primary=11.18 cfs 50,859 cf

**Total Runoff Area = 3,285,140 sf Runoff Volume = 609,419 cf Average Runoff Depth = 2.23"**  
**100.00% Pervious = 3,285,140 sf 0.00% Impervious = 0 sf**

## Existing Conditions

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 100-yr Rainfall=7.74"

Printed 9/25/2024

Page 11

Time span=0.00-96.00 hrs, dt=0.01 hrs, 9601 points  
Runoff by SCS TR-20 method, UH=SCS, Weighted-CN  
Reach routing by Stor-Ind+Trans method - Pond routing by Stor-Ind method

### Subcatchment1: Subcat 1

Runoff Area=680,739 sf 0.00% Impervious Runoff Depth=1.79"  
Flow Length=1,302' Tc=47.6 min CN=47 Runoff=11.62 cfs 101,811 cf

### Subcatchment2: Subcat 2

Runoff Area=1,328,730 sf 0.00% Impervious Runoff Depth=1.79"  
Flow Length=1,011' Tc=33.6 min CN=47 Runoff=27.45 cfs 198,724 cf

### Subcatchment3: Subcat 3

Runoff Area=899,497 sf 0.00% Impervious Runoff Depth=5.15"  
Flow Length=691' Tc=42.4 min CN=78 Runoff=54.78 cfs 386,124 cf

### Subcatchment4: Subcat 4

Runoff Area=376,174 sf 0.00% Impervious Runoff Depth=2.09"  
Flow Length=846' Tc=13.2 min CN=50 Runoff=15.08 cfs 65,619 cf

### Link 2L: Northeast Wetland

Inflow=11.62 cfs 101,811 cf  
Primary=11.62 cfs 101,811 cf

### Link 3L: South Off-Site (POC 3)

Inflow=54.78 cfs 386,124 cf  
Primary=54.78 cfs 386,124 cf




### Link 4L: West Wetlands (POC 1)

Inflow=37.44 cfs 300,535 cf  
Primary=37.44 cfs 300,535 cf

### Link 5L: West Off-Site (POC 2)

Inflow=15.08 cfs 65,619 cf  
Primary=15.08 cfs 65,619 cf

**Total Runoff Area = 3,285,140 sf Runoff Volume = 752,278 cf Average Runoff Depth = 2.75"**  
**100.00% Pervious = 3,285,140 sf 0.00% Impervious = 0 sf**



**Routing Diagram for New Conditions**  
 Prepared by Loureiro Engineering Assoc, Inc, Printed 9/25/2024  
 HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

## **New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

Printed 9/25/2024

Page 2

---

## **Project Notes**

Defined 5 rainfall events from CT-Gales Ferry-1761 Route 12\_DEPTHs IDF

Defined 5 rainfall events from CT-Gales Ferry-1761 Route 12\_DEPTHs IDF



## New Conditions

Prepared by Loureiro Engineering Assoc, Inc  
HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

Printed 9/25/2024

Page 3

### Rainfall Events Listing

Event#	Event Name	Storm Type	Curve	Mode	Duration (hours)	B/B	Depth (inches)	AMC
1	2-yr	NOAA 24-hr	D	Default	24.00	1	3.46	2
2	10-yr	NOAA 24-hr	D	Default	24.00	1	5.12	2
3	25-yr	NOAA 24-hr	D	Default	24.00	1	6.15	2
4	50-yr	NOAA 24-hr	D	Default	24.00	1	6.92	2
5	100-yr	NOAA 24-hr	D	Default	24.00	1	7.74	2

## New Conditions

### Area Listing (all nodes)

Area (sq-ft)	CN	Description (subcatchment-numbers)
883,042	39	>75% Grass cover, Good, HSG A (1, 2, 3, 4, 6, 8, 9, 10, 11)
400,892	80	>75% Grass cover, Good, HSG D (2, 3, 4, 6)
76,598	30	Brush, Good, HSG A (1, 7, 11)
4,094	48	Brush, Good, HSG B (1, 11)
118,932	73	Brush, Good, HSG D (5, 6, 7)
1,022	72	Dirt roads, HSG A (1)
2,922	89	Dirt roads, HSG D (5)
9,853	76	Gravel roads, HSG A (7)
72,185	91	Gravel roads, HSG D (5, 7)
39,655	96	Gravel surface, HSG A (2, 3, 4, 8, 9, 10, 11)
24,103	98	Unconnected pavement, HSG A (2, 9)
145,671	98	Unconnected pavement, HSG D (3, 4, 5, 6)
453,950	30	Woods, Good, HSG A (1, 2, 7, 10, 11)
16,017	55	Woods, Good, HSG B (1)
704,815	77	Woods, Good, HSG D (1, 2, 3, 4, 5, 6, 7)
329,560	86	Woods/grass comb., Poor, HSG D (2, 3, 4, 6, 9)
<b>3,283,311</b>	<b>62</b>	<b>TOTAL AREA</b>

## New Conditions

Prepared by Loureiro Engineering Assoc, Inc  
HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

Printed 9/25/2024

Page 5

### Soil Listing (all nodes)

Area (sq-ft)	Soil Group	Subcatchment Numbers
1,488,222	HSG A	1, 2, 3, 4, 6, 7, 8, 9, 10, 11
20,111	HSG B	1, 11
0	HSG C	
1,774,978	HSG D	1, 2, 3, 4, 5, 6, 7, 9
0	Other	
<b>3,283,311</b>		<b>TOTAL AREA</b>

## New Conditions

Prepared by Loureiro Engineering Assoc, Inc

Printed 9/25/2024

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

Page 6

### Ground Covers (all nodes)

HSG-A (sq-ft)	HSG-B (sq-ft)	HSG-C (sq-ft)	HSG-D (sq-ft)	Other (sq-ft)	Total (sq-ft)	Ground Cover
883,042	0	0	400,892	0	1,283,934	>75% Grass cover, Good
76,598	4,094	0	118,932	0	199,624	Brush, Good
1,022	0	0	2,922	0	3,944	Dirt roads
9,853	0	0	72,185	0	82,038	Gravel roads
39,655	0	0	0	0	39,655	Gravel surface
24,103	0	0	145,671	0	169,774	Unconnected pavement
453,950	16,017	0	704,815	0	1,174,782	Woods, Good
0	0	0	329,560	0	329,560	Woods/grass comb., Poor
<b>1,488,222</b>	<b>20,111</b>	<b>0</b>	<b>1,774,978</b>	<b>0</b>	<b>3,283,311</b>	<b>TOTAL AREA</b>

## New Conditions

Prepared by Loureiro Engineering Assoc, Inc  
HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

Printed 9/25/2024

Page 7

### Pipe Listing (all nodes)

Line#	Node Number	In-Invert (feet)	Out-Invert (feet)	Length (feet)	Slope (ft/ft)	n	Width (inches)	Diam/Height (inches)	Inside-Fill (inches)
1	12P	21.00	19.10	184.0	0.0103	0.012	0.0	30.0	0.0
2	13P	14.00	12.50	107.0	0.0140	0.012	0.0	30.0	0.0
3	18P	20.00	19.50	25.0	0.0200	0.013	0.0	18.0	0.0
4	20P	16.00	13.80	202.0	0.0109	0.013	0.0	30.0	0.0
5	21P	22.00	21.00	56.0	0.0179	0.013	0.0	24.0	0.0
6	22P	34.00	22.00	838.0	0.0143	0.013	0.0	24.0	0.0

## New Conditions

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 2-yr Rainfall=3.46"

Printed 9/25/2024

Page 8

Time span=0.00-96.00 hrs, dt=0.01 hrs, 9601 points  
Runoff by SCS TR-20 method, UH=SCS, Weighted-CN  
Reach routing by Stor-Ind+Trans method - Pond routing by Stor-Ind method

<b>Subcatchment1: Subcat 1</b>	Runoff Area=121,732 sf 0.00% Impervious Runoff Depth=0.03" Flow Length=1,013' Tc=23.3 min CN=42 Runoff=0.01 cfs 341 cf
<b>Subcatchment2: Subcat 2</b>	Runoff Area=150,383 sf 12.20% Impervious Runoff Depth=0.55" Flow Length=296' Tc=17.5 min UI Adjusted CN=61 Runoff=1.11 cfs 6,954 cf
<b>Subcatchment3: Subcat 3</b>	Runoff Area=542,887 sf 2.45% Impervious Runoff Depth=0.14" Flow Length=936' Tc=44.3 min UI Adjusted CN=48 Runoff=0.24 cfs 6,240 cf
<b>Subcatchment4: Subcat 4</b>	Runoff Area=480,934 sf 13.66% Impervious Runoff Depth=1.75" Flow Length=633' Tc=36.3 min UI Adjusted CN=82 Runoff=10.83 cfs 70,122 cf
<b>Subcatchment5: Subcat 5</b>	Runoff Area=625,838 sf 0.00% Impervious Runoff Depth=1.47" Flow Length=1,037' Tc=40.7 min CN=78 Runoff=10.95 cfs 76,511 cf
<b>Subcatchment6: Subcat 6</b>	Runoff Area=405,402 sf 16.44% Impervious Runoff Depth=1.40" Flow Length=280' Tc=29.1 min UI Adjusted CN=77 Runoff=8.06 cfs 47,326 cf
<b>Subcatchment7: Subcat 7</b>	Runoff Area=351,134 sf 0.00% Impervious Runoff Depth=0.14" Flow Length=815' Tc=28.4 min CN=48 Runoff=0.17 cfs 4,036 cf
<b>Subcatchment8: Subcat 8</b>	Runoff Area=109,129 sf 0.00% Impervious Runoff Depth=0.05" Flow Length=261' Slope=0.0150 '/' Tc=18.5 min CN=43 Runoff=0.01 cfs 423 cf
<b>Subcatchment9: Subcat 9</b>	Runoff Area=209,524 sf 2.74% Impervious Runoff Depth=0.08" Flow Length=651' Tc=22.1 min UI Adjusted CN=45 Runoff=0.04 cfs 1,360 cf
<b>Subcatchment10: Subcat 10</b>	Runoff Area=48,549 sf 0.00% Impervious Runoff Depth=0.06" Flow Length=335' Tc=16.8 min CN=44 Runoff=0.01 cfs 248 cf
<b>Subcatchment11: Subcat 11</b>	Runoff Area=237,799 sf 0.00% Impervious Runoff Depth=0.00" Flow Length=138' Tc=17.2 min CN=30 Runoff=0.00 cfs 0 cf
<b>Pond 12P: Water Quality Basin #4</b>	Peak Elev=24.41' Storage=45,819 cf Inflow=10.83 cfs 70,122 cf Discarded=0.47 cfs 51,826 cf Primary=0.18 cfs 18,296 cf Outflow=0.65 cfs 70,122 cf
<b>Pond 13P: Water Quality Basin #1</b>	Peak Elev=14.02' Storage=212 cf Inflow=0.04 cfs 1,360 cf Discarded=0.04 cfs 1,360 cf Primary=0.00 cfs 0 cf Outflow=0.04 cfs 1,360 cf
<b>Pond 18P: Water Quality Basin #5</b>	Peak Elev=20.04' Storage=69 cf Inflow=0.01 cfs 423 cf Discarded=0.01 cfs 423 cf Primary=0.00 cfs 0 cf Outflow=0.01 cfs 423 cf
<b>Pond 20P: Water Quality Basin #3.1</b>	Peak Elev=19.19' Storage=27,462 cf Inflow=8.06 cfs 47,326 cf Discarded=0.30 cfs 26,031 cf Primary=0.32 cfs 21,295 cf Outflow=0.62 cfs 47,326 cf
<b>Pond 21P: Water Quality Basin #2</b>	Peak Elev=22.14' Storage=1,502 cf Inflow=0.24 cfs 6,240 cf Discarded=0.12 cfs 6,240 cf Primary=0.00 cfs 0 cf Outflow=0.12 cfs 6,240 cf

**New Conditions**

NOAA 24-hr D 2-yr Rainfall=3.46"

Prepared by Loureiro Engineering Assoc, Inc

Printed 9/25/2024

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

Page 9

**Pond 22P: Water Quality Basin #3.2** Peak Elev=35.48' Storage=3,700 cf Inflow=1.11 cfs 6,954 cf  
Discarded=0.06 cfs 5,821 cf Primary=0.04 cfs 1,133 cf Outflow=0.10 cfs 6,954 cf

**Link 2L: Northeast Wetland** Inflow=0.01 cfs 341 cf  
Primary=0.01 cfs 341 cf

**Link 3L: South Off-Site (POC 3)** Inflow=10.95 cfs 76,511 cf  
Primary=10.95 cfs 76,511 cf

**Link 4L: West Wetlands (POC 1)** Inflow=0.56 cfs 41,313 cf  
Primary=0.56 cfs 41,313 cf

**Link 5L: West Off-Site (POC 2)** Inflow=0.17 cfs 4,036 cf  
Primary=0.17 cfs 4,036 cf

**Total Runoff Area = 3,283,311 sf Runoff Volume = 213,561 cf Average Runoff Depth = 0.78"**  
**94.83% Pervious = 3,113,537 sf 5.17% Impervious = 169,774 sf**

**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc  
 HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 2-yr Rainfall=3.46"

Printed 9/25/2024

Page 10

**Summary for Subcatchment 1: Subcat 1**

Runoff = 0.01 cfs @ 21.62 hrs, Volume= 341 cf, Depth= 0.03"  
 Routed to Link 2L : Northeast Wetland

Runoff by SCS TR-20 method, UH=SCS, Weighted-CN, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 NOAA 24-hr D 2-yr Rainfall=3.46"

Area (sf)	CN	Description
700	48	Brush, Good, HSG B
14,806	55	Woods, Good, HSG B
1,211	55	Woods, Good, HSG B
24	39	>75% Grass cover, Good, HSG A
1,022	72	Dirt roads, HSG A
9,987	30	Brush, Good, HSG A
13,422	30	Woods, Good, HSG A
21,799	77	Woods, Good, HSG D
58,761	30	Woods, Good, HSG A
121,732	42	Weighted Average
121,732	42	100.00% Pervious Area

Tc (min)	Length (feet)	Slope (ft/ft)	Velocity (ft/sec)	Capacity (cfs)	Description
13.3	100	0.2400	0.13		<b>Sheet Flow,</b> Woods: Dense underbrush n= 0.800 P2= 3.46"
10.0	913	0.0920	1.52		<b>Shallow Concentrated Flow,</b> Woodland Kv= 5.0 fps
23.3	1,013	Total			



**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC


NOAA 24-hr D 2-yr Rainfall=3.46"

Printed 9/25/2024

Page 11

**Subcatchment 1: Subcat 1**

Hydrograph



**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc  
 HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 2-yr Rainfall=3.46"

Printed 9/25/2024

Page 12

**Summary for Subcatchment 2: Subcat 2**

Runoff = 1.11 cfs @ 12.31 hrs, Volume= 6,954 cf, Depth= 0.55"  
 Routed to Pond 22P : Water Quality Basin #3.2

Runoff by SCS TR-20 method, UH=SCS, Weighted-CN, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 NOAA 24-hr D 2-yr Rainfall=3.46"

Area (sf)	CN	Adj	Description
72,676	39		>75% Grass cover, Good, HSG A
18,352	98		Unconnected pavement, HSG A
995	96		Gravel surface, HSG A
6	30		Woods, Good, HSG A
4,992	77		Woods, Good, HSG D
35,625	86		Woods/grass comb., Poor, HSG D
17,737	80		>75% Grass cover, Good, HSG D
150,383	64	61	Weighted Average, UI Adjusted
132,031	59	59	87.80% Pervious Area
18,352	98	98	12.20% Impervious Area
18,352			100.00% Unconnected

Tc (min)	Length (feet)	Slope (ft/ft)	Velocity (ft/sec)	Capacity (cfs)	Description
14.6	62	0.0730	0.07		<b>Sheet Flow, sheet</b> Woods: Dense underbrush n= 0.800 P2= 3.46"
2.0					<b>Direct Entry, rock crossing</b>
0.9	234	0.0100	4.26	17.02	<b>Channel Flow, swale</b> Area= 4.0 sf Perim= 8.0' r= 0.50' n= 0.022 Earth, clean & straight
17.5	296	Total			

**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC


NOAA 24-hr D 2-yr Rainfall=3.46"

Printed 9/25/2024

Page 13

**Subcatchment 2: Subcat 2**

Hydrograph



**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc  
 HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 2-yr Rainfall=3.46"

Printed 9/25/2024

Page 14

**Summary for Subcatchment 3: Subcat 3**

Runoff = 0.24 cfs @ 13.73 hrs, Volume= 6,240 cf, Depth= 0.14"  
 Routed to Pond 21P : Water Quality Basin #2

Runoff by SCS TR-20 method, UH=SCS, Weighted-CN, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 NOAA 24-hr D 2-yr Rainfall=3.46"

Area (sf)	CN	Adj	Description
185,176	39		>75% Grass cover, Good, HSG A
238,754	39		>75% Grass cover, Good, HSG A
15,049	96		Gravel surface, HSG A
13,325	98		Unconnected pavement, HSG D
55,139	80		>75% Grass cover, Good, HSG D
9,578	77		Woods, Good, HSG D
25,866	86		Woods/grass comb., Poor, HSG D
542,887	49	48	Weighted Average, UI Adjusted
529,562	48	48	97.55% Pervious Area
13,325	98	98	2.45% Impervious Area
13,325			100.00% Unconnected

Tc (min)	Length (feet)	Slope (ft/ft)	Velocity (ft/sec)	Capacity (cfs)	Description
2.0					<b>Direct Entry,</b>
28.7	100	0.0350	0.06		<b>Sheet Flow, sheet</b> Woods: Dense underbrush n= 0.800 P2= 3.46"
2.1	246	0.0813	2.00		<b>Shallow Concentrated Flow, scf</b> Short Grass Pasture Kv= 7.0 fps
11.5	590	0.0150	0.86		<b>Shallow Concentrated Flow, scf grass</b> Short Grass Pasture Kv= 7.0 fps
44.3	936	Total			

**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC


NOAA 24-hr D 2-yr Rainfall=3.46"

Printed 9/25/2024

Page 15

**Subcatchment 3: Subcat 3**

Hydrograph



**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc  
 HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 2-yr Rainfall=3.46"

Printed 9/25/2024

Page 16

**Summary for Subcatchment 4: Subcat 4**

Runoff = 10.83 cfs @ 12.50 hrs, Volume= 70,122 cf, Depth= 1.75"  
 Routed to Pond 12P : Water Quality Basin #4

Runoff by SCS TR-20 method, UH=SCS, Weighted-CN, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 NOAA 24-hr D 2-yr Rainfall=3.46"

Area (sf)	CN	Adj	Description
414	96		Gravel surface, HSG A
9,603	39		>75% Grass cover, Good, HSG A
0	77		Woods, Good, HSG D
0	77		Woods, Good, HSG D
2	77		Woods, Good, HSG D
5,250	77		Woods, Good, HSG D
0	77		Woods, Good, HSG D
23,224	77		Woods, Good, HSG D
249,238	80		>75% Grass cover, Good, HSG D
65,690	98		Unconnected pavement, HSG D
127,513	86		Woods/grass comb., Poor, HSG D
480,934	83	82	Weighted Average, UI Adjusted
415,244	81	81	86.34% Pervious Area
65,690	98	98	13.66% Impervious Area
65,690			100.00% Unconnected

Tc (min)	Length (feet)	Slope (ft/ft)	Velocity (ft/sec)	Capacity (cfs)	Description
30.6	100	0.0300	0.05		<b>Sheet Flow, sheet</b> Woods: Dense underbrush n= 0.800 P2= 3.46"
0.7	50	0.1988	1.11		<b>Shallow Concentrated Flow, scf</b> Forest w/Heavy Litter Kv= 2.5 fps
2.0					<b>Direct Entry, rock crossing</b>
3.0	483	0.1500	2.71		<b>Shallow Concentrated Flow, scf grass</b> Short Grass Pasture Kv= 7.0 fps
36.3	633	Total			

**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC


NOAA 24-hr D 2-yr Rainfall=3.46"

Printed 9/25/2024

Page 17

**Subcatchment 4: Subcat 4**

Hydrograph



**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc  
 HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 2-yr Rainfall=3.46"

Printed 9/25/2024

Page 18

**Summary for Subcatchment 5: Subcat 5**

Runoff = 10.95 cfs @ 12.57 hrs, Volume= 76,511 cf, Depth= 1.47"  
 Routed to Link 3L : South Off-Site (POC 3)

Runoff by SCS TR-20 method, UH=SCS, Weighted-CN, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 NOAA 24-hr D 2-yr Rainfall=3.46"

Area (sf)	CN	Description
0	98	Unconnected pavement, HSG D
14,987	73	Brush, Good, HSG D
1,504	91	Gravel roads, HSG D
39,327	91	Gravel roads, HSG D
18,528	91	Gravel roads, HSG D
2,922	89	Dirt roads, HSG D
2,214	73	Brush, Good, HSG D
7,635	77	Woods, Good, HSG D
137,134	77	Woods, Good, HSG D
10,652	77	Woods, Good, HSG D
291,847	77	Woods, Good, HSG D
34,529	77	Woods, Good, HSG D
23,786	77	Woods, Good, HSG D
1,988	73	Brush, Good, HSG D
357	91	Gravel roads, HSG D
38,427	73	Brush, Good, HSG D
625,838	78	Weighted Average
625,838	78	100.00% Pervious Area
0	98	0.00% Impervious Area
0		100.00% Unconnected

Tc (min)	Length (feet)	Slope (ft/ft)	Velocity (ft/sec)	Capacity (cfs)	Description
26.0	100	0.0450	0.06		<b>Sheet Flow, sheet</b> Woods: Dense underbrush n= 0.800 P2= 3.46"
6.1	225	0.0600	0.61		<b>Shallow Concentrated Flow, scf woods</b> Forest w/Heavy Litter Kv= 2.5 fps
0.7	112	0.1560	2.76		<b>Shallow Concentrated Flow, scfbrush</b> Short Grass Pasture Kv= 7.0 fps
0.5	140	0.0820	4.61		<b>Shallow Concentrated Flow, scf unpaved</b> Unpaved Kv= 16.1 fps
7.4	460	0.1740	1.04		<b>Shallow Concentrated Flow, scf woods</b> Forest w/Heavy Litter Kv= 2.5 fps
40.7	1,037	Total			



**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC


NOAA 24-hr D 2-yr Rainfall=3.46"

Printed 9/25/2024

Page 19

**Subcatchment 5: Subcat 5**

Hydrograph



**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc  
 HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 2-yr Rainfall=3.46"

Printed 9/25/2024

Page 20

**Summary for Subcatchment 6: Subcat 6**

Runoff = 8.06 cfs @ 12.42 hrs, Volume= 47,326 cf, Depth= 1.40"  
 Routed to Pond 20P : Water Quality Basin #3.1

Runoff by SCS TR-20 method, UH=SCS, Weighted-CN, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 NOAA 24-hr D 2-yr Rainfall=3.46"

Area (sf)	CN	Adj	Description
1,758	73		Brush, Good, HSG D
66,656	98		Unconnected pavement, HSG D
1,257	77		Woods, Good, HSG D
34,488	77		Woods, Good, HSG D
49,599	39		>75% Grass cover, Good, HSG A
43,447	77		Woods, Good, HSG D
129,391	86		Woods/grass comb., Poor, HSG D
28	73		Brush, Good, HSG D
78,778	80		>75% Grass cover, Good, HSG D
405,402	79	77	Weighted Average, UI Adjusted
338,746	76	76	83.56% Pervious Area
66,656	98	98	16.44% Impervious Area
66,656			100.00% Unconnected

Tc (min)	Length (feet)	Slope (ft/ft)	Velocity (ft/sec)	Capacity (cfs)	Description
24.9	100	0.0500	0.07		<b>Sheet Flow, sheet</b> Woods: Dense underbrush n= 0.800 P2= 3.46"
2.2	180	0.3000	1.37		<b>Shallow Concentrated Flow, scf</b> Forest w/Heavy Litter Kv= 2.5 fps
2.0					<b>Direct Entry, rock crossing</b>
29.1	280	Total			

**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC


NOAA 24-hr D 2-yr Rainfall=3.46"

Printed 9/25/2024

Page 21

**Subcatchment 6: Subcat 6**

Hydrograph



**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc  
 HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 2-yr Rainfall=3.46"

Printed 9/25/2024

Page 22

**Summary for Subcatchment 7: Subcat 7**

Runoff = 0.17 cfs @ 13.35 hrs, Volume= 4,036 cf, Depth= 0.14"  
 Routed to Link 5L : West Off-Site (POC 2)

Runoff by SCS TR-20 method, UH=SCS, Weighted-CN, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 NOAA 24-hr D 2-yr Rainfall=3.46"

Area (sf)	CN	Description
8,651	91	Gravel roads, HSG D
11,645	73	Brush, Good, HSG D
8,819	73	Brush, Good, HSG D
23	77	Woods, Good, HSG D
338	77	Woods, Good, HSG D
7	77	Woods, Good, HSG D
9,853	76	Gravel roads, HSG A
17,832	30	Brush, Good, HSG A
195,049	30	Woods, Good, HSG A
1,207	30	Woods, Good, HSG A
7,262	77	Woods, Good, HSG D
47,566	77	Woods, Good, HSG D
39,066	73	Brush, Good, HSG D
1	91	Gravel roads, HSG D
3,817	91	Gravel roads, HSG D
351,134	48	Weighted Average
351,134	48	100.00% Pervious Area

Tc (min)	Length (feet)	Slope (ft/ft)	Velocity (ft/sec)	Capacity (cfs)	Description
18.9	100	0.1000	0.09		<b>Sheet Flow, sheet</b> Woods: Dense underbrush n= 0.800 P2= 3.46"
9.5	715	0.2500	1.25		<b>Shallow Concentrated Flow, scf</b> Forest w/Heavy Litter Kv= 2.5 fps
28.4	815	Total			

**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC


NOAA 24-hr D 2-yr Rainfall=3.46"

Printed 9/25/2024

Page 23

**Subcatchment 7: Subcat 7**

Hydrograph



**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc  
 HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 2-yr Rainfall=3.46"

Printed 9/25/2024

Page 24

**Summary for Subcatchment 8: Subcat 8**

Runoff = 0.01 cfs @ 16.96 hrs, Volume= 423 cf, Depth= 0.05"  
 Routed to Pond 18P : Water Quality Basin #5


Runoff by SCS TR-20 method, UH=SCS, Weighted-CN, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 NOAA 24-hr D 2-yr Rainfall=3.46"

Area (sf)	CN	Description
8,265	96	Gravel surface, HSG A
10,542	39	>75% Grass cover, Good, HSG A
90,322	39	>75% Grass cover, Good, HSG A
109,129	43	Weighted Average
109,129	43	100.00% Pervious Area

Tc (min)	Length (feet)	Slope (ft/ft)	Velocity (ft/sec)	Capacity (cfs)	Description
15.4	100	0.0150	0.11		<b>Sheet Flow, sheet</b>
					Grass: Dense n= 0.240 P2= 3.46"
3.1	161	0.0150	0.86		<b>Shallow Concentrated Flow, scf</b>
					Short Grass Pasture Kv= 7.0 fps
18.5	261	Total			

**Subcatchment 8: Subcat 8**

Hydrograph



**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc  
 HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 2-yr Rainfall=3.46"

Printed 9/25/2024

Page 25

**Summary for Subcatchment 9: Subcat 9**

Runoff = 0.04 cfs @ 14.66 hrs, Volume= 1,360 cf, Depth= 0.08"  
 Routed to Pond 13P : Water Quality Basin #1

Runoff by SCS TR-20 method, UH=SCS, Weighted-CN, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 NOAA 24-hr D 2-yr Rainfall=3.46"

Area (sf)	CN	Adj	Description
5,751	98		Unconnected pavement, HSG A
10,904	96		Gravel surface, HSG A
181,704	39		>75% Grass cover, Good, HSG A
11,165	86		Woods/grass comb., Poor, HSG D
209,524	46	45	Weighted Average, UI Adjusted
203,773	45	45	97.26% Pervious Area
5,751	98	98	2.74% Impervious Area
5,751			100.00% Unconnected

Tc (min)	Length (feet)	Slope (ft/ft)	Velocity (ft/sec)	Capacity (cfs)	Description
15.4	100	0.0150	0.11		<b>Sheet Flow, sheet</b> Grass: Dense n= 0.240 P2= 3.46"
5.7	291	0.0150	0.86		<b>Shallow Concentrated Flow, scf</b> Short Grass Pasture Kv= 7.0 fps
1.0	260	0.0100	4.26	17.02	<b>Channel Flow, swale</b> Area= 4.0 sf Perim= 8.0' r= 0.50' n= 0.022 Earth, clean & straight
22.1	651	Total			

**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC


NOAA 24-hr D 2-yr Rainfall=3.46"

Printed 9/25/2024

Page 26

**Subcatchment 9: Subcat 9**

Hydrograph





**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 2-yr Rainfall=3.46"

Printed 9/25/2024

Page 27

**Summary for Subcatchment 10: Subcat 10**

Runoff = 0.01 cfs @ 16.48 hrs, Volume= 248 cf, Depth= 0.06"  
 Routed to Link 4L : West Wetlands (POC 1)


Runoff by SCS TR-20 method, UH=SCS, Weighted-CN, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 NOAA 24-hr D 2-yr Rainfall=3.46"

Area (sf)	CN	Description
15,200	39	>75% Grass cover, Good, HSG A
29,317	39	>75% Grass cover, Good, HSG A
4,025	96	Gravel surface, HSG A
5	30	Woods, Good, HSG A
1	30	Woods, Good, HSG A
2	30	Woods, Good, HSG A
0	30	Woods, Good, HSG A
48,549	44	Weighted Average
48,549	44	100.00% Pervious Area

Tc (min)	Length (feet)	Slope (ft/ft)	Velocity (ft/sec)	Capacity (cfs)	Description
15.4	100	0.0150	0.11		<b>Sheet Flow, sheet</b> Grass: Dense n= 0.240 P2= 3.46"
1.4	235	0.1500	2.71		<b>Shallow Concentrated Flow, scf</b> Short Grass Pasture Kv= 7.0 fps
16.8	335	Total			

**Subcatchment 10: Subcat 10**

Hydrograph



**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 2-yr Rainfall=3.46"

Printed 9/25/2024

Page 28

**Summary for Subcatchment 11: Subcat 11**

[45] Hint: Runoff=Zero

Runoff = 0.00 cfs @ 0.00 hrs, Volume= 0 cf, Depth= 0.00"  
 Routed to Link 2L : Northeast Wetland

Runoff by SCS TR-20 method, UH=SCS, Weighted-CN, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 NOAA 24-hr D 2-yr Rainfall=3.46"

Area (sf)	CN	Description
3,394	48	Brush, Good, HSG B
72	39	>75% Grass cover, Good, HSG A
3	96	Gravel surface, HSG A
29	39	>75% Grass cover, Good, HSG A
24	39	>75% Grass cover, Good, HSG A
48,779	30	Brush, Good, HSG A
185,489	30	Woods, Good, HSG A
8	30	Woods, Good, HSG A
237,799	30	Weighted Average
237,799	30	100.00% Pervious Area

Tc (min)	Length (feet)	Slope (ft/ft)	Velocity (ft/sec)	Capacity (cfs)	Description
16.5	100	0.1400	0.10		<b>Sheet Flow, sheet</b> Woods: Dense underbrush n= 0.800 P2= 3.46"
0.7	38	0.1369	0.93		<b>Shallow Concentrated Flow, scf</b> Forest w/Heavy Litter Kv= 2.5 fps
17.2	138	Total			

**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC


NOAA 24-hr D 2-yr Rainfall=3.46"

Printed 9/25/2024

Page 29

**Subcatchment 11: Subcat 11**

Hydrograph



**New Conditions**

NOAA 24-hr D 2-yr Rainfall=3.46"

Prepared by Loureiro Engineering Assoc, Inc

Printed 9/25/2024

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

Page 30

**Summary for Pond 12P: Water Quality Basin #4**

Inflow Area = 480,934 sf, 13.66% Impervious, Inflow Depth = 1.75" for 2-yr event  
 Inflow = 10.83 cfs @ 12.50 hrs, Volume= 70,122 cf  
 Outflow = 0.65 cfs @ 17.80 hrs, Volume= 70,122 cf, Atten= 94%, Lag= 317.9 min  
 Discarded = 0.47 cfs @ 17.80 hrs, Volume= 51,826 cf  
 Primary = 0.18 cfs @ 17.80 hrs, Volume= 18,296 cf  
 Routed to Link 4L : West Wetlands (POC 1)

Routing by Stor-Ind method, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 Peak Elev= 24.41' @ 17.80 hrs Surf.Area= 16,202 sf Storage= 45,819 cf

Plug-Flow detention time= 919.7 min calculated for 70,114 cf (100% of inflow)  
 Center-of-Mass det. time= 919.9 min ( 1,790.7 - 870.8 )

Volume	Invert	Avail.Storage	Storage Description			
#1	21.00'	115,489 cf	<b>Custom Stage Data (Irregular)</b> Listed below (Recalc)			
Elevation (feet)	Surf.Area (sq-ft)	Perim. (feet)	Inc.Store (cubic-feet)	Cum.Store (cubic-feet)	Wet.Area (sq-ft)	
21.00	10,788	488.0	0	0	10,788	
22.00	12,288	512.0	11,530	11,530	12,762	
23.00	13,860	536.0	13,066	24,596	14,831	
24.00	15,504	560.0	14,674	39,270	16,995	
25.00	17,220	584.0	16,354	55,625	19,253	
26.00	19,008	608.0	18,107	73,731	21,607	
27.00	20,868	632.0	19,931	93,662	24,055	
28.00	22,800	656.0	21,827	115,489	26,598	

Device	Routing	Invert	Outlet Devices	
#1	Primary	21.00'	<b>30.0" Round Culvert</b> L= 184.0' Ke= 0.500 Inlet / Outlet Invert= 21.00' / 19.10' S= 0.0103 '/' Cc= 0.900 n= 0.012 Corrugated PP, smooth interior, Flow Area= 4.91 sf	
#2	Device 1	26.50'	<b>48.0" W x 36.0" H Vert. Orifice/Grate X 2.00</b> C= 0.600 Limited to weir flow at low heads	
#3	Discarded	21.00'	<b>0.500 in/hr Exfiltration over Wetted area</b> Conductivity to Groundwater Elevation = 19.00'	
#4	Device 1	21.30'	<b>2.0" Vert. Orifice/Grate</b> C= 0.600 Limited to weir flow at low heads	
#5	Device 1	24.70'	<b>6.0" Vert. Orifice/Grate</b> C= 0.600 Limited to weir flow at low heads	

**Discarded OutFlow** Max=0.47 cfs @ 17.80 hrs HW=24.41' (Free Discharge)  
 ↳ **3=Exfiltration** ( Controls 0.47 cfs)

**Primary OutFlow** Max=0.18 cfs @ 17.80 hrs HW=24.41' (Free Discharge)  
 ↳ **1=Culvert** (Passes 0.18 cfs of 34.76 cfs potential flow)  
 ↳ **2=Orifice/Grate** ( Controls 0.00 cfs)  
 ↳ **4=Orifice/Grate** (Orifice Controls 0.18 cfs @ 8.38 fps)  
 ↳ **5=Orifice/Grate** ( Controls 0.00 cfs)

**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC


NOAA 24-hr D 2-yr Rainfall=3.46"

Printed 9/25/2024

Page 31

**Pond 12P: Water Quality Basin #4**

Hydrograph



**New Conditions**

NOAA 24-hr D 2-yr Rainfall=3.46"

Prepared by Loureiro Engineering Assoc, Inc

Printed 9/25/2024

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

Page 32

**Summary for Pond 13P: Water Quality Basin #1**

Inflow Area = 209,524 sf, 2.74% Impervious, Inflow Depth = 0.08" for 2-yr event  
 Inflow = 0.04 cfs @ 14.66 hrs, Volume= 1,360 cf  
 Outflow = 0.04 cfs @ 17.68 hrs, Volume= 1,360 cf, Atten= 16%, Lag= 181.4 min  
 Discarded = 0.04 cfs @ 17.68 hrs, Volume= 1,360 cf  
 Primary = 0.00 cfs @ 0.00 hrs, Volume= 0 cf  
 Routed to Link 4L : West Wetlands (POC 1)

Routing by Stor-Ind method, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 Peak Elev= 14.02' @ 17.68 hrs Surf.Area= 9,214 sf Storage= 212 cf

Plug-Flow detention time= 100.2 min calculated for 1,360 cf (100% of inflow)  
 Center-of-Mass det. time= 100.2 min ( 1,205.3 - 1,105.0 )

Volume	Invert	Avail.Storage	Storage Description		
#1	14.00'	66,060 cf	<b>Custom Stage Data (Irregular)</b> Listed below (Recalc)		
Elevation (feet)	Surf.Area (sq-ft)	Perim. (feet)	Inc.Store (cubic-feet)	Cum.Store (cubic-feet)	Wet.Area (sq-ft)
14.00	9,180	498.0	0	0	9,180
15.00	10,710	522.0	9,935	9,935	11,194
16.00	12,312	546.0	11,502	21,437	13,302
17.00	13,986	570.0	13,140	34,577	15,505
18.00	15,732	594.0	14,850	49,427	17,803
19.00	17,550	618.0	16,633	66,060	20,196

Device	Routing	Invert	Outlet Devices
#1	Primary	14.00'	<b>30.0" Round Culvert</b> L= 107.0' Ke= 0.500 Inlet / Outlet Invert= 14.00' / 12.50' S= 0.0140 '/' Cc= 0.900 n= 0.012 Corrugated PP, smooth interior, Flow Area= 4.91 sf
#2	Device 1	18.00'	<b>48.0" W x 36.0" H Vert. Orifice/Grate X 2.00</b> C= 0.600 Limited to weir flow at low heads
#3	Discarded	14.00'	<b>0.500 in/hr Exfiltration over Surface area</b>
#4	Device 1	14.40'	<b>6.0" Vert. Orifice/Grate</b> C= 0.600 Limited to weir flow at low heads

**Discarded OutFlow** Max=0.11 cfs @ 17.68 hrs HW=14.02' (Free Discharge)  
 ↑ **3=Exfiltration** (Exfiltration Controls 0.11 cfs)

**Primary OutFlow** Max=0.00 cfs @ 0.00 hrs HW=14.00' (Free Discharge)  
 ↑ **1=Culvert** ( Controls 0.00 cfs)  
 ↑ **2=Orifice/Grate** ( Controls 0.00 cfs)  
 ↑ **4=Orifice/Grate** ( Controls 0.00 cfs)

**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC


NOAA 24-hr D 2-yr Rainfall=3.46"

Printed 9/25/2024

Page 33

**Pond 13P: Water Quality Basin #1**

Hydrograph



**New Conditions**

NOAA 24-hr D 2-yr Rainfall=3.46"

Prepared by Loureiro Engineering Assoc, Inc

Printed 9/25/2024

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

Page 34

**Summary for Pond 18P: Water Quality Basin #5**

Inflow Area = 109,129 sf, 0.00% Impervious, Inflow Depth = 0.05" for 2-yr event  
 Inflow = 0.01 cfs @ 16.96 hrs, Volume= 423 cf  
 Outflow = 0.01 cfs @ 22.07 hrs, Volume= 423 cf, Atten= 6%, Lag= 306.4 min  
 Discarded = 0.01 cfs @ 22.07 hrs, Volume= 423 cf  
 Primary = 0.00 cfs @ 0.00 hrs, Volume= 0 cf  
 Routed to Link 4L : West Wetlands (POC 1)

Routing by Stor-Ind method, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 Peak Elev= 20.04' @ 22.07 hrs Surf.Area= 1,745 sf Storage= 69 cf

Plug-Flow detention time= 99.7 min calculated for 423 cf (100% of inflow)  
 Center-of-Mass det. time= 99.6 min ( 1,251.0 - 1,151.5 )

Volume	Invert	Avail.Storage	Storage Description			
#1	20.00'	18,040 cf	<b>Custom Stage Data (Irregular)</b> Listed below (Recalc)			
Elevation (feet)	Surf.Area (sq-ft)	Perim. (feet)	Inc.Store (cubic-feet)	Cum.Store (cubic-feet)	Wet.Area (sq-ft)	
20.00	1,720	212.0	0	0	1,720	
21.00	2,392	236.0	2,047	2,047	2,604	
22.00	3,136	260.0	2,756	4,802	3,584	
23.00	3,952	284.0	3,536	8,339	4,658	
24.00	4,840	308.0	4,389	12,727	5,826	
25.00	5,800	332.0	5,313	18,040	7,090	

Device	Routing	Invert	Outlet Devices
#1	Primary	20.00'	<b>18.0" Round Culvert</b> L= 25.0' Ke= 0.500 Inlet / Outlet Invert= 20.00' / 19.50' S= 0.0200 '/' Cc= 0.900 n= 0.013 Corrugated PE, smooth interior, Flow Area= 1.77 sf
#2	Device 1	24.00'	<b>48.0" W x 36.0" H Vert. Orifice/Grate X 2.00</b> C= 0.600 Limited to weir flow at low heads
#3	Discarded	20.00'	<b>0.500 in/hr Exfiltration over Surface area</b>
#4	Device 1	20.40'	<b>6.0" Vert. Orifice/Grate</b> C= 0.600 Limited to weir flow at low heads

**Discarded OutFlow** Max=0.02 cfs @ 22.07 hrs HW=20.04' (Free Discharge)  
 ↑ **3=Exfiltration** (Exfiltration Controls 0.02 cfs)

**Primary OutFlow** Max=0.00 cfs @ 0.00 hrs HW=20.00' (Free Discharge)  
 ↑ **1=Culvert** ( Controls 0.00 cfs)  
 ↑ **2=Orifice/Grate** ( Controls 0.00 cfs)  
 ↑ **4=Orifice/Grate** ( Controls 0.00 cfs)



**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC


NOAA 24-hr D 2-yr Rainfall=3.46"

Printed 9/25/2024

Page 35

**Pond 18P: Water Quality Basin #5**

Hydrograph



**New Conditions**

NOAA 24-hr D 2-yr Rainfall=3.46"

Prepared by Loureiro Engineering Assoc, Inc

Printed 9/25/2024

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

Page 36

**Summary for Pond 20P: Water Quality Basin #3.1**

Inflow Area = 405,402 sf, 16.44% Impervious, Inflow Depth = 1.40" for 2-yr event  
 Inflow = 8.06 cfs @ 12.42 hrs, Volume= 47,326 cf  
 Outflow = 0.62 cfs @ 16.23 hrs, Volume= 47,326 cf, Atten= 92%, Lag= 228.6 min  
 Discarded = 0.30 cfs @ 16.23 hrs, Volume= 26,031 cf  
 Primary = 0.32 cfs @ 16.23 hrs, Volume= 21,295 cf  
 Routed to Link 4L : West Wetlands (POC 1)

Routing by Stor-Ind method, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 Peak Elev= 19.19' @ 16.23 hrs Surf.Area= 11,007 sf Storage= 27,462 cf

Plug-Flow detention time= 628.4 min calculated for 47,326 cf (100% of inflow)  
 Center-of-Mass det. time= 628.3 min ( 1,509.4 - 881.2 )

Volume	Invert	Avail.Storage	Storage Description			
#1	16.00'	81,518 cf	<b>Custom Stage Data (Irregular)</b> Listed below (Recalc)			
Elevation (feet)	Surf.Area (sq-ft)	Perim. (feet)	Inc.Store (cubic-feet)	Cum.Store (cubic-feet)	Wet.Area (sq-ft)	
16.00	6,336	450.0	0	0	6,336	
17.00	7,722	474.0	7,018	7,018	8,160	
18.00	9,180	498.0	8,440	15,458	10,079	
19.00	10,710	522.0	9,935	25,393	12,093	
20.00	12,312	546.0	11,502	36,895	14,201	
21.00	13,986	570.0	13,140	50,035	16,405	
22.00	15,732	594.0	14,850	64,886	18,703	
23.00	17,550	618.0	16,633	81,518	21,095	

Device	Routing	Invert	Outlet Devices	
#1	Primary	16.00'	<b>30.0" Round Culvert</b> L= 202.0' Ke= 0.500 Inlet / Outlet Invert= 16.00' / 13.80' S= 0.0109 '/' Cc= 0.900 n= 0.013 Corrugated PE, smooth interior, Flow Area= 4.91 sf	
#2	Device 1	22.00'	<b>48.0" W x 36.0" H Vert. Orifice/Grate X 2.00</b> C= 0.600 Limited to weir flow at low heads	
#3	Discarded	16.00'	<b>0.500 in/hr Exfiltration over Wetted area</b> Conductivity to Groundwater Elevation = 14.00'	
#4	Device 1	16.50'	<b>2.0" Vert. Orifice/Grate</b> C= 0.600 Limited to weir flow at low heads	
#5	Device 1	17.00'	<b>2.0" Vert. Orifice/Grate</b> C= 0.600 Limited to weir flow at low heads	

**Discarded OutFlow** Max=0.30 cfs @ 16.23 hrs HW=19.19' (Free Discharge)  
 ↳ **3=Exfiltration** ( Controls 0.30 cfs)

**Primary OutFlow** Max=0.32 cfs @ 16.23 hrs HW=19.19' (Free Discharge)  
 ↳ **1=Culvert** (Passes 0.32 cfs of 32.92 cfs potential flow)  
 ↳ **2=Orifice/Grate** ( Controls 0.00 cfs)  
 ↳ **4=Orifice/Grate** (Orifice Controls 0.17 cfs @ 7.77 fps)  
 ↳ **5=Orifice/Grate** (Orifice Controls 0.15 cfs @ 6.99 fps)

# New Conditions

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC


NOAA 24-hr D 2-yr Rainfall=3.46"

Printed 9/25/2024

Page 37

## Pond 20P: Water Quality Basin #3.1

Hydrograph



**New Conditions**

NOAA 24-hr D 2-yr Rainfall=3.46"

Prepared by Loureiro Engineering Assoc, Inc

Printed 9/25/2024

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

Page 38

**Summary for Pond 21P: Water Quality Basin #2**

Inflow Area = 542,887 sf, 2.45% Impervious, Inflow Depth = 0.14" for 2-yr event  
 Inflow = 0.24 cfs @ 13.73 hrs, Volume= 6,240 cf  
 Outflow = 0.12 cfs @ 18.89 hrs, Volume= 6,240 cf, Atten= 49%, Lag= 309.7 min  
 Discarded = 0.12 cfs @ 18.89 hrs, Volume= 6,240 cf  
 Primary = 0.00 cfs @ 0.00 hrs, Volume= 0 cf  
 Routed to Link 4L : West Wetlands (POC 1)

Routing by Stor-Ind method, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 Peak Elev= 22.14' @ 18.89 hrs Surf.Area= 10,769 sf Storage= 1,502 cf

Plug-Flow detention time= 166.3 min calculated for 6,240 cf (100% of inflow)  
 Center-of-Mass det. time= 166.2 min ( 1,237.5 - 1,071.3 )

Volume	Invert	Avail.Storage	Storage Description		
#1	22.00'	74,350 cf	<b>Custom Stage Data (Irregular)</b> Listed below (Recalc)		
Elevation (feet)	Surf.Area (sq-ft)	Perim. (feet)	Inc.Store (cubic-feet)	Cum.Store (cubic-feet)	Wet.Area (sq-ft)
22.00	10,550	552.0	0	0	10,550
23.00	12,152	546.0	11,342	11,342	11,309
24.00	13,826	570.0	12,980	24,322	13,512
25.00	15,572	594.0	14,690	39,012	15,810
26.00	17,930	618.0	16,737	55,749	18,203
27.00	19,280	642.0	18,601	74,350	20,691

Device	Routing	Invert	Outlet Devices
#1	Primary	22.00'	<b>24.0" Round Culvert</b> L= 56.0' Ke= 0.500 Inlet / Outlet Invert= 22.00' / 21.00' S= 0.0179 '/ Cc= 0.900 n= 0.013 Corrugated PE, smooth interior, Flow Area= 3.14 sf
#2	Device 1	26.80'	<b>48.0" W x 36.0" H Vert. Orifice/Grate X 2.00</b> C= 0.600 Limited to weir flow at low heads
#3	Discarded	22.00'	<b>0.500 in/hr Exfiltration over Surface area</b>
#4	Device 1	22.40'	<b>6.0" Vert. Orifice/Grate</b> C= 0.600 Limited to weir flow at low heads

**Discarded OutFlow** Max=0.12 cfs @ 18.89 hrs HW=22.14' (Free Discharge)  
 ↳ **3=Exfiltration** (Exfiltration Controls 0.12 cfs)

**Primary OutFlow** Max=0.00 cfs @ 0.00 hrs HW=22.00' (Free Discharge)  
 ↳ **1=Culvert** ( Controls 0.00 cfs)  
     ↳ **2=Orifice/Grate** ( Controls 0.00 cfs)  
         ↳ **4=Orifice/Grate** ( Controls 0.00 cfs)

**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC


NOAA 24-hr D 2-yr Rainfall=3.46"

Printed 9/25/2024

Page 39

**Pond 21P: Water Quality Basin #2**

Hydrograph



**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc  
 HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 2-yr Rainfall=3.46"

Printed 9/25/2024

Page 40

**Summary for Pond 22P: Water Quality Basin #3.2**

Inflow Area = 150,383 sf, 12.20% Impervious, Inflow Depth = 0.55" for 2-yr event  
 Inflow = 1.11 cfs @ 12.31 hrs, Volume= 6,954 cf  
 Outflow = 0.10 cfs @ 17.51 hrs, Volume= 6,954 cf, Atten= 91%, Lag= 311.8 min  
 Discarded = 0.06 cfs @ 17.51 hrs, Volume= 5,821 cf  
 Primary = 0.04 cfs @ 17.51 hrs, Volume= 1,133 cf  
 Routed to Link 4L : West Wetlands (POC 1)

Routing by Stor-Ind method, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 Peak Elev= 35.48' @ 17.51 hrs Surf.Area= 3,080 sf Storage= 3,700 cf  
 Flood Elev= 39.00' Surf.Area= 6,400 sf Storage= 20,137 cf

Plug-Flow detention time= 641.2 min calculated for 6,954 cf (100% of inflow)  
 Center-of-Mass det. time= 641.1 min ( 1,574.1 - 933.0 )

Volume	Invert	Avail.Storage	Storage Description			
#1	34.00'	20,137 cf	<b>Custom Stage Data (Irregular)</b> Listed below (Recalc)			
Elevation (feet)	Surf.Area (sq-ft)	Perim. (feet)	Inc.Store (cubic-feet)	Cum.Store (cubic-feet)	Wet.Area (sq-ft)	
34.00	1,960	236.0	0	0	1,960	
35.00	2,704	260.0	2,322	2,322	2,939	
36.00	3,520	284.0	3,103	5,425	4,013	
37.00	4,408	308.0	3,956	9,381	5,182	
38.00	5,368	332.0	4,880	14,261	6,445	
39.00	6,400	356.0	5,876	20,137	7,804	

Device	Routing	Invert	Outlet Devices	
#1	Primary	34.00'	<b>24.0" Round Culvert</b> L= 838.0' Ke= 0.500 Inlet / Outlet Invert= 34.00' / 22.00' S= 0.0143 '/ Cc= 0.900 n= 0.013 Corrugated PE, smooth interior, Flow Area= 3.14 sf	
#2	Device 1	38.50'	<b>48.0" W x 36.0" H Vert. Orifice/Grate X 2.00</b> C= 0.600 Limited to weir flow at low heads	
#3	Discarded	34.00'	<b>0.500 in/hr Exfiltration over Wetted area</b> Conductivity to Groundwater Elevation = 32.00'	
#4	Device 1	35.25'	<b>2.0" Vert. Orifice/Grate</b> C= 0.600 Limited to weir flow at low heads	
#5	Device 1	36.00'	<b>6.0" Vert. Orifice/Grate</b> C= 0.600 Limited to weir flow at low heads	

**Discarded OutFlow** Max=0.06 cfs @ 17.51 hrs HW=35.48' (Free Discharge)  
 ↳ **3=Exfiltration** ( Controls 0.06 cfs)

**Primary OutFlow** Max=0.04 cfs @ 17.51 hrs HW=35.48' (Free Discharge)  
 ↳ **1=Culvert** (Passes 0.04 cfs of 10.29 cfs potential flow)  
 ↳ **2=Orifice/Grate** ( Controls 0.00 cfs)  
 ↳ **4=Orifice/Grate** (Orifice Controls 0.04 cfs @ 1.82 fps)  
 ↳ **5=Orifice/Grate** ( Controls 0.00 cfs)

**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC


NOAA 24-hr D 2-yr Rainfall=3.46"

Printed 9/25/2024

Page 41

**Pond 22P: Water Quality Basin #3.2**

Hydrograph



**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 2-yr Rainfall=3.46"

Printed 9/25/2024

Page 42


**Summary for Link 2L: Northeast Wetland**

Inflow Area = 359,530 sf, 0.00% Impervious, Inflow Depth = 0.01" for 2-yr event  
Inflow = 0.01 cfs @ 21.62 hrs, Volume= 341 cf  
Primary = 0.01 cfs @ 21.62 hrs, Volume= 341 cf, Atten= 0%, Lag= 0.0 min  
Routed to Link 4L : West Wetlands (POC 1)

Primary outflow = Inflow, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs

**Link 2L: Northeast Wetland**

Hydrograph





**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 2-yr Rainfall=3.46"

Printed 9/25/2024

Page 43


**Summary for Link 3L: South Off-Site (POC 3)**

Inflow Area = 625,838 sf, 0.00% Impervious, Inflow Depth = 1.47" for 2-yr event  
Inflow = 10.95 cfs @ 12.57 hrs, Volume= 76,511 cf  
Primary = 10.95 cfs @ 12.57 hrs, Volume= 76,511 cf, Atten= 0%, Lag= 0.0 min

Primary outflow = Inflow, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs

**Link 3L: South Off-Site (POC 3)**

Hydrograph



**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 2-yr Rainfall=3.46"

Printed 9/25/2024

Page 44


**Summary for Link 4L: West Wetlands (POC 1)**

Inflow Area = 2,306,339 sf, 7.36% Impervious, Inflow Depth = 0.21" for 2-yr event  
Inflow = 0.56 cfs @ 17.16 hrs, Volume= 41,313 cf  
Primary = 0.56 cfs @ 17.16 hrs, Volume= 41,313 cf, Atten= 0%, Lag= 0.0 min

Primary outflow = Inflow, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs

**Link 4L: West Wetlands (POC 1)**

Hydrograph



# New Conditions

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 2-yr Rainfall=3.46"

Printed 9/25/2024

Page 45


## Summary for Link 5L: West Off-Site (POC 2)

Inflow Area = 351,134 sf, 0.00% Impervious, Inflow Depth = 0.14" for 2-yr event  
Inflow = 0.17 cfs @ 13.35 hrs, Volume= 4,036 cf  
Primary = 0.17 cfs @ 13.35 hrs, Volume= 4,036 cf, Atten= 0%, Lag= 0.0 min

Primary outflow = Inflow, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs

## Link 5L: West Off-Site (POC 2)

Hydrograph



## New Conditions

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 10-yr Rainfall=5.12"

Printed 9/25/2024

Page 46

Time span=0.00-96.00 hrs, dt=0.01 hrs, 9601 points  
Runoff by SCS TR-20 method, UH=SCS, Weighted-CN  
Reach routing by Stor-Ind+Trans method - Pond routing by Stor-Ind method

<b>Subcatchment1: Subcat 1</b>	Runoff Area=121,732 sf 0.00% Impervious Runoff Depth=0.34" Flow Length=1,013' Tc=23.3 min CN=42 Runoff=0.22 cfs 3,489 cf
<b>Subcatchment2: Subcat 2</b>	Runoff Area=150,383 sf 12.20% Impervious Runoff Depth=1.44" Flow Length=296' Tc=17.5 min UI Adjusted CN=61 Runoff=3.69 cfs 18,068 cf
<b>Subcatchment3: Subcat 3</b>	Runoff Area=542,887 sf 2.45% Impervious Runoff Depth=0.63" Flow Length=936' Tc=44.3 min UI Adjusted CN=48 Runoff=2.43 cfs 28,622 cf
<b>Subcatchment4: Subcat 4</b>	Runoff Area=480,934 sf 13.66% Impervious Runoff Depth=3.19" Flow Length=633' Tc=36.3 min UI Adjusted CN=82 Runoff=19.76 cfs 127,713 cf
<b>Subcatchment5: Subcat 5</b>	Runoff Area=625,838 sf 0.00% Impervious Runoff Depth=2.81" Flow Length=1,037' Tc=40.7 min CN=78 Runoff=21.38 cfs 146,752 cf
<b>Subcatchment6: Subcat 6</b>	Runoff Area=405,402 sf 16.44% Impervious Runoff Depth=2.72" Flow Length=280' Tc=29.1 min UI Adjusted CN=77 Runoff=15.99 cfs 92,016 cf
<b>Subcatchment7: Subcat 7</b>	Runoff Area=351,134 sf 0.00% Impervious Runoff Depth=0.63" Flow Length=815' Tc=28.4 min CN=48 Runoff=1.92 cfs 18,512 cf
<b>Subcatchment8: Subcat 8</b>	Runoff Area=109,129 sf 0.00% Impervious Runoff Depth=0.39" Flow Length=261' Slope=0.0150 '/' Tc=18.5 min CN=43 Runoff=0.25 cfs 3,525 cf
<b>Subcatchment9: Subcat 9</b>	Runoff Area=209,524 sf 2.74% Impervious Runoff Depth=0.48" Flow Length=651' Tc=22.1 min UI Adjusted CN=45 Runoff=0.73 cfs 8,390 cf
<b>Subcatchment10: Subcat 10</b>	Runoff Area=48,549 sf 0.00% Impervious Runoff Depth=0.43" Flow Length=335' Tc=16.8 min CN=44 Runoff=0.15 cfs 1,753 cf
<b>Subcatchment11: Subcat 11</b>	Runoff Area=237,799 sf 0.00% Impervious Runoff Depth=0.01" Flow Length=138' Tc=17.2 min CN=30 Runoff=0.01 cfs 171 cf
<b>Pond 12P: Water Quality Basin #4</b>	Peak Elev=26.19' Storage=77,285 cf Inflow=19.76 cfs 127,713 cf Discarded=0.67 cfs 70,180 cf Primary=1.28 cfs 57,533 cf Outflow=1.95 cfs 127,713 cf
<b>Pond 13P: Water Quality Basin #1</b>	Peak Elev=14.39' Storage=3,714 cf Inflow=0.73 cfs 8,390 cf Discarded=0.11 cfs 8,390 cf Primary=0.00 cfs 0 cf Outflow=0.11 cfs 8,390 cf
<b>Pond 18P: Water Quality Basin #5</b>	Peak Elev=20.56' Storage=1,061 cf Inflow=0.25 cfs 3,525 cf Discarded=0.02 cfs 1,877 cf Primary=0.07 cfs 1,649 cf Outflow=0.10 cfs 3,525 cf
<b>Pond 20P: Water Quality Basin #3.1</b>	Peak Elev=21.59' Storage=58,623 cf Inflow=15.99 cfs 92,016 cf Discarded=0.51 cfs 49,763 cf Primary=0.46 cfs 42,253 cf Outflow=0.97 cfs 92,016 cf
<b>Pond 21P: Water Quality Basin #2</b>	Peak Elev=22.94' Storage=10,669 cf Inflow=2.43 cfs 28,622 cf Discarded=0.14 cfs 12,579 cf Primary=0.51 cfs 16,042 cf Outflow=0.65 cfs 28,622 cf

**New Conditions**

NOAA 24-hr D 10-yr Rainfall=5.12"

Prepared by Loureiro Engineering Assoc, Inc

Printed 9/25/2024

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

Page 47

**Pond 22P: Water Quality Basin #3.2** Peak Elev=36.51' Storage=7,315 cf Inflow=3.69 cfs 18,068 cf  
Discarded=0.09 cfs 8,018 cf Primary=0.59 cfs 10,050 cf Outflow=0.69 cfs 18,068 cf

**Link 2L: Northeast Wetland** Inflow=0.22 cfs 3,660 cf  
Primary=0.22 cfs 3,660 cf

**Link 3L: South Off-Site (POC 3)** Inflow=21.38 cfs 146,752 cf  
Primary=21.38 cfs 146,752 cf

**Link 4L: West Wetlands (POC 1)** Inflow=2.88 cfs 132,939 cf  
Primary=2.88 cfs 132,939 cf

**Link 5L: West Off-Site (POC 2)** Inflow=1.92 cfs 18,512 cf  
Primary=1.92 cfs 18,512 cf

**Total Runoff Area = 3,283,311 sf Runoff Volume = 449,010 cf Average Runoff Depth = 1.64"**  
**94.83% Pervious = 3,113,537 sf 5.17% Impervious = 169,774 sf**

**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 10-yr Rainfall=5.12"

Printed 9/25/2024

Page 48

**Summary for Subcatchment 1: Subcat 1**

Runoff = 0.22 cfs @ 12.71 hrs, Volume= 3,489 cf, Depth= 0.34"  
 Routed to Link 2L : Northeast Wetland

Runoff by SCS TR-20 method, UH=SCS, Weighted-CN, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 NOAA 24-hr D 10-yr Rainfall=5.12"

Area (sf)	CN	Description
700	48	Brush, Good, HSG B
14,806	55	Woods, Good, HSG B
1,211	55	Woods, Good, HSG B
24	39	>75% Grass cover, Good, HSG A
1,022	72	Dirt roads, HSG A
9,987	30	Brush, Good, HSG A
13,422	30	Woods, Good, HSG A
21,799	77	Woods, Good, HSG D
58,761	30	Woods, Good, HSG A
121,732	42	Weighted Average
121,732	42	100.00% Pervious Area

Tc (min)	Length (feet)	Slope (ft/ft)	Velocity (ft/sec)	Capacity (cfs)	Description
13.3	100	0.2400	0.13		<b>Sheet Flow,</b> Woods: Dense underbrush n= 0.800 P2= 3.46"
10.0	913	0.0920	1.52		<b>Shallow Concentrated Flow,</b> Woodland Kv= 5.0 fps
23.3	1,013	Total			

**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC


NOAA 24-hr D 10-yr Rainfall=5.12"

Printed 9/25/2024

Page 49

**Subcatchment 1: Subcat 1**

Hydrograph



**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 10-yr Rainfall=5.12"

Printed 9/25/2024

Page 50

**Summary for Subcatchment 2: Subcat 2**

Runoff = 3.69 cfs @ 12.27 hrs, Volume= 18,068 cf, Depth= 1.44"

Routed to Pond 22P : Water Quality Basin #3.2

Runoff by SCS TR-20 method, UH=SCS, Weighted-CN, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 NOAA 24-hr D 10-yr Rainfall=5.12"

Area (sf)	CN	Adj	Description
72,676	39		>75% Grass cover, Good, HSG A
18,352	98		Unconnected pavement, HSG A
995	96		Gravel surface, HSG A
6	30		Woods, Good, HSG A
4,992	77		Woods, Good, HSG D
35,625	86		Woods/grass comb., Poor, HSG D
17,737	80		>75% Grass cover, Good, HSG D
150,383	64	61	Weighted Average, UI Adjusted
132,031	59	59	87.80% Pervious Area
18,352	98	98	12.20% Impervious Area
18,352			100.00% Unconnected

Tc (min)	Length (feet)	Slope (ft/ft)	Velocity (ft/sec)	Capacity (cfs)	Description
14.6	62	0.0730	0.07		<b>Sheet Flow, sheet</b> Woods: Dense underbrush n= 0.800 P2= 3.46"
2.0					<b>Direct Entry, rock crossing</b>
0.9	234	0.0100	4.26	17.02	<b>Channel Flow, swale</b> Area= 4.0 sf Perim= 8.0' r= 0.50' n= 0.022 Earth, clean & straight
17.5	296	Total			



**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC


NOAA 24-hr D 10-yr Rainfall=5.12"

Printed 9/25/2024

Page 51

**Subcatchment 2: Subcat 2**

Hydrograph



**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 10-yr Rainfall=5.12"

Printed 9/25/2024

Page 52

**Summary for Subcatchment 3: Subcat 3**

Runoff = 2.43 cfs @ 12.80 hrs, Volume= 28,622 cf, Depth= 0.63"

Routed to Pond 21P : Water Quality Basin #2

Runoff by SCS TR-20 method, UH=SCS, Weighted-CN, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 NOAA 24-hr D 10-yr Rainfall=5.12"

Area (sf)	CN	Adj	Description
185,176	39		>75% Grass cover, Good, HSG A
238,754	39		>75% Grass cover, Good, HSG A
15,049	96		Gravel surface, HSG A
13,325	98		Unconnected pavement, HSG D
55,139	80		>75% Grass cover, Good, HSG D
9,578	77		Woods, Good, HSG D
25,866	86		Woods/grass comb., Poor, HSG D
542,887	49	48	Weighted Average, UI Adjusted
529,562	48	48	97.55% Pervious Area
13,325	98	98	2.45% Impervious Area
13,325			100.00% Unconnected

Tc (min)	Length (feet)	Slope (ft/ft)	Velocity (ft/sec)	Capacity (cfs)	Description
2.0					<b>Direct Entry,</b>
28.7	100	0.0350	0.06		<b>Sheet Flow, sheet</b>
					Woods: Dense underbrush n= 0.800 P2= 3.46"
2.1	246	0.0813	2.00		<b>Shallow Concentrated Flow, scf</b>
					Short Grass Pasture Kv= 7.0 fps
11.5	590	0.0150	0.86		<b>Shallow Concentrated Flow, scf grass</b>
					Short Grass Pasture Kv= 7.0 fps
44.3	936	Total			

**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC


NOAA 24-hr D 10-yr Rainfall=5.12"

Printed 9/25/2024

Page 53

**Subcatchment 3: Subcat 3**

Hydrograph



**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 10-yr Rainfall=5.12"

Printed 9/25/2024

Page 54

**Summary for Subcatchment 4: Subcat 4**

Runoff = 19.76 cfs @ 12.50 hrs, Volume= 127,713 cf, Depth= 3.19"

Routed to Pond 12P : Water Quality Basin #4

Runoff by SCS TR-20 method, UH=SCS, Weighted-CN, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 NOAA 24-hr D 10-yr Rainfall=5.12"

Area (sf)	CN	Adj	Description
414	96		Gravel surface, HSG A
9,603	39		>75% Grass cover, Good, HSG A
0	77		Woods, Good, HSG D
0	77		Woods, Good, HSG D
2	77		Woods, Good, HSG D
5,250	77		Woods, Good, HSG D
0	77		Woods, Good, HSG D
23,224	77		Woods, Good, HSG D
249,238	80		>75% Grass cover, Good, HSG D
65,690	98		Unconnected pavement, HSG D
127,513	86		Woods/grass comb., Poor, HSG D
480,934	83	82	Weighted Average, UI Adjusted
415,244	81	81	86.34% Pervious Area
65,690	98	98	13.66% Impervious Area
65,690			100.00% Unconnected

Tc (min)	Length (feet)	Slope (ft/ft)	Velocity (ft/sec)	Capacity (cfs)	Description
30.6	100	0.0300	0.05		<b>Sheet Flow, sheet</b> Woods: Dense underbrush n= 0.800 P2= 3.46"
0.7	50	0.1988	1.11		<b>Shallow Concentrated Flow, scf</b> Forest w/Heavy Litter Kv= 2.5 fps
2.0					<b>Direct Entry, rock crossing</b>
3.0	483	0.1500	2.71		<b>Shallow Concentrated Flow, scf grass</b> Short Grass Pasture Kv= 7.0 fps
36.3	633	Total			

**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC


NOAA 24-hr D 10-yr Rainfall=5.12"

Printed 9/25/2024

Page 55

**Subcatchment 4: Subcat 4**

Hydrograph



**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc  
 HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 10-yr Rainfall=5.12"

Printed 9/25/2024

Page 56

**Summary for Subcatchment 5: Subcat 5**

Runoff = 21.38 cfs @ 12.57 hrs, Volume= 146,752 cf, Depth= 2.81"  
 Routed to Link 3L : South Off-Site (POC 3)

Runoff by SCS TR-20 method, UH=SCS, Weighted-CN, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 NOAA 24-hr D 10-yr Rainfall=5.12"

Area (sf)	CN	Description
0	98	Unconnected pavement, HSG D
14,987	73	Brush, Good, HSG D
1,504	91	Gravel roads, HSG D
39,327	91	Gravel roads, HSG D
18,528	91	Gravel roads, HSG D
2,922	89	Dirt roads, HSG D
2,214	73	Brush, Good, HSG D
7,635	77	Woods, Good, HSG D
137,134	77	Woods, Good, HSG D
10,652	77	Woods, Good, HSG D
291,847	77	Woods, Good, HSG D
34,529	77	Woods, Good, HSG D
23,786	77	Woods, Good, HSG D
1,988	73	Brush, Good, HSG D
357	91	Gravel roads, HSG D
38,427	73	Brush, Good, HSG D
625,838	78	Weighted Average
625,838	78	100.00% Pervious Area
0	98	0.00% Impervious Area
0		100.00% Unconnected

Tc (min)	Length (feet)	Slope (ft/ft)	Velocity (ft/sec)	Capacity (cfs)	Description
26.0	100	0.0450	0.06		<b>Sheet Flow, sheet</b> Woods: Dense underbrush n= 0.800 P2= 3.46"
6.1	225	0.0600	0.61		<b>Shallow Concentrated Flow, scf woods</b> Forest w/Heavy Litter Kv= 2.5 fps
0.7	112	0.1560	2.76		<b>Shallow Concentrated Flow, scfbrush</b> Short Grass Pasture Kv= 7.0 fps
0.5	140	0.0820	4.61		<b>Shallow Concentrated Flow, scf unpaved</b> Unpaved Kv= 16.1 fps
7.4	460	0.1740	1.04		<b>Shallow Concentrated Flow, scf woods</b> Forest w/Heavy Litter Kv= 2.5 fps
40.7	1,037	Total			

**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC


NOAA 24-hr D 10-yr Rainfall=5.12"

Printed 9/25/2024

Page 57

**Subcatchment 5: Subcat 5**

Hydrograph



**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc  
 HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 10-yr Rainfall=5.12"

Printed 9/25/2024

Page 58

**Summary for Subcatchment 6: Subcat 6**

Runoff = 15.99 cfs @ 12.41 hrs, Volume= 92,016 cf, Depth= 2.72"  
 Routed to Pond 20P : Water Quality Basin #3.1

Runoff by SCS TR-20 method, UH=SCS, Weighted-CN, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 NOAA 24-hr D 10-yr Rainfall=5.12"

Area (sf)	CN	Adj	Description
1,758	73		Brush, Good, HSG D
66,656	98		Unconnected pavement, HSG D
1,257	77		Woods, Good, HSG D
34,488	77		Woods, Good, HSG D
49,599	39		>75% Grass cover, Good, HSG A
43,447	77		Woods, Good, HSG D
129,391	86		Woods/grass comb., Poor, HSG D
28	73		Brush, Good, HSG D
78,778	80		>75% Grass cover, Good, HSG D
405,402	79	77	Weighted Average, UI Adjusted
338,746	76	76	83.56% Pervious Area
66,656	98	98	16.44% Impervious Area
66,656			100.00% Unconnected

Tc (min)	Length (feet)	Slope (ft/ft)	Velocity (ft/sec)	Capacity (cfs)	Description
24.9	100	0.0500	0.07		<b>Sheet Flow, sheet</b> Woods: Dense underbrush n= 0.800 P2= 3.46"
2.2	180	0.3000	1.37		<b>Shallow Concentrated Flow, scf</b> Forest w/Heavy Litter Kv= 2.5 fps
2.0					<b>Direct Entry, rock crossing</b>
29.1	280	Total			



**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC


NOAA 24-hr D 10-yr Rainfall=5.12"

Printed 9/25/2024

Page 59

**Subcatchment 6: Subcat 6**

Hydrograph



**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 10-yr Rainfall=5.12"

Printed 9/25/2024

Page 60

**Summary for Subcatchment 7: Subcat 7**

Runoff = 1.92 cfs @ 12.53 hrs, Volume= 18,512 cf, Depth= 0.63"

Routed to Link 5L : West Off-Site (POC 2)

Runoff by SCS TR-20 method, UH=SCS, Weighted-CN, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 NOAA 24-hr D 10-yr Rainfall=5.12"

Area (sf)	CN	Description
8,651	91	Gravel roads, HSG D
11,645	73	Brush, Good, HSG D
8,819	73	Brush, Good, HSG D
23	77	Woods, Good, HSG D
338	77	Woods, Good, HSG D
7	77	Woods, Good, HSG D
9,853	76	Gravel roads, HSG A
17,832	30	Brush, Good, HSG A
195,049	30	Woods, Good, HSG A
1,207	30	Woods, Good, HSG A
7,262	77	Woods, Good, HSG D
47,566	77	Woods, Good, HSG D
39,066	73	Brush, Good, HSG D
1	91	Gravel roads, HSG D
3,817	91	Gravel roads, HSG D
351,134	48	Weighted Average
351,134	48	100.00% Pervious Area

Tc (min)	Length (feet)	Slope (ft/ft)	Velocity (ft/sec)	Capacity (cfs)	Description
18.9	100	0.1000	0.09		<b>Sheet Flow, sheet</b> Woods: Dense underbrush n= 0.800 P2= 3.46"
9.5	715	0.2500	1.25		<b>Shallow Concentrated Flow, scf</b> Forest w/Heavy Litter Kv= 2.5 fps
28.4	815	Total			

**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC


NOAA 24-hr D 10-yr Rainfall=5.12"

Printed 9/25/2024

Page 61

**Subcatchment 7: Subcat 7**

Hydrograph



**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc  
 HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 10-yr Rainfall=5.12"

Printed 9/25/2024

Page 62

**Summary for Subcatchment 8: Subcat 8**

Runoff = 0.25 cfs @ 12.56 hrs, Volume= 3,525 cf, Depth= 0.39"  
 Routed to Pond 18P : Water Quality Basin #5


Runoff by SCS TR-20 method, UH=SCS, Weighted-CN, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 NOAA 24-hr D 10-yr Rainfall=5.12"

Area (sf)	CN	Description
8,265	96	Gravel surface, HSG A
10,542	39	>75% Grass cover, Good, HSG A
90,322	39	>75% Grass cover, Good, HSG A
109,129	43	Weighted Average
109,129	43	100.00% Pervious Area

Tc (min)	Length (feet)	Slope (ft/ft)	Velocity (ft/sec)	Capacity (cfs)	Description
15.4	100	0.0150	0.11		<b>Sheet Flow, sheet</b>
					Grass: Dense n= 0.240 P2= 3.46"
3.1	161	0.0150	0.86		<b>Shallow Concentrated Flow, scf</b>
					Short Grass Pasture Kv= 7.0 fps
18.5	261	Total			

**Subcatchment 8: Subcat 8**

Hydrograph



**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 10-yr Rainfall=5.12"

Printed 9/25/2024

Page 63

**Summary for Subcatchment 9: Subcat 9**

Runoff = 0.73 cfs @ 12.49 hrs, Volume= 8,390 cf, Depth= 0.48"

Routed to Pond 13P : Water Quality Basin #1

Runoff by SCS TR-20 method, UH=SCS, Weighted-CN, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 NOAA 24-hr D 10-yr Rainfall=5.12"

Area (sf)	CN	Adj	Description
5,751	98		Unconnected pavement, HSG A
10,904	96		Gravel surface, HSG A
181,704	39		>75% Grass cover, Good, HSG A
11,165	86		Woods/grass comb., Poor, HSG D
209,524	46	45	Weighted Average, UI Adjusted
203,773	45	45	97.26% Pervious Area
5,751	98	98	2.74% Impervious Area
5,751			100.00% Unconnected

Tc (min)	Length (feet)	Slope (ft/ft)	Velocity (ft/sec)	Capacity (cfs)	Description
15.4	100	0.0150	0.11		<b>Sheet Flow, sheet</b> Grass: Dense n= 0.240 P2= 3.46"
5.7	291	0.0150	0.86		<b>Shallow Concentrated Flow, scf</b> Short Grass Pasture Kv= 7.0 fps
1.0	260	0.0100	4.26	17.02	<b>Channel Flow, swale</b> Area= 4.0 sf Perim= 8.0' r= 0.50' n= 0.022 Earth, clean & straight
22.1	651	Total			

**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC


NOAA 24-hr D 10-yr Rainfall=5.12"

Printed 9/25/2024

Page 64

**Subcatchment 9: Subcat 9**

Hydrograph



**New Conditions**

**Summary for Subcatchment 10: Subcat 10**

Runoff = 0.15 cfs @ 12.42 hrs, Volume= 1,753 cf, Depth= 0.43"  
 Routed to Link 4L : West Wetlands (POC 1)


Runoff by SCS TR-20 method, UH=SCS, Weighted-CN, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 NOAA 24-hr D 10-yr Rainfall=5.12"

Area (sf)	CN	Description
15,200	39	>75% Grass cover, Good, HSG A
29,317	39	>75% Grass cover, Good, HSG A
4,025	96	Gravel surface, HSG A
5	30	Woods, Good, HSG A
1	30	Woods, Good, HSG A
2	30	Woods, Good, HSG A
0	30	Woods, Good, HSG A
48,549	44	Weighted Average
48,549	44	100.00% Pervious Area

Tc (min)	Length (feet)	Slope (ft/ft)	Velocity (ft/sec)	Capacity (cfs)	Description
15.4	100	0.0150	0.11		<b>Sheet Flow, sheet</b> Grass: Dense n= 0.240 P2= 3.46"
1.4	235	0.1500	2.71		<b>Shallow Concentrated Flow, scf</b> Short Grass Pasture Kv= 7.0 fps
16.8	335	Total			

**Subcatchment 10: Subcat 10**

Hydrograph



**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc  
 HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 10-yr Rainfall=5.12"

Printed 9/25/2024

Page 66

**Summary for Subcatchment 11: Subcat 11**

Runoff = 0.01 cfs @ 24.02 hrs, Volume= 171 cf, Depth= 0.01"  
 Routed to Link 2L : Northeast Wetland

Runoff by SCS TR-20 method, UH=SCS, Weighted-CN, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 NOAA 24-hr D 10-yr Rainfall=5.12"

Area (sf)	CN	Description
3,394	48	Brush, Good, HSG B
72	39	>75% Grass cover, Good, HSG A
3	96	Gravel surface, HSG A
29	39	>75% Grass cover, Good, HSG A
24	39	>75% Grass cover, Good, HSG A
48,779	30	Brush, Good, HSG A
185,489	30	Woods, Good, HSG A
8	30	Woods, Good, HSG A
237,799	30	Weighted Average
237,799	30	100.00% Pervious Area

Tc (min)	Length (feet)	Slope (ft/ft)	Velocity (ft/sec)	Capacity (cfs)	Description
16.5	100	0.1400	0.10		<b>Sheet Flow, sheet</b> Woods: Dense underbrush n= 0.800 P2= 3.46"
0.7	38	0.1369	0.93		<b>Shallow Concentrated Flow, scf</b> Forest w/Heavy Litter Kv= 2.5 fps
17.2	138	Total			



**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC


NOAA 24-hr D 10-yr Rainfall=5.12"

Printed 9/25/2024

Page 67

**Subcatchment 11: Subcat 11**

Hydrograph



**New Conditions**

NOAA 24-hr D 10-yr Rainfall=5.12"

Prepared by Loureiro Engineering Assoc, Inc

Printed 9/25/2024

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

Page 68

**Summary for Pond 12P: Water Quality Basin #4**

Inflow Area = 480,934 sf, 13.66% Impervious, Inflow Depth = 3.19" for 10-yr event  
 Inflow = 19.76 cfs @ 12.50 hrs, Volume= 127,713 cf  
 Outflow = 1.95 cfs @ 15.06 hrs, Volume= 127,713 cf, Atten= 90%, Lag= 153.9 min  
 Discarded = 0.67 cfs @ 15.06 hrs, Volume= 70,180 cf  
 Primary = 1.28 cfs @ 15.06 hrs, Volume= 57,533 cf  
 Routed to Link 4L : West Wetlands (POC 1)

Routing by Stor-Ind method, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 Peak Elev= 26.19' @ 15.06 hrs Surf.Area= 19,346 sf Storage= 77,285 cf

Plug-Flow detention time= 781.9 min calculated for 127,713 cf (100% of inflow)  
 Center-of-Mass det. time= 781.9 min ( 1,633.6 - 851.7 )

Volume	Invert	Avail.Storage	Storage Description		
#1	21.00'	115,489 cf	<b>Custom Stage Data (Irregular)</b> Listed below (Recalc)		
Elevation (feet)	Surf.Area (sq-ft)	Perim. (feet)	Inc.Store (cubic-feet)	Cum.Store (cubic-feet)	Wet.Area (sq-ft)
21.00	10,788	488.0	0	0	10,788
22.00	12,288	512.0	11,530	11,530	12,762
23.00	13,860	536.0	13,066	24,596	14,831
24.00	15,504	560.0	14,674	39,270	16,995
25.00	17,220	584.0	16,354	55,625	19,253
26.00	19,008	608.0	18,107	73,731	21,607
27.00	20,868	632.0	19,931	93,662	24,055
28.00	22,800	656.0	21,827	115,489	26,598

Device	Routing	Invert	Outlet Devices	
#1	Primary	21.00'	<b>30.0" Round Culvert</b> L= 184.0' Ke= 0.500 Inlet / Outlet Invert= 21.00' / 19.10' S= 0.0103 '/' Cc= 0.900 n= 0.012 Corrugated PP, smooth interior, Flow Area= 4.91 sf	
#2	Device 1	26.50'	<b>48.0" W x 36.0" H Vert. Orifice/Grate X 2.00</b> C= 0.600 Limited to weir flow at low heads	
#3	Discarded	21.00'	<b>0.500 in/hr Exfiltration over Wetted area</b> Conductivity to Groundwater Elevation = 19.00'	
#4	Device 1	21.30'	<b>2.0" Vert. Orifice/Grate</b> C= 0.600 Limited to weir flow at low heads	
#5	Device 1	24.70'	<b>6.0" Vert. Orifice/Grate</b> C= 0.600 Limited to weir flow at low heads	

**Discarded OutFlow** Max=0.67 cfs @ 15.06 hrs HW=26.19' (Free Discharge)  
 ↳ **3=Exfiltration** ( Controls 0.67 cfs)

**Primary OutFlow** Max=1.28 cfs @ 15.06 hrs HW=26.19' (Free Discharge)  
 ↳ **1=Culvert** (Passes 1.28 cfs of 46.89 cfs potential flow)  
 ↳ **2=Orifice/Grate** ( Controls 0.00 cfs)  
 ↳ **4=Orifice/Grate** (Orifice Controls 0.23 cfs @ 10.55 fps)  
 ↳ **5=Orifice/Grate** (Orifice Controls 1.05 cfs @ 5.35 fps)

**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC


NOAA 24-hr D 10-yr Rainfall=5.12"

Printed 9/25/2024

Page 69

**Pond 12P: Water Quality Basin #4**

Hydrograph



**New Conditions**

NOAA 24-hr D 10-yr Rainfall=5.12"

Prepared by Loureiro Engineering Assoc, Inc

Printed 9/25/2024

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

Page 70

**Summary for Pond 13P: Water Quality Basin #1**

Inflow Area = 209,524 sf, 2.74% Impervious, Inflow Depth = 0.48" for 10-yr event  
 Inflow = 0.73 cfs @ 12.49 hrs, Volume= 8,390 cf  
 Outflow = 0.11 cfs @ 20.71 hrs, Volume= 8,390 cf, Atten= 84%, Lag= 493.3 min  
 Discarded = 0.11 cfs @ 20.71 hrs, Volume= 8,390 cf  
 Primary = 0.00 cfs @ 0.00 hrs, Volume= 0 cf  
 Routed to Link 4L : West Wetlands (POC 1)

Routing by Stor-Ind method, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 Peak Elev= 14.39' @ 20.71 hrs Surf.Area= 9,766 sf Storage= 3,714 cf

Plug-Flow detention time= 396.0 min calculated for 8,389 cf (100% of inflow)  
 Center-of-Mass det. time= 396.1 min ( 1,373.0 - 976.9 )

Volume	Invert	Avail.Storage	Storage Description			
#1	14.00'	66,060 cf	<b>Custom Stage Data (Irregular)</b> Listed below (Recalc)			
Elevation (feet)	Surf.Area (sq-ft)	Perim. (feet)	Inc.Store (cubic-feet)	Cum.Store (cubic-feet)	Wet.Area (sq-ft)	
14.00	9,180	498.0	0	0	9,180	
15.00	10,710	522.0	9,935	9,935	11,194	
16.00	12,312	546.0	11,502	21,437	13,302	
17.00	13,986	570.0	13,140	34,577	15,505	
18.00	15,732	594.0	14,850	49,427	17,803	
19.00	17,550	618.0	16,633	66,060	20,196	

Device	Routing	Invert	Outlet Devices	
#1	Primary	14.00'	<b>30.0" Round Culvert</b> L= 107.0' Ke= 0.500 Inlet / Outlet Invert= 14.00' / 12.50' S= 0.0140 '/' Cc= 0.900 n= 0.012 Corrugated PP, smooth interior, Flow Area= 4.91 sf	
#2	Device 1	18.00'	<b>48.0" W x 36.0" H Vert. Orifice/Grate X 2.00</b> C= 0.600 Limited to weir flow at low heads	
#3	Discarded	14.00'	<b>0.500 in/hr Exfiltration over Surface area</b>	
#4	Device 1	14.40'	<b>6.0" Vert. Orifice/Grate</b> C= 0.600 Limited to weir flow at low heads	

**Discarded OutFlow** Max=0.11 cfs @ 20.71 hrs HW=14.39' (Free Discharge)  
 ↳ **3=Exfiltration** (Exfiltration Controls 0.11 cfs)

**Primary OutFlow** Max=0.00 cfs @ 0.00 hrs HW=14.00' (Free Discharge)  
 ↳ **1=Culvert** ( Controls 0.00 cfs)  
     ↳ **2=Orifice/Grate** ( Controls 0.00 cfs)  
         ↳ **4=Orifice/Grate** ( Controls 0.00 cfs)

**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC


NOAA 24-hr D 10-yr Rainfall=5.12"

Printed 9/25/2024

Page 71

**Pond 13P: Water Quality Basin #1**

Hydrograph



**New Conditions**

NOAA 24-hr D 10-yr Rainfall=5.12"

Prepared by Loureiro Engineering Assoc, Inc

Printed 9/25/2024

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

Page 72

**Summary for Pond 18P: Water Quality Basin #5**

Inflow Area = 109,129 sf, 0.00% Impervious, Inflow Depth = 0.39" for 10-yr event  
 Inflow = 0.25 cfs @ 12.56 hrs, Volume= 3,525 cf  
 Outflow = 0.10 cfs @ 14.95 hrs, Volume= 3,525 cf, Atten= 61%, Lag= 143.6 min  
 Discarded = 0.02 cfs @ 14.95 hrs, Volume= 1,877 cf  
 Primary = 0.07 cfs @ 14.95 hrs, Volume= 1,649 cf  
 Routed to Link 4L : West Wetlands (POC 1)

Routing by Stor-Ind method, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 Peak Elev= 20.56' @ 14.95 hrs Surf.Area= 2,082 sf Storage= 1,061 cf

Plug-Flow detention time= 268.4 min calculated for 3,525 cf (100% of inflow)  
 Center-of-Mass det. time= 268.4 min ( 1,259.4 - 990.9 )

Volume	Invert	Avail.Storage	Storage Description			
#1	20.00'	18,040 cf	<b>Custom Stage Data (Irregular)</b> Listed below (Recalc)			
Elevation (feet)	Surf.Area (sq-ft)	Perim. (feet)	Inc.Store (cubic-feet)	Cum.Store (cubic-feet)	Wet.Area (sq-ft)	
20.00	1,720	212.0	0	0	1,720	
21.00	2,392	236.0	2,047	2,047	2,604	
22.00	3,136	260.0	2,756	4,802	3,584	
23.00	3,952	284.0	3,536	8,339	4,658	
24.00	4,840	308.0	4,389	12,727	5,826	
25.00	5,800	332.0	5,313	18,040	7,090	

Device	Routing	Invert	Outlet Devices
#1	Primary	20.00'	<b>18.0" Round Culvert</b> L= 25.0' Ke= 0.500 Inlet / Outlet Invert= 20.00' / 19.50' S= 0.0200 '/' Cc= 0.900 n= 0.013 Corrugated PE, smooth interior, Flow Area= 1.77 sf
#2	Device 1	24.00'	<b>48.0" W x 36.0" H Vert. Orifice/Grate X 2.00</b> C= 0.600 Limited to weir flow at low heads
#3	Discarded	20.00'	<b>0.500 in/hr Exfiltration over Surface area</b>
#4	Device 1	20.40'	<b>6.0" Vert. Orifice/Grate</b> C= 0.600 Limited to weir flow at low heads

**Discarded OutFlow** Max=0.02 cfs @ 14.95 hrs HW=20.56' (Free Discharge)  
 ↑ **3=Exfiltration** (Exfiltration Controls 0.02 cfs)

**Primary OutFlow** Max=0.07 cfs @ 14.95 hrs HW=20.56' (Free Discharge)  
 ↑ **1=Culvert** (Passes 0.07 cfs of 1.53 cfs potential flow)  
 ↑ **2=Orifice/Grate** ( Controls 0.00 cfs)  
 ↑ **4=Orifice/Grate** (Orifice Controls 0.07 cfs @ 1.36 fps)

**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC


NOAA 24-hr D 10-yr Rainfall=5.12"

Printed 9/25/2024

Page 73

**Pond 18P: Water Quality Basin #5**

Hydrograph



**New Conditions**

NOAA 24-hr D 10-yr Rainfall=5.12"

Prepared by Loureiro Engineering Assoc, Inc

Printed 9/25/2024

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

Page 74

**Summary for Pond 20P: Water Quality Basin #3.1**

Inflow Area = 405,402 sf, 16.44% Impervious, Inflow Depth = 2.72" for 10-yr event  
 Inflow = 15.99 cfs @ 12.41 hrs, Volume= 92,016 cf  
 Outflow = 0.97 cfs @ 16.87 hrs, Volume= 92,016 cf, Atten= 94%, Lag= 267.5 min  
 Discarded = 0.51 cfs @ 16.87 hrs, Volume= 49,763 cf  
 Primary = 0.46 cfs @ 16.87 hrs, Volume= 42,253 cf  
 Routed to Link 4L : West Wetlands (POC 1)

Routing by Stor-Ind method, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 Peak Elev= 21.59' @ 16.87 hrs Surf.Area= 15,008 sf Storage= 58,623 cf

Plug-Flow detention time= 816.7 min calculated for 92,016 cf (100% of inflow)  
 Center-of-Mass det. time= 816.6 min ( 1,676.4 - 859.8 )

Volume	Invert	Avail.Storage	Storage Description		
#1	16.00'	81,518 cf	<b>Custom Stage Data (Irregular)</b> Listed below (Recalc)		
Elevation (feet)	Surf.Area (sq-ft)	Perim. (feet)	Inc.Store (cubic-feet)	Cum.Store (cubic-feet)	Wet.Area (sq-ft)
16.00	6,336	450.0	0	0	6,336
17.00	7,722	474.0	7,018	7,018	8,160
18.00	9,180	498.0	8,440	15,458	10,079
19.00	10,710	522.0	9,935	25,393	12,093
20.00	12,312	546.0	11,502	36,895	14,201
21.00	13,986	570.0	13,140	50,035	16,405
22.00	15,732	594.0	14,850	64,886	18,703
23.00	17,550	618.0	16,633	81,518	21,095

Device	Routing	Invert	Outlet Devices
#1	Primary	16.00'	<b>30.0" Round Culvert</b> L= 202.0' Ke= 0.500 Inlet / Outlet Invert= 16.00' / 13.80' S= 0.0109 '/' Cc= 0.900 n= 0.013 Corrugated PE, smooth interior, Flow Area= 4.91 sf
#2	Device 1	22.00'	<b>48.0" W x 36.0" H Vert. Orifice/Grate X 2.00</b> C= 0.600 Limited to weir flow at low heads
#3	Discarded	16.00'	<b>0.500 in/hr Exfiltration over Wetted area</b> Conductivity to Groundwater Elevation = 14.00'
#4	Device 1	16.50'	<b>2.0" Vert. Orifice/Grate</b> C= 0.600 Limited to weir flow at low heads
#5	Device 1	17.00'	<b>2.0" Vert. Orifice/Grate</b> C= 0.600 Limited to weir flow at low heads

**Discarded OutFlow** Max=0.51 cfs @ 16.87 hrs HW=21.59' (Free Discharge)  
 ↳ **3=Exfiltration** ( Controls 0.51 cfs)

**Primary OutFlow** Max=0.46 cfs @ 16.87 hrs HW=21.59' (Free Discharge)  
 ↳ **1=Culvert** (Passes 0.46 cfs of 49.25 cfs potential flow)  
 ↳ **2=Orifice/Grate** ( Controls 0.00 cfs)  
 ↳ **4=Orifice/Grate** (Orifice Controls 0.24 cfs @ 10.78 fps)  
 ↳ **5=Orifice/Grate** (Orifice Controls 0.22 cfs @ 10.22 fps)



**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC


NOAA 24-hr D 10-yr Rainfall=5.12"

Printed 9/25/2024

Page 75

**Pond 20P: Water Quality Basin #3.1**

Hydrograph



**New Conditions**

NOAA 24-hr D 10-yr Rainfall=5.12"

Prepared by Loureiro Engineering Assoc, Inc

Printed 9/25/2024

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

Page 76

**Summary for Pond 21P: Water Quality Basin #2**

Inflow Area = 542,887 sf, 2.45% Impervious, Inflow Depth = 0.63" for 10-yr event  
 Inflow = 2.43 cfs @ 12.80 hrs, Volume= 28,622 cf  
 Outflow = 0.65 cfs @ 15.59 hrs, Volume= 28,622 cf, Atten= 73%, Lag= 167.2 min  
 Discarded = 0.14 cfs @ 15.59 hrs, Volume= 12,579 cf  
 Primary = 0.51 cfs @ 15.59 hrs, Volume= 16,042 cf  
 Routed to Link 4L : West Wetlands (POC 1)

Routing by Stor-Ind method, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 Peak Elev= 22.94' @ 15.59 hrs Surf.Area= 12,060 sf Storage= 10,669 cf

Plug-Flow detention time= 323.3 min calculated for 28,619 cf (100% of inflow)  
 Center-of-Mass det. time= 323.5 min ( 1,299.9 - 976.5 )

Volume	Invert	Avail.Storage	Storage Description		
#1	22.00'	74,350 cf	<b>Custom Stage Data (Irregular)</b> Listed below (Recalc)		
Elevation (feet)	Surf.Area (sq-ft)	Perim. (feet)	Inc.Store (cubic-feet)	Cum.Store (cubic-feet)	Wet.Area (sq-ft)
22.00	10,550	552.0	0	0	10,550
23.00	12,152	546.0	11,342	11,342	11,309
24.00	13,826	570.0	12,980	24,322	13,512
25.00	15,572	594.0	14,690	39,012	15,810
26.00	17,930	618.0	16,737	55,749	18,203
27.00	19,280	642.0	18,601	74,350	20,691

Device	Routing	Invert	Outlet Devices
#1	Primary	22.00'	<b>24.0" Round Culvert</b> L= 56.0' Ke= 0.500 Inlet / Outlet Invert= 22.00' / 21.00' S= 0.0179 '/ Cc= 0.900 n= 0.013 Corrugated PE, smooth interior, Flow Area= 3.14 sf
#2	Device 1	26.80'	<b>48.0" W x 36.0" H Vert. Orifice/Grate X 2.00</b> C= 0.600 Limited to weir flow at low heads
#3	Discarded	22.00'	<b>0.500 in/hr Exfiltration over Surface area</b>
#4	Device 1	22.40'	<b>6.0" Vert. Orifice/Grate</b> C= 0.600 Limited to weir flow at low heads

**Discarded OutFlow** Max=0.14 cfs @ 15.59 hrs HW=22.94' (Free Discharge)  
 ↑ **3=Exfiltration** (Exfiltration Controls 0.14 cfs)

**Primary OutFlow** Max=0.51 cfs @ 15.59 hrs HW=22.94' (Free Discharge)  
 ↑ **1=Culvert** (Passes 0.51 cfs of 4.83 cfs potential flow)  
 ↑ **2=Orifice/Grate** ( Controls 0.00 cfs)  
 ↑ **4=Orifice/Grate** (Orifice Controls 0.51 cfs @ 2.61 fps)

**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC


NOAA 24-hr D 10-yr Rainfall=5.12"

Printed 9/25/2024

Page 77

**Pond 21P: Water Quality Basin #2**

Hydrograph



**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 10-yr Rainfall=5.12"

Printed 9/25/2024

Page 78

**Summary for Pond 22P: Water Quality Basin #3.2**

Inflow Area = 150,383 sf, 12.20% Impervious, Inflow Depth = 1.44" for 10-yr event  
 Inflow = 3.69 cfs @ 12.27 hrs, Volume= 18,068 cf  
 Outflow = 0.69 cfs @ 13.42 hrs, Volume= 18,068 cf, Atten= 81%, Lag= 68.8 min  
 Discarded = 0.09 cfs @ 13.42 hrs, Volume= 8,018 cf  
 Primary = 0.59 cfs @ 13.42 hrs, Volume= 10,050 cf  
 Routed to Link 4L : West Wetlands (POC 1)

Routing by Stor-Ind method, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 Peak Elev= 36.51' @ 13.42 hrs Surf.Area= 3,957 sf Storage= 7,315 cf  
 Flood Elev= 39.00' Surf.Area= 6,400 sf Storage= 20,137 cf

Plug-Flow detention time= 415.2 min calculated for 18,066 cf (100% of inflow)  
 Center-of-Mass det. time= 415.4 min ( 1,310.6 - 895.2 )

Volume	Invert	Avail.Storage	Storage Description		
#1	34.00'	20,137 cf	<b>Custom Stage Data (Irregular)</b> Listed below (Recalc)		
Elevation (feet)	Surf.Area (sq-ft)	Perim. (feet)	Inc.Store (cubic-feet)	Cum.Store (cubic-feet)	Wet.Area (sq-ft)
34.00	1,960	236.0	0	0	1,960
35.00	2,704	260.0	2,322	2,322	2,939
36.00	3,520	284.0	3,103	5,425	4,013
37.00	4,408	308.0	3,956	9,381	5,182
38.00	5,368	332.0	4,880	14,261	6,445
39.00	6,400	356.0	5,876	20,137	7,804

Device	Routing	Invert	Outlet Devices	
#1	Primary	34.00'	<b>24.0" Round Culvert</b> L= 838.0' Ke= 0.500 Inlet / Outlet Invert= 34.00' / 22.00' S= 0.0143 '/ Cc= 0.900 n= 0.013 Corrugated PE, smooth interior, Flow Area= 3.14 sf	
#2	Device 1	38.50'	<b>48.0" W x 36.0" H Vert. Orifice/Grate X 2.00</b> C= 0.600 Limited to weir flow at low heads	
#3	Discarded	34.00'	<b>0.500 in/hr Exfiltration over Wetted area</b> Conductivity to Groundwater Elevation = 32.00'	
#4	Device 1	35.25'	<b>2.0" Vert. Orifice/Grate</b> C= 0.600 Limited to weir flow at low heads	
#5	Device 1	36.00'	<b>6.0" Vert. Orifice/Grate</b> C= 0.600 Limited to weir flow at low heads	

**Discarded OutFlow** Max=0.09 cfs @ 13.42 hrs HW=36.51' (Free Discharge)  
 ↑ **3=Exfiltration** ( Controls 0.09 cfs)

**Primary OutFlow** Max=0.59 cfs @ 13.42 hrs HW=36.51' (Free Discharge)  
 ↑ **1=Culvert** (Passes 0.59 cfs of 18.56 cfs potential flow)  
 ↑ **2=Orifice/Grate** ( Controls 0.00 cfs)  
 ↑ **4=Orifice/Grate** (Orifice Controls 0.11 cfs @ 5.21 fps)  
 ↑ **5=Orifice/Grate** (Orifice Controls 0.48 cfs @ 2.44 fps)

**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC


NOAA 24-hr D 10-yr Rainfall=5.12"

Printed 9/25/2024

Page 79

**Pond 22P: Water Quality Basin #3.2**

Hydrograph



# New Conditions

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 10-yr Rainfall=5.12"

Printed 9/25/2024

Page 80


## Summary for Link 2L: Northeast Wetland

Inflow Area = 359,530 sf, 0.00% Impervious, Inflow Depth = 0.12" for 10-yr event  
Inflow = 0.22 cfs @ 12.71 hrs, Volume= 3,660 cf  
Primary = 0.22 cfs @ 12.71 hrs, Volume= 3,660 cf, Atten= 0%, Lag= 0.0 min  
Routed to Link 4L : West Wetlands (POC 1)

Primary outflow = Inflow, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs

## Link 2L: Northeast Wetland

Hydrograph



**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 10-yr Rainfall=5.12"

Printed 9/25/2024

Page 81


**Summary for Link 3L: South Off-Site (POC 3)**

Inflow Area = 625,838 sf, 0.00% Impervious, Inflow Depth = 2.81" for 10-yr event  
Inflow = 21.38 cfs @ 12.57 hrs, Volume= 146,752 cf  
Primary = 21.38 cfs @ 12.57 hrs, Volume= 146,752 cf, Atten= 0%, Lag= 0.0 min

Primary outflow = Inflow, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs

**Link 3L: South Off-Site (POC 3)**

Hydrograph



**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 10-yr Rainfall=5.12"

Printed 9/25/2024

Page 82


**Summary for Link 4L: West Wetlands (POC 1)**

Inflow Area = 2,306,339 sf, 7.36% Impervious, Inflow Depth = 0.69" for 10-yr event  
Inflow = 2.88 cfs @ 14.37 hrs, Volume= 132,939 cf  
Primary = 2.88 cfs @ 14.37 hrs, Volume= 132,939 cf, Atten= 0%, Lag= 0.0 min

Primary outflow = Inflow, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs

**Link 4L: West Wetlands (POC 1)**

Hydrograph





**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 10-yr Rainfall=5.12"

Printed 9/25/2024

Page 83


**Summary for Link 5L: West Off-Site (POC 2)**

Inflow Area = 351,134 sf, 0.00% Impervious, Inflow Depth = 0.63" for 10-yr event  
Inflow = 1.92 cfs @ 12.53 hrs, Volume= 18,512 cf  
Primary = 1.92 cfs @ 12.53 hrs, Volume= 18,512 cf, Atten= 0%, Lag= 0.0 min

Primary outflow = Inflow, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs

**Link 5L: West Off-Site (POC 2)**

Hydrograph



## New Conditions

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 25-yr Rainfall=6.15"

Printed 9/25/2024

Page 84

Time span=0.00-96.00 hrs, dt=0.01 hrs, 9601 points  
Runoff by SCS TR-20 method, UH=SCS, Weighted-CN  
Reach routing by Stor-Ind+Trans method - Pond routing by Stor-Ind method

<b>Subcatchment1: Subcat 1</b>	Runoff Area=121,732 sf 0.00% Impervious Runoff Depth=0.67" Flow Length=1,013' Tc=23.3 min CN=42 Runoff=0.68 cfs 6,771 cf
<b>Subcatchment2: Subcat 2</b>	Runoff Area=150,383 sf 12.20% Impervious Runoff Depth=2.11" Flow Length=296' Tc=17.5 min UI Adjusted CN=61 Runoff=5.63 cfs 26,399 cf
<b>Subcatchment3: Subcat 3</b>	Runoff Area=542,887 sf 2.45% Impervious Runoff Depth=1.07" Flow Length=936' Tc=44.3 min UI Adjusted CN=48 Runoff=5.07 cfs 48,447 cf
<b>Subcatchment4: Subcat 4</b>	Runoff Area=480,934 sf 13.66% Impervious Runoff Depth=4.13" Flow Length=633' Tc=36.3 min UI Adjusted CN=82 Runoff=25.45 cfs 165,334 cf
<b>Subcatchment5: Subcat 5</b>	Runoff Area=625,838 sf 0.00% Impervious Runoff Depth=3.71" Flow Length=1,037' Tc=40.7 min CN=78 Runoff=28.19 cfs 193,578 cf
<b>Subcatchment6: Subcat 6</b>	Runoff Area=405,402 sf 16.44% Impervious Runoff Depth=3.61" Flow Length=280' Tc=29.1 min UI Adjusted CN=77 Runoff=21.21 cfs 121,972 cf
<b>Subcatchment7: Subcat 7</b>	Runoff Area=351,134 sf 0.00% Impervious Runoff Depth=1.07" Flow Length=815' Tc=28.4 min CN=48 Runoff=4.14 cfs 31,335 cf
<b>Subcatchment8: Subcat 8</b>	Runoff Area=109,129 sf 0.00% Impervious Runoff Depth=0.73" Flow Length=261' Slope=0.0150 '/' Tc=18.5 min CN=43 Runoff=0.80 cfs 6,645 cf
<b>Subcatchment9: Subcat 9</b>	Runoff Area=209,524 sf 2.74% Impervious Runoff Depth=0.86" Flow Length=651' Tc=22.1 min UI Adjusted CN=45 Runoff=1.94 cfs 15,052 cf
<b>Subcatchment10: Subcat 10</b>	Runoff Area=48,549 sf 0.00% Impervious Runoff Depth=0.80" Flow Length=335' Tc=16.8 min CN=44 Runoff=0.44 cfs 3,219 cf
<b>Subcatchment11: Subcat 11</b>	Runoff Area=237,799 sf 0.00% Impervious Runoff Depth=0.09" Flow Length=138' Tc=17.2 min CN=30 Runoff=0.05 cfs 1,757 cf
<b>Pond 12P: Water Quality Basin #4</b>	Peak Elev=26.79' Storage=89,391 cf Inflow=25.45 cfs 165,334 cf Discarded=0.75 cfs 75,822 cf Primary=5.63 cfs 89,512 cf Outflow=6.37 cfs 165,334 cf
<b>Pond 13P: Water Quality Basin #1</b>	Peak Elev=14.66' Storage=6,416 cf Inflow=1.94 cfs 15,052 cf Discarded=0.12 cfs 10,024 cf Primary=0.18 cfs 5,028 cf Outflow=0.30 cfs 15,052 cf
<b>Pond 18P: Water Quality Basin #5</b>	Peak Elev=20.75' Storage=1,478 cf Inflow=0.80 cfs 6,645 cf Discarded=0.03 cfs 1,953 cf Primary=0.30 cfs 4,692 cf Outflow=0.33 cfs 6,645 cf
<b>Pond 20P: Water Quality Basin #3.1</b>	Peak Elev=22.22' Storage=68,378 cf Inflow=21.21 cfs 121,972 cf Discarded=0.57 cfs 57,208 cf Primary=3.14 cfs 64,764 cf Outflow=3.71 cfs 121,972 cf
<b>Pond 21P: Water Quality Basin #2</b>	Peak Elev=23.62' Storage=19,229 cf Inflow=5.07 cfs 48,447 cf Discarded=0.15 cfs 13,807 cf Primary=0.93 cfs 34,641 cf Outflow=1.08 cfs 48,447 cf

**New Conditions**

NOAA 24-hr D 25-yr Rainfall=6.15"

Prepared by Loureiro Engineering Assoc, Inc

Printed 9/25/2024

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

Page 85

**Pond 22P: Water Quality Basin #3.2** Peak Elev=37.17' Storage=10,158 cf Inflow=5.63 cfs 26,399 cf  
Discarded=0.12 cfs 8,595 cf Primary=1.05 cfs 17,804 cf Outflow=1.17 cfs 26,399 cf

**Link 2L: Northeast Wetland** Inflow=0.68 cfs 8,528 cf  
Primary=0.68 cfs 8,528 cf

**Link 3L: South Off-Site (POC 3)** Inflow=28.19 cfs 193,578 cf  
Primary=28.19 cfs 193,578 cf

**Link 4L: West Wetlands (POC 1)** Inflow=11.26 cfs 228,187 cf  
Primary=11.26 cfs 228,187 cf

**Link 5L: West Off-Site (POC 2)** Inflow=4.14 cfs 31,335 cf  
Primary=4.14 cfs 31,335 cf

**Total Runoff Area = 3,283,311 sf Runoff Volume = 620,510 cf Average Runoff Depth = 2.27"**  
**94.83% Pervious = 3,113,537 sf 5.17% Impervious = 169,774 sf**

**New Conditions**

NOAA 24-hr D 25-yr Rainfall=6.15"

Prepared by Loureiro Engineering Assoc, Inc

Printed 9/25/2024

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

Page 86

**Summary for Subcatchment 1: Subcat 1**

Runoff = 0.68 cfs @ 12.46 hrs, Volume= 6,771 cf, Depth= 0.67"  
 Routed to Link 2L : Northeast Wetland

Runoff by SCS TR-20 method, UH=SCS, Weighted-CN, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 NOAA 24-hr D 25-yr Rainfall=6.15"

Area (sf)	CN	Description
700	48	Brush, Good, HSG B
14,806	55	Woods, Good, HSG B
1,211	55	Woods, Good, HSG B
24	39	>75% Grass cover, Good, HSG A
1,022	72	Dirt roads, HSG A
9,987	30	Brush, Good, HSG A
13,422	30	Woods, Good, HSG A
21,799	77	Woods, Good, HSG D
58,761	30	Woods, Good, HSG A
121,732	42	Weighted Average
121,732	42	100.00% Pervious Area

Tc (min)	Length (feet)	Slope (ft/ft)	Velocity (ft/sec)	Capacity (cfs)	Description
13.3	100	0.2400	0.13		<b>Sheet Flow,</b> Woods: Dense underbrush n= 0.800 P2= 3.46"
10.0	913	0.0920	1.52		<b>Shallow Concentrated Flow,</b> Woodland Kv= 5.0 fps
23.3	1,013	Total			

**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC


NOAA 24-hr D 25-yr Rainfall=6.15"

Printed 9/25/2024

Page 87

**Subcatchment 1: Subcat 1**

Hydrograph



**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 25-yr Rainfall=6.15"

Printed 9/25/2024

Page 88

**Summary for Subcatchment 2: Subcat 2**

Runoff = 5.63 cfs @ 12.27 hrs, Volume= 26,399 cf, Depth= 2.11"

Routed to Pond 22P : Water Quality Basin #3.2

Runoff by SCS TR-20 method, UH=SCS, Weighted-CN, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 NOAA 24-hr D 25-yr Rainfall=6.15"

Area (sf)	CN	Adj	Description
72,676	39		>75% Grass cover, Good, HSG A
18,352	98		Unconnected pavement, HSG A
995	96		Gravel surface, HSG A
6	30		Woods, Good, HSG A
4,992	77		Woods, Good, HSG D
35,625	86		Woods/grass comb., Poor, HSG D
17,737	80		>75% Grass cover, Good, HSG D
150,383	64	61	Weighted Average, UI Adjusted
132,031	59	59	87.80% Pervious Area
18,352	98	98	12.20% Impervious Area
18,352			100.00% Unconnected

Tc (min)	Length (feet)	Slope (ft/ft)	Velocity (ft/sec)	Capacity (cfs)	Description
14.6	62	0.0730	0.07		<b>Sheet Flow, sheet</b> Woods: Dense underbrush n= 0.800 P2= 3.46"
2.0					<b>Direct Entry, rock crossing</b>
0.9	234	0.0100	4.26	17.02	<b>Channel Flow, swale</b> Area= 4.0 sf Perim= 8.0' r= 0.50' n= 0.022 Earth, clean & straight
17.5	296	Total			

**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC


NOAA 24-hr D 25-yr Rainfall=6.15"

Printed 9/25/2024

Page 89

**Subcatchment 2: Subcat 2**

Hydrograph



**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 25-yr Rainfall=6.15"

Printed 9/25/2024

Page 90

**Summary for Subcatchment 3: Subcat 3**

Runoff = 5.07 cfs @ 12.75 hrs, Volume= 48,447 cf, Depth= 1.07"

Routed to Pond 21P : Water Quality Basin #2

Runoff by SCS TR-20 method, UH=SCS, Weighted-CN, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 NOAA 24-hr D 25-yr Rainfall=6.15"

Area (sf)	CN	Adj	Description
185,176	39		>75% Grass cover, Good, HSG A
238,754	39		>75% Grass cover, Good, HSG A
15,049	96		Gravel surface, HSG A
13,325	98		Unconnected pavement, HSG D
55,139	80		>75% Grass cover, Good, HSG D
9,578	77		Woods, Good, HSG D
25,866	86		Woods/grass comb., Poor, HSG D
542,887	49	48	Weighted Average, UI Adjusted
529,562	48	48	97.55% Pervious Area
13,325	98	98	2.45% Impervious Area
13,325			100.00% Unconnected

Tc (min)	Length (feet)	Slope (ft/ft)	Velocity (ft/sec)	Capacity (cfs)	Description
2.0					<b>Direct Entry,</b>
28.7	100	0.0350	0.06		<b>Sheet Flow, sheet</b> Woods: Dense underbrush n= 0.800 P2= 3.46"
2.1	246	0.0813	2.00		<b>Shallow Concentrated Flow, scf</b> Short Grass Pasture Kv= 7.0 fps
11.5	590	0.0150	0.86		<b>Shallow Concentrated Flow, scf grass</b> Short Grass Pasture Kv= 7.0 fps
44.3	936	Total			



**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC


NOAA 24-hr D 25-yr Rainfall=6.15"

Printed 9/25/2024

Page 91

**Subcatchment 3: Subcat 3**

Hydrograph



**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc  
 HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 25-yr Rainfall=6.15"

Printed 9/25/2024

Page 92

**Summary for Subcatchment 4: Subcat 4**

Runoff = 25.45 cfs @ 12.47 hrs, Volume= 165,334 cf, Depth= 4.13"  
 Routed to Pond 12P : Water Quality Basin #4

Runoff by SCS TR-20 method, UH=SCS, Weighted-CN, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 NOAA 24-hr D 25-yr Rainfall=6.15"

Area (sf)	CN	Adj	Description
414	96		Gravel surface, HSG A
9,603	39		>75% Grass cover, Good, HSG A
0	77		Woods, Good, HSG D
0	77		Woods, Good, HSG D
2	77		Woods, Good, HSG D
5,250	77		Woods, Good, HSG D
0	77		Woods, Good, HSG D
23,224	77		Woods, Good, HSG D
249,238	80		>75% Grass cover, Good, HSG D
65,690	98		Unconnected pavement, HSG D
127,513	86		Woods/grass comb., Poor, HSG D
480,934	83	82	Weighted Average, UI Adjusted
415,244	81	81	86.34% Pervious Area
65,690	98	98	13.66% Impervious Area
65,690			100.00% Unconnected

Tc (min)	Length (feet)	Slope (ft/ft)	Velocity (ft/sec)	Capacity (cfs)	Description
30.6	100	0.0300	0.05		<b>Sheet Flow, sheet</b> Woods: Dense underbrush n= 0.800 P2= 3.46"
0.7	50	0.1988	1.11		<b>Shallow Concentrated Flow, scf</b> Forest w/Heavy Litter Kv= 2.5 fps
2.0					<b>Direct Entry, rock crossing</b>
3.0	483	0.1500	2.71		<b>Shallow Concentrated Flow, scf grass</b> Short Grass Pasture Kv= 7.0 fps
36.3	633	Total			

**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC


NOAA 24-hr D 25-yr Rainfall=6.15"

Printed 9/25/2024

Page 93

**Subcatchment 4: Subcat 4**

Hydrograph



**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc  
 HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 25-yr Rainfall=6.15"

Printed 9/25/2024

Page 94

**Summary for Subcatchment 5: Subcat 5**

Runoff = 28.19 cfs @ 12.54 hrs, Volume= 193,578 cf, Depth= 3.71"  
 Routed to Link 3L : South Off-Site (POC 3)

Runoff by SCS TR-20 method, UH=SCS, Weighted-CN, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 NOAA 24-hr D 25-yr Rainfall=6.15"

Area (sf)	CN	Description
0	98	Unconnected pavement, HSG D
14,987	73	Brush, Good, HSG D
1,504	91	Gravel roads, HSG D
39,327	91	Gravel roads, HSG D
18,528	91	Gravel roads, HSG D
2,922	89	Dirt roads, HSG D
2,214	73	Brush, Good, HSG D
7,635	77	Woods, Good, HSG D
137,134	77	Woods, Good, HSG D
10,652	77	Woods, Good, HSG D
291,847	77	Woods, Good, HSG D
34,529	77	Woods, Good, HSG D
23,786	77	Woods, Good, HSG D
1,988	73	Brush, Good, HSG D
357	91	Gravel roads, HSG D
38,427	73	Brush, Good, HSG D
625,838	78	Weighted Average
625,838	78	100.00% Pervious Area
0	98	0.00% Impervious Area
0		100.00% Unconnected

Tc (min)	Length (feet)	Slope (ft/ft)	Velocity (ft/sec)	Capacity (cfs)	Description
26.0	100	0.0450	0.06		<b>Sheet Flow, sheet</b> Woods: Dense underbrush n= 0.800 P2= 3.46"
6.1	225	0.0600	0.61		<b>Shallow Concentrated Flow, scf woods</b> Forest w/Heavy Litter Kv= 2.5 fps
0.7	112	0.1560	2.76		<b>Shallow Concentrated Flow, scfbrush</b> Short Grass Pasture Kv= 7.0 fps
0.5	140	0.0820	4.61		<b>Shallow Concentrated Flow, scf unpaved</b> Unpaved Kv= 16.1 fps
7.4	460	0.1740	1.04		<b>Shallow Concentrated Flow, scf woods</b> Forest w/Heavy Litter Kv= 2.5 fps
40.7	1,037	Total			

**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC


NOAA 24-hr D 25-yr Rainfall=6.15"

Printed 9/25/2024

Page 95

**Subcatchment 5: Subcat 5**

Hydrograph



**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc  
 HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 25-yr Rainfall=6.15"

Printed 9/25/2024

Page 96

**Summary for Subcatchment 6: Subcat 6**

Runoff = 21.21 cfs @ 12.41 hrs, Volume= 121,972 cf, Depth= 3.61"

Routed to Pond 20P : Water Quality Basin #3.1

Runoff by SCS TR-20 method, UH=SCS, Weighted-CN, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 NOAA 24-hr D 25-yr Rainfall=6.15"

Area (sf)	CN	Adj	Description
1,758	73		Brush, Good, HSG D
66,656	98		Unconnected pavement, HSG D
1,257	77		Woods, Good, HSG D
34,488	77		Woods, Good, HSG D
49,599	39		>75% Grass cover, Good, HSG A
43,447	77		Woods, Good, HSG D
129,391	86		Woods/grass comb., Poor, HSG D
28	73		Brush, Good, HSG D
78,778	80		>75% Grass cover, Good, HSG D
405,402	79	77	Weighted Average, UI Adjusted
338,746	76	76	83.56% Pervious Area
66,656	98	98	16.44% Impervious Area
66,656			100.00% Unconnected

Tc (min)	Length (feet)	Slope (ft/ft)	Velocity (ft/sec)	Capacity (cfs)	Description
24.9	100	0.0500	0.07		<b>Sheet Flow, sheet</b> Woods: Dense underbrush n= 0.800 P2= 3.46"
2.2	180	0.3000	1.37		<b>Shallow Concentrated Flow, scf</b> Forest w/Heavy Litter Kv= 2.5 fps
2.0					<b>Direct Entry, rock crossing</b>
29.1	280	Total			

**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC


NOAA 24-hr D 25-yr Rainfall=6.15"

Printed 9/25/2024

Page 97

**Subcatchment 6: Subcat 6**

Hydrograph



**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc  
 HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 25-yr Rainfall=6.15"

Printed 9/25/2024

Page 98

**Summary for Subcatchment 7: Subcat 7**

Runoff = 4.14 cfs @ 12.47 hrs, Volume= 31,335 cf, Depth= 1.07"  
 Routed to Link 5L : West Off-Site (POC 2)

Runoff by SCS TR-20 method, UH=SCS, Weighted-CN, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 NOAA 24-hr D 25-yr Rainfall=6.15"

Area (sf)	CN	Description
8,651	91	Gravel roads, HSG D
11,645	73	Brush, Good, HSG D
8,819	73	Brush, Good, HSG D
23	77	Woods, Good, HSG D
338	77	Woods, Good, HSG D
7	77	Woods, Good, HSG D
9,853	76	Gravel roads, HSG A
17,832	30	Brush, Good, HSG A
195,049	30	Woods, Good, HSG A
1,207	30	Woods, Good, HSG A
7,262	77	Woods, Good, HSG D
47,566	77	Woods, Good, HSG D
39,066	73	Brush, Good, HSG D
1	91	Gravel roads, HSG D
3,817	91	Gravel roads, HSG D
351,134	48	Weighted Average
351,134	48	100.00% Pervious Area

Tc (min)	Length (feet)	Slope (ft/ft)	Velocity (ft/sec)	Capacity (cfs)	Description
18.9	100	0.1000	0.09		<b>Sheet Flow, sheet</b> Woods: Dense underbrush n= 0.800 P2= 3.46"
9.5	715	0.2500	1.25		<b>Shallow Concentrated Flow, scf</b> Forest w/Heavy Litter Kv= 2.5 fps
28.4	815	Total			



**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC


NOAA 24-hr D 25-yr Rainfall=6.15"

Printed 9/25/2024

Page 99

**Subcatchment 7: Subcat 7**

Hydrograph



**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc  
 HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 25-yr Rainfall=6.15"

Printed 9/25/2024

Page 100

**Summary for Subcatchment 8: Subcat 8**

Runoff = 0.80 cfs @ 12.36 hrs, Volume= 6,645 cf, Depth= 0.73"  
 Routed to Pond 18P : Water Quality Basin #5


Runoff by SCS TR-20 method, UH=SCS, Weighted-CN, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 NOAA 24-hr D 25-yr Rainfall=6.15"

Area (sf)	CN	Description
8,265	96	Gravel surface, HSG A
10,542	39	>75% Grass cover, Good, HSG A
90,322	39	>75% Grass cover, Good, HSG A
109,129	43	Weighted Average
109,129	43	100.00% Pervious Area

Tc (min)	Length (feet)	Slope (ft/ft)	Velocity (ft/sec)	Capacity (cfs)	Description
15.4	100	0.0150	0.11		<b>Sheet Flow, sheet</b>
					Grass: Dense n= 0.240 P2= 3.46"
3.1	161	0.0150	0.86		<b>Shallow Concentrated Flow, scf</b>
					Short Grass Pasture Kv= 7.0 fps
18.5	261	Total			

**Subcatchment 8: Subcat 8**

Hydrograph



**New Conditions**

NOAA 24-hr D 25-yr Rainfall=6.15"

Prepared by Loureiro Engineering Assoc, Inc

Printed 9/25/2024

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

Page 101

**Summary for Subcatchment 9: Subcat 9**

Runoff = 1.94 cfs @ 12.40 hrs, Volume= 15,052 cf, Depth= 0.86"

Routed to Pond 13P : Water Quality Basin #1

Runoff by SCS TR-20 method, UH=SCS, Weighted-CN, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 NOAA 24-hr D 25-yr Rainfall=6.15"

Area (sf)	CN	Adj	Description
5,751	98		Unconnected pavement, HSG A
10,904	96		Gravel surface, HSG A
181,704	39		>75% Grass cover, Good, HSG A
11,165	86		Woods/grass comb., Poor, HSG D
209,524	46	45	Weighted Average, UI Adjusted
203,773	45	45	97.26% Pervious Area
5,751	98	98	2.74% Impervious Area
5,751			100.00% Unconnected

Tc (min)	Length (feet)	Slope (ft/ft)	Velocity (ft/sec)	Capacity (cfs)	Description
15.4	100	0.0150	0.11		<b>Sheet Flow, sheet</b> Grass: Dense n= 0.240 P2= 3.46"
5.7	291	0.0150	0.86		<b>Shallow Concentrated Flow, scf</b> Short Grass Pasture Kv= 7.0 fps
1.0	260	0.0100	4.26	17.02	<b>Channel Flow, swale</b> Area= 4.0 sf Perim= 8.0' r= 0.50' n= 0.022 Earth, clean & straight
22.1	651	Total			

**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC


NOAA 24-hr D 25-yr Rainfall=6.15"

Printed 9/25/2024

Page 102

**Subcatchment 9: Subcat 9**

Hydrograph



**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc  
 HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 25-yr Rainfall=6.15"

Printed 9/25/2024

Page 103

**Summary for Subcatchment 10: Subcat 10**

Runoff = 0.44 cfs @ 12.32 hrs, Volume= 3,219 cf, Depth= 0.80"  
 Routed to Link 4L : West Wetlands (POC 1)


Runoff by SCS TR-20 method, UH=SCS, Weighted-CN, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 NOAA 24-hr D 25-yr Rainfall=6.15"

Area (sf)	CN	Description
15,200	39	>75% Grass cover, Good, HSG A
29,317	39	>75% Grass cover, Good, HSG A
4,025	96	Gravel surface, HSG A
5	30	Woods, Good, HSG A
1	30	Woods, Good, HSG A
2	30	Woods, Good, HSG A
0	30	Woods, Good, HSG A
48,549	44	Weighted Average
48,549	44	100.00% Pervious Area

Tc (min)	Length (feet)	Slope (ft/ft)	Velocity (ft/sec)	Capacity (cfs)	Description
15.4	100	0.0150	0.11		<b>Sheet Flow, sheet</b>
					Grass: Dense n= 0.240 P2= 3.46"
1.4	235	0.1500	2.71		<b>Shallow Concentrated Flow, scf</b>
					Short Grass Pasture Kv= 7.0 fps
16.8	335	Total			

**Subcatchment 10: Subcat 10**

Hydrograph



**New Conditions**

NOAA 24-hr D 25-yr Rainfall=6.15"

Prepared by Loureiro Engineering Assoc, Inc

Printed 9/25/2024

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

Page 104

**Summary for Subcatchment 11: Subcat 11**

Runoff = 0.05 cfs @ 16.84 hrs, Volume= 1,757 cf, Depth= 0.09"  
 Routed to Link 2L : Northeast Wetland

Runoff by SCS TR-20 method, UH=SCS, Weighted-CN, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 NOAA 24-hr D 25-yr Rainfall=6.15"

Area (sf)	CN	Description
3,394	48	Brush, Good, HSG B
72	39	>75% Grass cover, Good, HSG A
3	96	Gravel surface, HSG A
29	39	>75% Grass cover, Good, HSG A
24	39	>75% Grass cover, Good, HSG A
48,779	30	Brush, Good, HSG A
185,489	30	Woods, Good, HSG A
8	30	Woods, Good, HSG A
237,799	30	Weighted Average
237,799	30	100.00% Pervious Area

Tc (min)	Length (feet)	Slope (ft/ft)	Velocity (ft/sec)	Capacity (cfs)	Description
16.5	100	0.1400	0.10		<b>Sheet Flow, sheet</b> Woods: Dense underbrush n= 0.800 P2= 3.46"
0.7	38	0.1369	0.93		<b>Shallow Concentrated Flow, scf</b> Forest w/Heavy Litter Kv= 2.5 fps
17.2	138	Total			

**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC


NOAA 24-hr D 25-yr Rainfall=6.15"

Printed 9/25/2024

Page 105

**Subcatchment 11: Subcat 11**

Hydrograph



**New Conditions**

NOAA 24-hr D 25-yr Rainfall=6.15"

Prepared by Loureiro Engineering Assoc, Inc

Printed 9/25/2024

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

Page 106

**Summary for Pond 12P: Water Quality Basin #4**

Inflow Area = 480,934 sf, 13.66% Impervious, Inflow Depth = 4.13" for 25-yr event  
 Inflow = 25.45 cfs @ 12.47 hrs, Volume= 165,334 cf  
 Outflow = 6.37 cfs @ 13.49 hrs, Volume= 165,334 cf, Atten= 75%, Lag= 61.2 min  
 Discarded = 0.75 cfs @ 13.49 hrs, Volume= 75,822 cf  
 Primary = 5.63 cfs @ 13.49 hrs, Volume= 89,512 cf  
 Routed to Link 4L : West Wetlands (POC 1)

Routing by Stor-Ind method, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 Peak Elev= 26.79' @ 13.49 hrs Surf.Area= 20,477 sf Storage= 89,391 cf

Plug-Flow detention time= 673.6 min calculated for 165,334 cf (100% of inflow)  
 Center-of-Mass det. time= 673.5 min ( 1,517.1 - 843.5 )

Volume	Invert	Avail.Storage	Storage Description		
#1	21.00'	115,489 cf	<b>Custom Stage Data (Irregular)</b> Listed below (Recalc)		
Elevation (feet)	Surf.Area (sq-ft)	Perim. (feet)	Inc.Store (cubic-feet)	Cum.Store (cubic-feet)	Wet.Area (sq-ft)
21.00	10,788	488.0	0	0	10,788
22.00	12,288	512.0	11,530	11,530	12,762
23.00	13,860	536.0	13,066	24,596	14,831
24.00	15,504	560.0	14,674	39,270	16,995
25.00	17,220	584.0	16,354	55,625	19,253
26.00	19,008	608.0	18,107	73,731	21,607
27.00	20,868	632.0	19,931	93,662	24,055
28.00	22,800	656.0	21,827	115,489	26,598

Device	Routing	Invert	Outlet Devices	
#1	Primary	21.00'	<b>30.0" Round Culvert</b> L= 184.0' Ke= 0.500 Inlet / Outlet Invert= 21.00' / 19.10' S= 0.0103 '/' Cc= 0.900 n= 0.012 Corrugated PP, smooth interior, Flow Area= 4.91 sf	
#2	Device 1	26.50'	<b>48.0" W x 36.0" H Vert. Orifice/Grate X 2.00</b> C= 0.600 Limited to weir flow at low heads	
#3	Discarded	21.00'	<b>0.500 in/hr Exfiltration over Wetted area</b> Conductivity to Groundwater Elevation = 19.00'	
#4	Device 1	21.30'	<b>2.0" Vert. Orifice/Grate</b> C= 0.600 Limited to weir flow at low heads	
#5	Device 1	24.70'	<b>6.0" Vert. Orifice/Grate</b> C= 0.600 Limited to weir flow at low heads	

**Discarded OutFlow** Max=0.75 cfs @ 13.49 hrs HW=26.79' (Free Discharge)  
 ↳ **3=Exfiltration** ( Controls 0.75 cfs)

**Primary OutFlow** Max=5.61 cfs @ 13.49 hrs HW=26.79' (Free Discharge)  
 ↳ **1=Culvert** (Passes 5.61 cfs of 50.38 cfs potential flow)  
 ↳ **2=Orifice/Grate** (Orifice Controls 4.08 cfs @ 1.74 fps)  
 ↳ **4=Orifice/Grate** (Orifice Controls 0.24 cfs @ 11.20 fps)  
 ↳ **5=Orifice/Grate** (Orifice Controls 1.28 cfs @ 6.54 fps)



**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC


NOAA 24-hr D 25-yr Rainfall=6.15"

Printed 9/25/2024

Page 107

**Pond 12P: Water Quality Basin #4**

Hydrograph



**New Conditions**

NOAA 24-hr D 25-yr Rainfall=6.15"

Prepared by Loureiro Engineering Assoc, Inc

Printed 9/25/2024

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

Page 108

**Summary for Pond 13P: Water Quality Basin #1**

Inflow Area = 209,524 sf, 2.74% Impervious, Inflow Depth = 0.86" for 25-yr event  
 Inflow = 1.94 cfs @ 12.40 hrs, Volume= 15,052 cf  
 Outflow = 0.30 cfs @ 15.60 hrs, Volume= 15,052 cf, Atten= 84%, Lag= 191.8 min  
 Discarded = 0.12 cfs @ 15.60 hrs, Volume= 10,024 cf  
 Primary = 0.18 cfs @ 15.60 hrs, Volume= 5,028 cf  
 Routed to Link 4L : West Wetlands (POC 1)

Routing by Stor-Ind method, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 Peak Elev= 14.66' @ 15.60 hrs Surf.Area= 10,181 sf Storage= 6,416 cf

Plug-Flow detention time= 392.5 min calculated for 15,051 cf (100% of inflow)  
 Center-of-Mass det. time= 392.6 min ( 1,339.4 - 946.8 )

Volume	Invert	Avail.Storage	Storage Description		
#1	14.00'	66,060 cf	<b>Custom Stage Data (Irregular)</b> Listed below (Recalc)		
Elevation (feet)	Surf.Area (sq-ft)	Perim. (feet)	Inc.Store (cubic-feet)	Cum.Store (cubic-feet)	Wet.Area (sq-ft)
14.00	9,180	498.0	0	0	9,180
15.00	10,710	522.0	9,935	9,935	11,194
16.00	12,312	546.0	11,502	21,437	13,302
17.00	13,986	570.0	13,140	34,577	15,505
18.00	15,732	594.0	14,850	49,427	17,803
19.00	17,550	618.0	16,633	66,060	20,196

Device	Routing	Invert	Outlet Devices
#1	Primary	14.00'	<b>30.0" Round Culvert</b> L= 107.0' Ke= 0.500 Inlet / Outlet Invert= 14.00' / 12.50' S= 0.0140 '/' Cc= 0.900 n= 0.012 Corrugated PP, smooth interior, Flow Area= 4.91 sf
#2	Device 1	18.00'	<b>48.0" W x 36.0" H Vert. Orifice/Grate X 2.00</b> C= 0.600 Limited to weir flow at low heads
#3	Discarded	14.00'	<b>0.500 in/hr Exfiltration over Surface area</b>
#4	Device 1	14.40'	<b>6.0" Vert. Orifice/Grate</b> C= 0.600 Limited to weir flow at low heads

**Discarded OutFlow** Max=0.12 cfs @ 15.60 hrs HW=14.66' (Free Discharge)  
 ↳ **3=Exfiltration** (Exfiltration Controls 0.12 cfs)

**Primary OutFlow** Max=0.18 cfs @ 15.60 hrs HW=14.66' (Free Discharge)  
 ↳ **1=Culvert** (Passes 0.18 cfs of 2.89 cfs potential flow)  
 ↳ **2=Orifice/Grate** ( Controls 0.00 cfs)  
 ↳ **4=Orifice/Grate** (Orifice Controls 0.18 cfs @ 1.75 fps)

# New Conditions

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC


NOAA 24-hr D 25-yr Rainfall=6.15"

Printed 9/25/2024

Page 109

## Pond 13P: Water Quality Basin #1

Hydrograph



**New Conditions**

NOAA 24-hr D 25-yr Rainfall=6.15"

Prepared by Loureiro Engineering Assoc, Inc

Printed 9/25/2024

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

Page 110

**Summary for Pond 18P: Water Quality Basin #5**

Inflow Area = 109,129 sf, 0.00% Impervious, Inflow Depth = 0.73" for 25-yr event  
 Inflow = 0.80 cfs @ 12.36 hrs, Volume= 6,645 cf  
 Outflow = 0.33 cfs @ 13.28 hrs, Volume= 6,645 cf, Atten= 59%, Lag= 55.5 min  
 Discarded = 0.03 cfs @ 13.28 hrs, Volume= 1,953 cf  
 Primary = 0.30 cfs @ 13.28 hrs, Volume= 4,692 cf  
 Routed to Link 4L : West Wetlands (POC 1)

Routing by Stor-Ind method, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 Peak Elev= 20.75' @ 13.28 hrs Surf.Area= 2,216 sf Storage= 1,478 cf

Plug-Flow detention time= 166.9 min calculated for 6,644 cf (100% of inflow)  
 Center-of-Mass det. time= 167.0 min ( 1,122.6 - 955.5 )

Volume	Invert	Avail.Storage	Storage Description		
#1	20.00'	18,040 cf	<b>Custom Stage Data (Irregular)</b> Listed below (Recalc)		
Elevation (feet)	Surf.Area (sq-ft)	Perim. (feet)	Inc.Store (cubic-feet)	Cum.Store (cubic-feet)	Wet.Area (sq-ft)
20.00	1,720	212.0	0	0	1,720
21.00	2,392	236.0	2,047	2,047	2,604
22.00	3,136	260.0	2,756	4,802	3,584
23.00	3,952	284.0	3,536	8,339	4,658
24.00	4,840	308.0	4,389	12,727	5,826
25.00	5,800	332.0	5,313	18,040	7,090

Device	Routing	Invert	Outlet Devices
#1	Primary	20.00'	<b>18.0" Round Culvert</b> L= 25.0' Ke= 0.500 Inlet / Outlet Invert= 20.00' / 19.50' S= 0.0200 '/' Cc= 0.900 n= 0.013 Corrugated PE, smooth interior, Flow Area= 1.77 sf
#2	Device 1	24.00'	<b>48.0" W x 36.0" H Vert. Orifice/Grate X 2.00</b> C= 0.600 Limited to weir flow at low heads
#3	Discarded	20.00'	<b>0.500 in/hr Exfiltration over Surface area</b>
#4	Device 1	20.40'	<b>6.0" Vert. Orifice/Grate</b> C= 0.600 Limited to weir flow at low heads

**Discarded OutFlow** Max=0.03 cfs @ 13.28 hrs HW=20.75' (Free Discharge)  
 ↳ **3=Exfiltration** (Exfiltration Controls 0.03 cfs)

**Primary OutFlow** Max=0.30 cfs @ 13.28 hrs HW=20.75' (Free Discharge)  
 ↳ **1=Culvert** (Passes 0.30 cfs of 2.63 cfs potential flow)  
 ↳ ↳ **2=Orifice/Grate** ( Controls 0.00 cfs)  
 ↳ ↳ ↳ **4=Orifice/Grate** (Orifice Controls 0.30 cfs @ 2.02 fps)

**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC


NOAA 24-hr D 25-yr Rainfall=6.15"

Printed 9/25/2024

Page 111

**Pond 18P: Water Quality Basin #5**

Hydrograph



**New Conditions**

NOAA 24-hr D 25-yr Rainfall=6.15"

Prepared by Loureiro Engineering Assoc, Inc

Printed 9/25/2024

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

Page 112

**Summary for Pond 20P: Water Quality Basin #3.1**

Inflow Area = 405,402 sf, 16.44% Impervious, Inflow Depth = 3.61" for 25-yr event  
 Inflow = 21.21 cfs @ 12.41 hrs, Volume= 121,972 cf  
 Outflow = 3.71 cfs @ 13.63 hrs, Volume= 121,972 cf, Atten= 83%, Lag= 73.6 min  
 Discarded = 0.57 cfs @ 13.63 hrs, Volume= 57,208 cf  
 Primary = 3.14 cfs @ 13.63 hrs, Volume= 64,764 cf  
 Routed to Link 4L : West Wetlands (POC 1)

Routing by Stor-Ind method, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 Peak Elev= 22.22' @ 13.63 hrs Surf.Area= 16,122 sf Storage= 68,378 cf

Plug-Flow detention time= 743.3 min calculated for 121,972 cf (100% of inflow)  
 Center-of-Mass det. time= 743.3 min ( 1,594.1 - 850.9 )

Volume	Invert	Avail.Storage	Storage Description			
#1	16.00'	81,518 cf	<b>Custom Stage Data (Irregular)</b> Listed below (Recalc)			
Elevation (feet)	Surf.Area (sq-ft)	Perim. (feet)	Inc.Store (cubic-feet)	Cum.Store (cubic-feet)	Wet.Area (sq-ft)	
16.00	6,336	450.0	0	0	6,336	
17.00	7,722	474.0	7,018	7,018	8,160	
18.00	9,180	498.0	8,440	15,458	10,079	
19.00	10,710	522.0	9,935	25,393	12,093	
20.00	12,312	546.0	11,502	36,895	14,201	
21.00	13,986	570.0	13,140	50,035	16,405	
22.00	15,732	594.0	14,850	64,886	18,703	
23.00	17,550	618.0	16,633	81,518	21,095	

Device	Routing	Invert	Outlet Devices	
#1	Primary	16.00'	<b>30.0" Round Culvert</b> L= 202.0' Ke= 0.500 Inlet / Outlet Invert= 16.00' / 13.80' S= 0.0109 '/' Cc= 0.900 n= 0.013 Corrugated PE, smooth interior, Flow Area= 4.91 sf	
#2	Device 1	22.00'	<b>48.0" W x 36.0" H Vert. Orifice/Grate X 2.00</b> C= 0.600 Limited to weir flow at low heads	
#3	Discarded	16.00'	<b>0.500 in/hr Exfiltration over Wetted area</b> Conductivity to Groundwater Elevation = 14.00'	
#4	Device 1	16.50'	<b>2.0" Vert. Orifice/Grate</b> C= 0.600 Limited to weir flow at low heads	
#5	Device 1	17.00'	<b>2.0" Vert. Orifice/Grate</b> C= 0.600 Limited to weir flow at low heads	

**Discarded OutFlow** Max=0.57 cfs @ 13.63 hrs HW=22.22' (Free Discharge)  
 ↑ **3=Exfiltration** ( Controls 0.57 cfs)

**Primary OutFlow** Max=3.12 cfs @ 13.63 hrs HW=22.22' (Free Discharge)  
 ↑ **1=Culvert** (Passes 3.12 cfs of 52.21 cfs potential flow)  
 ↑ **2=Orifice/Grate** (Orifice Controls 2.64 cfs @ 1.50 fps)  
 ↑ **4=Orifice/Grate** (Orifice Controls 0.25 cfs @ 11.43 fps)  
 ↑ **5=Orifice/Grate** (Orifice Controls 0.24 cfs @ 10.91 fps)

**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC


NOAA 24-hr D 25-yr Rainfall=6.15"

Printed 9/25/2024

Page 113

**Pond 20P: Water Quality Basin #3.1**

Hydrograph



**New Conditions**

NOAA 24-hr D 25-yr Rainfall=6.15"

Prepared by Loureiro Engineering Assoc, Inc

Printed 9/25/2024

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

Page 114

**Summary for Pond 21P: Water Quality Basin #2**

Inflow Area = 542,887 sf, 2.45% Impervious, Inflow Depth = 1.07" for 25-yr event  
 Inflow = 5.07 cfs @ 12.75 hrs, Volume= 48,447 cf  
 Outflow = 1.08 cfs @ 15.36 hrs, Volume= 48,447 cf, Atten= 79%, Lag= 156.7 min  
 Discarded = 0.15 cfs @ 15.36 hrs, Volume= 13,807 cf  
 Primary = 0.93 cfs @ 15.36 hrs, Volume= 34,641 cf  
 Routed to Link 4L : West Wetlands (POC 1)

Routing by Stor-Ind method, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 Peak Elev= 23.62' @ 15.36 hrs Surf.Area= 13,182 sf Storage= 19,229 cf

Plug-Flow detention time= 299.8 min calculated for 48,447 cf (100% of inflow)  
 Center-of-Mass det. time= 299.6 min ( 1,251.7 - 952.1 )

Volume	Invert	Avail.Storage	Storage Description		
#1	22.00'	74,350 cf	<b>Custom Stage Data (Irregular)</b> Listed below (Recalc)		
Elevation (feet)	Surf.Area (sq-ft)	Perim. (feet)	Inc.Store (cubic-feet)	Cum.Store (cubic-feet)	Wet.Area (sq-ft)
22.00	10,550	552.0	0	0	10,550
23.00	12,152	546.0	11,342	11,342	11,309
24.00	13,826	570.0	12,980	24,322	13,512
25.00	15,572	594.0	14,690	39,012	15,810
26.00	17,930	618.0	16,737	55,749	18,203
27.00	19,280	642.0	18,601	74,350	20,691

Device	Routing	Invert	Outlet Devices
#1	Primary	22.00'	<b>24.0" Round Culvert</b> L= 56.0' Ke= 0.500 Inlet / Outlet Invert= 22.00' / 21.00' S= 0.0179 '/ Cc= 0.900 n= 0.013 Corrugated PE, smooth interior, Flow Area= 3.14 sf
#2	Device 1	26.80'	<b>48.0" W x 36.0" H Vert. Orifice/Grate X 2.00</b> C= 0.600 Limited to weir flow at low heads
#3	Discarded	22.00'	<b>0.500 in/hr Exfiltration over Surface area</b>
#4	Device 1	22.40'	<b>6.0" Vert. Orifice/Grate</b> C= 0.600 Limited to weir flow at low heads

**Discarded OutFlow** Max=0.15 cfs @ 15.36 hrs HW=23.62' (Free Discharge)  
 ↑ **3=Exfiltration** (Exfiltration Controls 0.15 cfs)

**Primary OutFlow** Max=0.93 cfs @ 15.36 hrs HW=23.62' (Free Discharge)  
 ↑ **1=Culvert** (Passes 0.93 cfs of 11.84 cfs potential flow)  
 ↑ **2=Orifice/Grate** ( Controls 0.00 cfs)  
 ↑ **4=Orifice/Grate** (Orifice Controls 0.93 cfs @ 4.75 fps)



**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC


NOAA 24-hr D 25-yr Rainfall=6.15"

Printed 9/25/2024

Page 115

**Pond 21P: Water Quality Basin #2**

Hydrograph



**New Conditions**

NOAA 24-hr D 25-yr Rainfall=6.15"

Prepared by Loureiro Engineering Assoc, Inc

Printed 9/25/2024

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

Page 116

**Summary for Pond 22P: Water Quality Basin #3.2**

Inflow Area = 150,383 sf, 12.20% Impervious, Inflow Depth = 2.11" for 25-yr event  
 Inflow = 5.63 cfs @ 12.27 hrs, Volume= 26,399 cf  
 Outflow = 1.17 cfs @ 13.18 hrs, Volume= 26,399 cf, Atten= 79%, Lag= 54.6 min  
 Discarded = 0.12 cfs @ 13.18 hrs, Volume= 8,595 cf  
 Primary = 1.05 cfs @ 13.18 hrs, Volume= 17,804 cf  
 Routed to Link 4L : West Wetlands (POC 1)

Routing by Stor-Ind method, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 Peak Elev= 37.17' @ 13.18 hrs Surf.Area= 4,568 sf Storage= 10,158 cf  
 Flood Elev= 39.00' Surf.Area= 6,400 sf Storage= 20,137 cf

Plug-Flow detention time= 317.6 min calculated for 26,399 cf (100% of inflow)  
 Center-of-Mass det. time= 317.5 min ( 1,199.5 - 882.1 )

Volume	Invert	Avail.Storage	Storage Description			
#1	34.00'	20,137 cf	<b>Custom Stage Data (Irregular)</b> Listed below (Recalc)			
Elevation (feet)	Surf.Area (sq-ft)	Perim. (feet)	Inc.Store (cubic-feet)	Cum.Store (cubic-feet)	Wet.Area (sq-ft)	
34.00	1,960	236.0	0	0	1,960	
35.00	2,704	260.0	2,322	2,322	2,939	
36.00	3,520	284.0	3,103	5,425	4,013	
37.00	4,408	308.0	3,956	9,381	5,182	
38.00	5,368	332.0	4,880	14,261	6,445	
39.00	6,400	356.0	5,876	20,137	7,804	

Device	Routing	Invert	Outlet Devices	
#1	Primary	34.00'	<b>24.0" Round Culvert</b> L= 838.0' Ke= 0.500 Inlet / Outlet Invert= 34.00' / 22.00' S= 0.0143 '/ Cc= 0.900 n= 0.013 Corrugated PE, smooth interior, Flow Area= 3.14 sf	
#2	Device 1	38.50'	<b>48.0" W x 36.0" H Vert. Orifice/Grate X 2.00</b> C= 0.600 Limited to weir flow at low heads	
#3	Discarded	34.00'	<b>0.500 in/hr Exfiltration over Wetted area</b> Conductivity to Groundwater Elevation = 32.00'	
#4	Device 1	35.25'	<b>2.0" Vert. Orifice/Grate</b> C= 0.600 Limited to weir flow at low heads	
#5	Device 1	36.00'	<b>6.0" Vert. Orifice/Grate</b> C= 0.600 Limited to weir flow at low heads	

**Discarded OutFlow** Max=0.12 cfs @ 13.18 hrs HW=37.17' (Free Discharge)  
 ↳ **3=Exfiltration** ( Controls 0.12 cfs)

**Primary OutFlow** Max=1.05 cfs @ 13.18 hrs HW=37.17' (Free Discharge)  
 ↳ **1=Culvert** (Passes 1.05 cfs of 22.30 cfs potential flow)  
 ↳ **2=Orifice/Grate** ( Controls 0.00 cfs)  
 ↳ **4=Orifice/Grate** (Orifice Controls 0.14 cfs @ 6.53 fps)  
 ↳ **5=Orifice/Grate** (Orifice Controls 0.91 cfs @ 4.63 fps)

**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC


NOAA 24-hr D 25-yr Rainfall=6.15"

Printed 9/25/2024

Page 117

**Pond 22P: Water Quality Basin #3.2**

Hydrograph



# New Conditions

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 25-yr Rainfall=6.15"

Printed 9/25/2024

Page 118


## Summary for Link 2L: Northeast Wetland

Inflow Area = 359,530 sf, 0.00% Impervious, Inflow Depth = 0.28" for 25-yr event  
Inflow = 0.68 cfs @ 12.46 hrs, Volume= 8,528 cf  
Primary = 0.68 cfs @ 12.46 hrs, Volume= 8,528 cf, Atten= 0%, Lag= 0.0 min  
Routed to Link 4L : West Wetlands (POC 1)

Primary outflow = Inflow, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs

## Link 2L: Northeast Wetland

Hydrograph



**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 25-yr Rainfall=6.15"

Printed 9/25/2024

Page 119


**Summary for Link 3L: South Off-Site (POC 3)**

Inflow Area = 625,838 sf, 0.00% Impervious, Inflow Depth = 3.71" for 25-yr event  
Inflow = 28.19 cfs @ 12.54 hrs, Volume= 193,578 cf  
Primary = 28.19 cfs @ 12.54 hrs, Volume= 193,578 cf, Atten= 0%, Lag= 0.0 min

Primary outflow = Inflow, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs

**Link 3L: South Off-Site (POC 3)**

Hydrograph



**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 25-yr Rainfall=6.15"

Printed 9/25/2024

Page 120


**Summary for Link 4L: West Wetlands (POC 1)**

Inflow Area = 2,306,339 sf, 7.36% Impervious, Inflow Depth = 1.19" for 25-yr event  
Inflow = 11.26 cfs @ 13.55 hrs, Volume= 228,187 cf  
Primary = 11.26 cfs @ 13.55 hrs, Volume= 228,187 cf, Atten= 0%, Lag= 0.0 min

Primary outflow = Inflow, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs

**Link 4L: West Wetlands (POC 1)**

Hydrograph



**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 25-yr Rainfall=6.15"

Printed 9/25/2024

Page 121


**Summary for Link 5L: West Off-Site (POC 2)**

Inflow Area = 351,134 sf, 0.00% Impervious, Inflow Depth = 1.07" for 25-yr event  
Inflow = 4.14 cfs @ 12.47 hrs, Volume= 31,335 cf  
Primary = 4.14 cfs @ 12.47 hrs, Volume= 31,335 cf, Atten= 0%, Lag= 0.0 min

Primary outflow = Inflow, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs

**Link 5L: West Off-Site (POC 2)**

Hydrograph



## New Conditions

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 50-yr Rainfall=6.92"

Printed 9/25/2024

Page 122

Time span=0.00-96.00 hrs, dt=0.01 hrs, 9601 points  
Runoff by SCS TR-20 method, UH=SCS, Weighted-CN  
Reach routing by Stor-Ind+Trans method - Pond routing by Stor-Ind method

<b>Subcatchment1: Subcat 1</b>	Runoff Area=121,732 sf 0.00% Impervious Runoff Depth=0.96" Flow Length=1,013' Tc=23.3 min CN=42 Runoff=1.22 cfs 9,762 cf
<b>Subcatchment2: Subcat 2</b>	Runoff Area=150,383 sf 12.20% Impervious Runoff Depth=2.64" Flow Length=296' Tc=17.5 min UI Adjusted CN=61 Runoff=7.19 cfs 33,139 cf
<b>Subcatchment3: Subcat 3</b>	Runoff Area=542,887 sf 2.45% Impervious Runoff Depth=1.45" Flow Length=936' Tc=44.3 min UI Adjusted CN=48 Runoff=7.49 cfs 65,580 cf
<b>Subcatchment4: Subcat 4</b>	Runoff Area=480,934 sf 13.66% Impervious Runoff Depth=4.84" Flow Length=633' Tc=36.3 min UI Adjusted CN=82 Runoff=29.75 cfs 194,026 cf
<b>Subcatchment5: Subcat 5</b>	Runoff Area=625,838 sf 0.00% Impervious Runoff Depth=4.40" Flow Length=1,037' Tc=40.7 min CN=78 Runoff=33.40 cfs 229,595 cf
<b>Subcatchment6: Subcat 6</b>	Runoff Area=405,402 sf 16.44% Impervious Runoff Depth=4.29" Flow Length=280' Tc=29.1 min UI Adjusted CN=77 Runoff=25.18 cfs 145,066 cf
<b>Subcatchment7: Subcat 7</b>	Runoff Area=351,134 sf 0.00% Impervious Runoff Depth=1.45" Flow Length=815' Tc=28.4 min CN=48 Runoff=6.16 cfs 42,417 cf
<b>Subcatchment8: Subcat 8</b>	Runoff Area=109,129 sf 0.00% Impervious Runoff Depth=1.04" Flow Length=261' Slope=0.0150 '/' Tc=18.5 min CN=43 Runoff=1.40 cfs 9,456 cf
<b>Subcatchment9: Subcat 9</b>	Runoff Area=209,524 sf 2.74% Impervious Runoff Depth=1.20" Flow Length=651' Tc=22.1 min UI Adjusted CN=45 Runoff=3.12 cfs 20,945 cf
<b>Subcatchment10: Subcat 10</b>	Runoff Area=48,549 sf 0.00% Impervious Runoff Depth=1.12" Flow Length=335' Tc=16.8 min CN=44 Runoff=0.74 cfs 4,527 cf
<b>Subcatchment11: Subcat 11</b>	Runoff Area=237,799 sf 0.00% Impervious Runoff Depth=0.20" Flow Length=138' Tc=17.2 min CN=30 Runoff=0.13 cfs 3,932 cf
<b>Pond 12P: Water Quality Basin #4</b>	Peak Elev=27.01' Storage=93,953 cf Inflow=29.75 cfs 194,026 cf Discarded=0.77 cfs 78,208 cf Primary=11.07 cfs 115,818 cf Outflow=11.85 cfs 194,026 cf
<b>Pond 13P: Water Quality Basin #1</b>	Peak Elev=14.84' Storage=8,249 cf Inflow=3.12 cfs 20,945 cf Discarded=0.12 cfs 10,434 cf Primary=0.41 cfs 10,512 cf Outflow=0.54 cfs 20,945 cf
<b>Pond 18P: Water Quality Basin #5</b>	Peak Elev=20.97' Storage=1,967 cf Inflow=1.40 cfs 9,456 cf Discarded=0.03 cfs 1,998 cf Primary=0.53 cfs 7,459 cf Outflow=0.56 cfs 9,456 cf
<b>Pond 20P: Water Quality Basin #3.1</b>	Peak Elev=22.41' Storage=71,537 cf Inflow=25.18 cfs 145,066 cf Discarded=0.59 cfs 59,197 cf Primary=7.34 cfs 85,869 cf Outflow=7.93 cfs 145,066 cf
<b>Pond 21P: Water Quality Basin #2</b>	Peak Elev=24.27' Storage=28,052 cf Inflow=7.49 cfs 65,580 cf Discarded=0.17 cfs 15,166 cf Primary=1.20 cfs 50,414 cf Outflow=1.37 cfs 65,580 cf



**New Conditions**

NOAA 24-hr D 50-yr Rainfall=6.92"

Prepared by Loureiro Engineering Assoc, Inc

Printed 9/25/2024

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

Page 123

**Pond 22P: Water Quality Basin #3.2** Peak Elev=37.76' Storage=12,992 cf Inflow=7.19 cfs 33,139 cf  
Discarded=0.14 cfs 9,050 cf Primary=1.32 cfs 24,089 cf Outflow=1.47 cfs 33,139 cf

**Link 2L: Northeast Wetland** Inflow=1.22 cfs 13,694 cf  
Primary=1.22 cfs 13,694 cf

**Link 3L: South Off-Site (POC 3)** Inflow=33.40 cfs 229,595 cf  
Primary=33.40 cfs 229,595 cf

**Link 4L: West Wetlands (POC 1)** Inflow=22.29 cfs 312,381 cf  
Primary=22.29 cfs 312,381 cf

**Link 5L: West Off-Site (POC 2)** Inflow=6.16 cfs 42,417 cf  
Primary=6.16 cfs 42,417 cf

**Total Runoff Area = 3,283,311 sf Runoff Volume = 758,445 cf Average Runoff Depth = 2.77"**  
**94.83% Pervious = 3,113,537 sf 5.17% Impervious = 169,774 sf**

**New Conditions**

NOAA 24-hr D 50-yr Rainfall=6.92"

Prepared by Loureiro Engineering Assoc, Inc

Printed 9/25/2024

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

Page 124

**Summary for Subcatchment 1: Subcat 1**

Runoff = 1.22 cfs @ 12.42 hrs, Volume= 9,762 cf, Depth= 0.96"  
 Routed to Link 2L : Northeast Wetland

Runoff by SCS TR-20 method, UH=SCS, Weighted-CN, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 NOAA 24-hr D 50-yr Rainfall=6.92"

Area (sf)	CN	Description
700	48	Brush, Good, HSG B
14,806	55	Woods, Good, HSG B
1,211	55	Woods, Good, HSG B
24	39	>75% Grass cover, Good, HSG A
1,022	72	Dirt roads, HSG A
9,987	30	Brush, Good, HSG A
13,422	30	Woods, Good, HSG A
21,799	77	Woods, Good, HSG D
58,761	30	Woods, Good, HSG A
121,732	42	Weighted Average
121,732	42	100.00% Pervious Area

Tc (min)	Length (feet)	Slope (ft/ft)	Velocity (ft/sec)	Capacity (cfs)	Description
13.3	100	0.2400	0.13		<b>Sheet Flow,</b> Woods: Dense underbrush n= 0.800 P2= 3.46"
10.0	913	0.0920	1.52		<b>Shallow Concentrated Flow,</b> Woodland Kv= 5.0 fps
23.3	1,013	Total			

**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC


NOAA 24-hr D 50-yr Rainfall=6.92"

Printed 9/25/2024

Page 125

**Subcatchment 1: Subcat 1**

Hydrograph



**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc  
 HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 50-yr Rainfall=6.92"

Printed 9/25/2024

Page 126

**Summary for Subcatchment 2: Subcat 2**

Runoff = 7.19 cfs @ 12.27 hrs, Volume= 33,139 cf, Depth= 2.64"  
 Routed to Pond 22P : Water Quality Basin #3.2

Runoff by SCS TR-20 method, UH=SCS, Weighted-CN, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 NOAA 24-hr D 50-yr Rainfall=6.92"

Area (sf)	CN	Adj	Description
72,676	39		>75% Grass cover, Good, HSG A
18,352	98		Unconnected pavement, HSG A
995	96		Gravel surface, HSG A
6	30		Woods, Good, HSG A
4,992	77		Woods, Good, HSG D
35,625	86		Woods/grass comb., Poor, HSG D
17,737	80		>75% Grass cover, Good, HSG D
150,383	64	61	Weighted Average, UI Adjusted
132,031	59	59	87.80% Pervious Area
18,352	98	98	12.20% Impervious Area
18,352			100.00% Unconnected

Tc (min)	Length (feet)	Slope (ft/ft)	Velocity (ft/sec)	Capacity (cfs)	Description
14.6	62	0.0730	0.07		<b>Sheet Flow, sheet</b> Woods: Dense underbrush n= 0.800 P2= 3.46"
2.0					<b>Direct Entry, rock crossing</b>
0.9	234	0.0100	4.26	17.02	<b>Channel Flow, swale</b> Area= 4.0 sf Perim= 8.0' r= 0.50' n= 0.022 Earth, clean & straight
17.5	296	Total			

**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC


NOAA 24-hr D 50-yr Rainfall=6.92"

Printed 9/25/2024

Page 127

**Subcatchment 2: Subcat 2**

Hydrograph



**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 50-yr Rainfall=6.92"

Printed 9/25/2024

Page 128

**Summary for Subcatchment 3: Subcat 3**

Runoff = 7.49 cfs @ 12.70 hrs, Volume= 65,580 cf, Depth= 1.45"

Routed to Pond 21P : Water Quality Basin #2

Runoff by SCS TR-20 method, UH=SCS, Weighted-CN, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 NOAA 24-hr D 50-yr Rainfall=6.92"

Area (sf)	CN	Adj	Description
185,176	39		>75% Grass cover, Good, HSG A
238,754	39		>75% Grass cover, Good, HSG A
15,049	96		Gravel surface, HSG A
13,325	98		Unconnected pavement, HSG D
55,139	80		>75% Grass cover, Good, HSG D
9,578	77		Woods, Good, HSG D
25,866	86		Woods/grass comb., Poor, HSG D
542,887	49	48	Weighted Average, UI Adjusted
529,562	48	48	97.55% Pervious Area
13,325	98	98	2.45% Impervious Area
13,325			100.00% Unconnected

Tc (min)	Length (feet)	Slope (ft/ft)	Velocity (ft/sec)	Capacity (cfs)	Description
2.0					<b>Direct Entry,</b>
28.7	100	0.0350	0.06		<b>Sheet Flow, sheet</b> Woods: Dense underbrush n= 0.800 P2= 3.46"
2.1	246	0.0813	2.00		<b>Shallow Concentrated Flow, scf</b> Short Grass Pasture Kv= 7.0 fps
11.5	590	0.0150	0.86		<b>Shallow Concentrated Flow, scf grass</b> Short Grass Pasture Kv= 7.0 fps
44.3	936	Total			

**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC


NOAA 24-hr D 50-yr Rainfall=6.92"

Printed 9/25/2024

Page 129

**Subcatchment 3: Subcat 3**

Hydrograph



**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 50-yr Rainfall=6.92"

Printed 9/25/2024

Page 130

**Summary for Subcatchment 4: Subcat 4**

Runoff = 29.75 cfs @ 12.47 hrs, Volume= 194,026 cf, Depth= 4.84"

Routed to Pond 12P : Water Quality Basin #4

Runoff by SCS TR-20 method, UH=SCS, Weighted-CN, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 NOAA 24-hr D 50-yr Rainfall=6.92"

Area (sf)	CN	Adj	Description
414	96		Gravel surface, HSG A
9,603	39		>75% Grass cover, Good, HSG A
0	77		Woods, Good, HSG D
0	77		Woods, Good, HSG D
2	77		Woods, Good, HSG D
5,250	77		Woods, Good, HSG D
0	77		Woods, Good, HSG D
23,224	77		Woods, Good, HSG D
249,238	80		>75% Grass cover, Good, HSG D
65,690	98		Unconnected pavement, HSG D
127,513	86		Woods/grass comb., Poor, HSG D
480,934	83	82	Weighted Average, UI Adjusted
415,244	81	81	86.34% Pervious Area
65,690	98	98	13.66% Impervious Area
65,690			100.00% Unconnected

Tc (min)	Length (feet)	Slope (ft/ft)	Velocity (ft/sec)	Capacity (cfs)	Description
30.6	100	0.0300	0.05		<b>Sheet Flow, sheet</b> Woods: Dense underbrush n= 0.800 P2= 3.46"
0.7	50	0.1988	1.11		<b>Shallow Concentrated Flow, scf</b> Forest w/Heavy Litter Kv= 2.5 fps
2.0					<b>Direct Entry, rock crossing</b>
3.0	483	0.1500	2.71		<b>Shallow Concentrated Flow, scf grass</b> Short Grass Pasture Kv= 7.0 fps
36.3	633	Total			



**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC


NOAA 24-hr D 50-yr Rainfall=6.92"

Printed 9/25/2024

Page 131

**Subcatchment 4: Subcat 4**

Hydrograph



**New Conditions**

NOAA 24-hr D 50-yr Rainfall=6.92"

Prepared by Loureiro Engineering Assoc, Inc

Printed 9/25/2024

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

Page 132

**Summary for Subcatchment 5: Subcat 5**

Runoff = 33.40 cfs @ 12.53 hrs, Volume= 229,595 cf, Depth= 4.40"

Routed to Link 3L : South Off-Site (POC 3)

Runoff by SCS TR-20 method, UH=SCS, Weighted-CN, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 NOAA 24-hr D 50-yr Rainfall=6.92"

Area (sf)	CN	Description
0	98	Unconnected pavement, HSG D
14,987	73	Brush, Good, HSG D
1,504	91	Gravel roads, HSG D
39,327	91	Gravel roads, HSG D
18,528	91	Gravel roads, HSG D
2,922	89	Dirt roads, HSG D
2,214	73	Brush, Good, HSG D
7,635	77	Woods, Good, HSG D
137,134	77	Woods, Good, HSG D
10,652	77	Woods, Good, HSG D
291,847	77	Woods, Good, HSG D
34,529	77	Woods, Good, HSG D
23,786	77	Woods, Good, HSG D
1,988	73	Brush, Good, HSG D
357	91	Gravel roads, HSG D
38,427	73	Brush, Good, HSG D
625,838	78	Weighted Average
625,838	78	100.00% Pervious Area
0	98	0.00% Impervious Area
0		100.00% Unconnected

Tc (min)	Length (feet)	Slope (ft/ft)	Velocity (ft/sec)	Capacity (cfs)	Description
26.0	100	0.0450	0.06		<b>Sheet Flow, sheet</b>
					Woods: Dense underbrush n= 0.800 P2= 3.46"
6.1	225	0.0600	0.61		<b>Shallow Concentrated Flow, scf woods</b>
					Forest w/Heavy Litter Kv= 2.5 fps
0.7	112	0.1560	2.76		<b>Shallow Concentrated Flow, scfbrush</b>
					Short Grass Pasture Kv= 7.0 fps
0.5	140	0.0820	4.61		<b>Shallow Concentrated Flow, scf unpaved</b>
					Unpaved Kv= 16.1 fps
7.4	460	0.1740	1.04		<b>Shallow Concentrated Flow, scf woods</b>
					Forest w/Heavy Litter Kv= 2.5 fps
40.7	1,037	Total			

**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC


NOAA 24-hr D 50-yr Rainfall=6.92"

Printed 9/25/2024

Page 133

**Subcatchment 5: Subcat 5**

Hydrograph



**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc  
 HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 50-yr Rainfall=6.92"

Printed 9/25/2024

Page 134

**Summary for Subcatchment 6: Subcat 6**

Runoff = 25.18 cfs @ 12.39 hrs, Volume= 145,066 cf, Depth= 4.29"

Routed to Pond 20P : Water Quality Basin #3.1

Runoff by SCS TR-20 method, UH=SCS, Weighted-CN, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 NOAA 24-hr D 50-yr Rainfall=6.92"

Area (sf)	CN	Adj	Description
1,758	73		Brush, Good, HSG D
66,656	98		Unconnected pavement, HSG D
1,257	77		Woods, Good, HSG D
34,488	77		Woods, Good, HSG D
49,599	39		>75% Grass cover, Good, HSG A
43,447	77		Woods, Good, HSG D
129,391	86		Woods/grass comb., Poor, HSG D
28	73		Brush, Good, HSG D
78,778	80		>75% Grass cover, Good, HSG D
405,402	79	77	Weighted Average, UI Adjusted
338,746	76	76	83.56% Pervious Area
66,656	98	98	16.44% Impervious Area
66,656			100.00% Unconnected

Tc (min)	Length (feet)	Slope (ft/ft)	Velocity (ft/sec)	Capacity (cfs)	Description
24.9	100	0.0500	0.07		<b>Sheet Flow, sheet</b> Woods: Dense underbrush n= 0.800 P2= 3.46"
2.2	180	0.3000	1.37		<b>Shallow Concentrated Flow, scf</b> Forest w/Heavy Litter Kv= 2.5 fps
2.0					<b>Direct Entry, rock crossing</b>
29.1	280	Total			

**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC


NOAA 24-hr D 50-yr Rainfall=6.92"

Printed 9/25/2024

Page 135

**Subcatchment 6: Subcat 6**

Hydrograph



**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc  
 HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 50-yr Rainfall=6.92"

Printed 9/25/2024

Page 136

**Summary for Subcatchment 7: Subcat 7**

Runoff = 6.16 cfs @ 12.46 hrs, Volume= 42,417 cf, Depth= 1.45"  
 Routed to Link 5L : West Off-Site (POC 2)

Runoff by SCS TR-20 method, UH=SCS, Weighted-CN, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 NOAA 24-hr D 50-yr Rainfall=6.92"

Area (sf)	CN	Description
8,651	91	Gravel roads, HSG D
11,645	73	Brush, Good, HSG D
8,819	73	Brush, Good, HSG D
23	77	Woods, Good, HSG D
338	77	Woods, Good, HSG D
7	77	Woods, Good, HSG D
9,853	76	Gravel roads, HSG A
17,832	30	Brush, Good, HSG A
195,049	30	Woods, Good, HSG A
1,207	30	Woods, Good, HSG A
7,262	77	Woods, Good, HSG D
47,566	77	Woods, Good, HSG D
39,066	73	Brush, Good, HSG D
1	91	Gravel roads, HSG D
3,817	91	Gravel roads, HSG D
351,134	48	Weighted Average
351,134	48	100.00% Pervious Area

Tc (min)	Length (feet)	Slope (ft/ft)	Velocity (ft/sec)	Capacity (cfs)	Description
18.9	100	0.1000	0.09		<b>Sheet Flow, sheet</b> Woods: Dense underbrush n= 0.800 P2= 3.46"
9.5	715	0.2500	1.25		<b>Shallow Concentrated Flow, scf</b> Forest w/Heavy Litter Kv= 2.5 fps
28.4	815	Total			

**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC


NOAA 24-hr D 50-yr Rainfall=6.92"

Printed 9/25/2024

Page 137

**Subcatchment 7: Subcat 7**

Hydrograph



**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc  
 HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 50-yr Rainfall=6.92"

Printed 9/25/2024

Page 138

**Summary for Subcatchment 8: Subcat 8**

Runoff = 1.40 cfs @ 12.33 hrs, Volume= 9,456 cf, Depth= 1.04"  
 Routed to Pond 18P : Water Quality Basin #5


Runoff by SCS TR-20 method, UH=SCS, Weighted-CN, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 NOAA 24-hr D 50-yr Rainfall=6.92"

Area (sf)	CN	Description
8,265	96	Gravel surface, HSG A
10,542	39	>75% Grass cover, Good, HSG A
90,322	39	>75% Grass cover, Good, HSG A
109,129	43	Weighted Average
109,129	43	100.00% Pervious Area

Tc (min)	Length (feet)	Slope (ft/ft)	Velocity (ft/sec)	Capacity (cfs)	Description
15.4	100	0.0150	0.11		<b>Sheet Flow, sheet</b>
					Grass: Dense n= 0.240 P2= 3.46"
3.1	161	0.0150	0.86		<b>Shallow Concentrated Flow, scf</b>
					Short Grass Pasture Kv= 7.0 fps
18.5	261	Total			

**Subcatchment 8: Subcat 8**

Hydrograph





**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 50-yr Rainfall=6.92"

Printed 9/25/2024

Page 139

**Summary for Subcatchment 9: Subcat 9**

Runoff = 3.12 cfs @ 12.38 hrs, Volume= 20,945 cf, Depth= 1.20"

Routed to Pond 13P : Water Quality Basin #1

Runoff by SCS TR-20 method, UH=SCS, Weighted-CN, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 NOAA 24-hr D 50-yr Rainfall=6.92"

Area (sf)	CN	Adj	Description
5,751	98		Unconnected pavement, HSG A
10,904	96		Gravel surface, HSG A
181,704	39		>75% Grass cover, Good, HSG A
11,165	86		Woods/grass comb., Poor, HSG D
209,524	46	45	Weighted Average, UI Adjusted
203,773	45	45	97.26% Pervious Area
5,751	98	98	2.74% Impervious Area
5,751			100.00% Unconnected

Tc (min)	Length (feet)	Slope (ft/ft)	Velocity (ft/sec)	Capacity (cfs)	Description
15.4	100	0.0150	0.11		<b>Sheet Flow, sheet</b> Grass: Dense n= 0.240 P2= 3.46"
5.7	291	0.0150	0.86		<b>Shallow Concentrated Flow, scf</b> Short Grass Pasture Kv= 7.0 fps
1.0	260	0.0100	4.26	17.02	<b>Channel Flow, swale</b> Area= 4.0 sf Perim= 8.0' r= 0.50' n= 0.022 Earth, clean & straight
22.1	651	Total			

**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC


NOAA 24-hr D 50-yr Rainfall=6.92"

Printed 9/25/2024

Page 140

**Subcatchment 9: Subcat 9**

Hydrograph



**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 50-yr Rainfall=6.92"

Printed 9/25/2024

Page 141

**Summary for Subcatchment 10: Subcat 10**

Runoff = 0.74 cfs @ 12.30 hrs, Volume= 4,527 cf, Depth= 1.12"

Routed to Link 4L : West Wetlands (POC 1)


Runoff by SCS TR-20 method, UH=SCS, Weighted-CN, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 NOAA 24-hr D 50-yr Rainfall=6.92"

Area (sf)	CN	Description
15,200	39	>75% Grass cover, Good, HSG A
29,317	39	>75% Grass cover, Good, HSG A
4,025	96	Gravel surface, HSG A
5	30	Woods, Good, HSG A
1	30	Woods, Good, HSG A
2	30	Woods, Good, HSG A
0	30	Woods, Good, HSG A
48,549	44	Weighted Average
48,549	44	100.00% Pervious Area

Tc (min)	Length (feet)	Slope (ft/ft)	Velocity (ft/sec)	Capacity (cfs)	Description
15.4	100	0.0150	0.11		<b>Sheet Flow, sheet</b> Grass: Dense n= 0.240 P2= 3.46"
1.4	235	0.1500	2.71		<b>Shallow Concentrated Flow, scf</b> Short Grass Pasture Kv= 7.0 fps
16.8	335	Total			

**Subcatchment 10: Subcat 10**

Hydrograph



**New Conditions**

NOAA 24-hr D 50-yr Rainfall=6.92"

Prepared by Loureiro Engineering Assoc, Inc

Printed 9/25/2024

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

Page 142

**Summary for Subcatchment 11: Subcat 11**

Runoff = 0.13 cfs @ 13.51 hrs, Volume= 3,932 cf, Depth= 0.20"  
 Routed to Link 2L : Northeast Wetland

Runoff by SCS TR-20 method, UH=SCS, Weighted-CN, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 NOAA 24-hr D 50-yr Rainfall=6.92"

Area (sf)	CN	Description
3,394	48	Brush, Good, HSG B
72	39	>75% Grass cover, Good, HSG A
3	96	Gravel surface, HSG A
29	39	>75% Grass cover, Good, HSG A
24	39	>75% Grass cover, Good, HSG A
48,779	30	Brush, Good, HSG A
185,489	30	Woods, Good, HSG A
8	30	Woods, Good, HSG A
237,799	30	Weighted Average
237,799	30	100.00% Pervious Area

Tc (min)	Length (feet)	Slope (ft/ft)	Velocity (ft/sec)	Capacity (cfs)	Description
16.5	100	0.1400	0.10		<b>Sheet Flow, sheet</b>
					Woods: Dense underbrush n= 0.800 P2= 3.46"
0.7	38	0.1369	0.93		<b>Shallow Concentrated Flow, scf</b>
					Forest w/Heavy Litter Kv= 2.5 fps
17.2	138	Total			

**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC


NOAA 24-hr D 50-yr Rainfall=6.92"

Printed 9/25/2024

Page 143

**Subcatchment 11: Subcat 11**

Hydrograph



**New Conditions**

NOAA 24-hr D 50-yr Rainfall=6.92"

Prepared by Loureiro Engineering Assoc, Inc

Printed 9/25/2024

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

Page 144

**Summary for Pond 12P: Water Quality Basin #4**

Inflow Area = 480,934 sf, 13.66% Impervious, Inflow Depth = 4.84" for 50-yr event  
 Inflow = 29.75 cfs @ 12.47 hrs, Volume= 194,026 cf  
 Outflow = 11.85 cfs @ 13.12 hrs, Volume= 194,026 cf, Atten= 60%, Lag= 38.6 min  
 Discarded = 0.77 cfs @ 13.12 hrs, Volume= 78,208 cf  
 Primary = 11.07 cfs @ 13.12 hrs, Volume= 115,818 cf  
 Routed to Link 4L : West Wetlands (POC 1)

Routing by Stor-Ind method, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 Peak Elev= 27.01' @ 13.12 hrs Surf.Area= 20,894 sf Storage= 93,953 cf

Plug-Flow detention time= 597.2 min calculated for 194,006 cf (100% of inflow)  
 Center-of-Mass det. time= 597.5 min ( 1,436.0 - 838.5 )

Volume	Invert	Avail.Storage	Storage Description		
#1	21.00'	115,489 cf	<b>Custom Stage Data (Irregular)</b> Listed below (Recalc)		
Elevation (feet)	Surf.Area (sq-ft)	Perim. (feet)	Inc.Store (cubic-feet)	Cum.Store (cubic-feet)	Wet.Area (sq-ft)
21.00	10,788	488.0	0	0	10,788
22.00	12,288	512.0	11,530	11,530	12,762
23.00	13,860	536.0	13,066	24,596	14,831
24.00	15,504	560.0	14,674	39,270	16,995
25.00	17,220	584.0	16,354	55,625	19,253
26.00	19,008	608.0	18,107	73,731	21,607
27.00	20,868	632.0	19,931	93,662	24,055
28.00	22,800	656.0	21,827	115,489	26,598

Device	Routing	Invert	Outlet Devices	
#1	Primary	21.00'	<b>30.0" Round Culvert</b> L= 184.0' Ke= 0.500 Inlet / Outlet Invert= 21.00' / 19.10' S= 0.0103 '/' Cc= 0.900 n= 0.012 Corrugated PP, smooth interior, Flow Area= 4.91 sf	
#2	Device 1	26.50'	<b>48.0" W x 36.0" H Vert. Orifice/Grate X 2.00</b> C= 0.600 Limited to weir flow at low heads	
#3	Discarded	21.00'	<b>0.500 in/hr Exfiltration over Wetted area</b> Conductivity to Groundwater Elevation = 19.00'	
#4	Device 1	21.30'	<b>2.0" Vert. Orifice/Grate</b> C= 0.600 Limited to weir flow at low heads	
#5	Device 1	24.70'	<b>6.0" Vert. Orifice/Grate</b> C= 0.600 Limited to weir flow at low heads	

**Discarded OutFlow** Max=0.77 cfs @ 13.12 hrs HW=27.01' (Free Discharge)  
 ↳ **3=Exfiltration** ( Controls 0.77 cfs)

**Primary OutFlow** Max=11.07 cfs @ 13.12 hrs HW=27.01' (Free Discharge)  
 ↳ **1=Culvert** (Passes 11.07 cfs of 51.59 cfs potential flow)  
 ↳ **2=Orifice/Grate** (Orifice Controls 9.46 cfs @ 2.30 fps)  
 ↳ **4=Orifice/Grate** (Orifice Controls 0.25 cfs @ 11.43 fps)  
 ↳ **5=Orifice/Grate** (Orifice Controls 1.36 cfs @ 6.92 fps)

**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC


NOAA 24-hr D 50-yr Rainfall=6.92"

Printed 9/25/2024

Page 145

**Pond 12P: Water Quality Basin #4**

Hydrograph



**New Conditions**

NOAA 24-hr D 50-yr Rainfall=6.92"

Prepared by Loureiro Engineering Assoc, Inc

Printed 9/25/2024

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

Page 146

**Summary for Pond 13P: Water Quality Basin #1**

Inflow Area = 209,524 sf, 2.74% Impervious, Inflow Depth = 1.20" for 50-yr event  
 Inflow = 3.12 cfs @ 12.38 hrs, Volume= 20,945 cf  
 Outflow = 0.54 cfs @ 14.63 hrs, Volume= 20,945 cf, Atten= 83%, Lag= 135.0 min  
 Discarded = 0.12 cfs @ 14.63 hrs, Volume= 10,434 cf  
 Primary = 0.41 cfs @ 14.63 hrs, Volume= 10,512 cf  
 Routed to Link 4L : West Wetlands (POC 1)

Routing by Stor-Ind method, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 Peak Elev= 14.84' @ 14.63 hrs Surf.Area= 10,458 sf Storage= 8,249 cf

Plug-Flow detention time= 332.1 min calculated for 20,943 cf (100% of inflow)  
 Center-of-Mass det. time= 332.2 min ( 1,264.1 - 931.9 )

Volume	Invert	Avail.Storage	Storage Description			
#1	14.00'	66,060 cf	<b>Custom Stage Data (Irregular)</b> Listed below (Recalc)			
Elevation (feet)	Surf.Area (sq-ft)	Perim. (feet)	Inc.Store (cubic-feet)	Cum.Store (cubic-feet)	Wet.Area (sq-ft)	
14.00	9,180	498.0	0	0	9,180	
15.00	10,710	522.0	9,935	9,935	11,194	
16.00	12,312	546.0	11,502	21,437	13,302	
17.00	13,986	570.0	13,140	34,577	15,505	
18.00	15,732	594.0	14,850	49,427	17,803	
19.00	17,550	618.0	16,633	66,060	20,196	

Device	Routing	Invert	Outlet Devices	
#1	Primary	14.00'	<b>30.0" Round Culvert</b> L= 107.0' Ke= 0.500 Inlet / Outlet Invert= 14.00' / 12.50' S= 0.0140 '/' Cc= 0.900 n= 0.012 Corrugated PP, smooth interior, Flow Area= 4.91 sf	
#2	Device 1	18.00'	<b>48.0" W x 36.0" H Vert. Orifice/Grate X 2.00</b> C= 0.600 Limited to weir flow at low heads	
#3	Discarded	14.00'	<b>0.500 in/hr Exfiltration over Surface area</b>	
#4	Device 1	14.40'	<b>6.0" Vert. Orifice/Grate</b> C= 0.600 Limited to weir flow at low heads	

**Discarded OutFlow** Max=0.12 cfs @ 14.63 hrs HW=14.84' (Free Discharge)  
 ↳ **3=Exfiltration** (Exfiltration Controls 0.12 cfs)

**Primary OutFlow** Max=0.41 cfs @ 14.63 hrs HW=14.84' (Free Discharge)  
 ↳ **1=Culvert** (Passes 0.41 cfs of 4.53 cfs potential flow)  
 ↳ **2=Orifice/Grate** ( Controls 0.00 cfs)  
 ↳ **4=Orifice/Grate** (Orifice Controls 0.41 cfs @ 2.26 fps)



**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC


NOAA 24-hr D 50-yr Rainfall=6.92"

Printed 9/25/2024

Page 147

**Pond 13P: Water Quality Basin #1**

Hydrograph



**New Conditions**

NOAA 24-hr D 50-yr Rainfall=6.92"

Prepared by Loureiro Engineering Assoc, Inc

Printed 9/25/2024

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

Page 148

**Summary for Pond 18P: Water Quality Basin #5**

Inflow Area = 109,129 sf, 0.00% Impervious, Inflow Depth = 1.04" for 50-yr event  
 Inflow = 1.40 cfs @ 12.33 hrs, Volume= 9,456 cf  
 Outflow = 0.56 cfs @ 13.02 hrs, Volume= 9,456 cf, Atten= 60%, Lag= 41.5 min  
 Discarded = 0.03 cfs @ 13.02 hrs, Volume= 1,998 cf  
 Primary = 0.53 cfs @ 13.02 hrs, Volume= 7,459 cf  
 Routed to Link 4L : West Wetlands (POC 1)

Routing by Stor-Ind method, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 Peak Elev= 20.97' @ 13.02 hrs Surf.Area= 2,368 sf Storage= 1,967 cf

Plug-Flow detention time= 129.0 min calculated for 9,455 cf (100% of inflow)  
 Center-of-Mass det. time= 129.1 min ( 1,067.6 - 938.5 )

Volume	Invert	Avail.Storage	Storage Description		
#1	20.00'	18,040 cf	<b>Custom Stage Data (Irregular)</b> Listed below (Recalc)		
Elevation (feet)	Surf.Area (sq-ft)	Perim. (feet)	Inc.Store (cubic-feet)	Cum.Store (cubic-feet)	Wet.Area (sq-ft)
20.00	1,720	212.0	0	0	1,720
21.00	2,392	236.0	2,047	2,047	2,604
22.00	3,136	260.0	2,756	4,802	3,584
23.00	3,952	284.0	3,536	8,339	4,658
24.00	4,840	308.0	4,389	12,727	5,826
25.00	5,800	332.0	5,313	18,040	7,090

Device	Routing	Invert	Outlet Devices
#1	Primary	20.00'	<b>18.0" Round Culvert</b> L= 25.0' Ke= 0.500 Inlet / Outlet Invert= 20.00' / 19.50' S= 0.0200 '/' Cc= 0.900 n= 0.013 Corrugated PE, smooth interior, Flow Area= 1.77 sf
#2	Device 1	24.00'	<b>48.0" W x 36.0" H Vert. Orifice/Grate X 2.00</b> C= 0.600 Limited to weir flow at low heads
#3	Discarded	20.00'	<b>0.500 in/hr Exfiltration over Surface area</b>
#4	Device 1	20.40'	<b>6.0" Vert. Orifice/Grate</b> C= 0.600 Limited to weir flow at low heads

**Discarded OutFlow** Max=0.03 cfs @ 13.02 hrs HW=20.97' (Free Discharge)  
 ↳ **3=Exfiltration** (Exfiltration Controls 0.03 cfs)

**Primary OutFlow** Max=0.53 cfs @ 13.02 hrs HW=20.97' (Free Discharge)  
 ↳ **1=Culvert** (Passes 0.53 cfs of 4.03 cfs potential flow)  
 ↳ ↳ **2=Orifice/Grate** ( Controls 0.00 cfs)  
 ↳ ↳ ↳ **4=Orifice/Grate** (Orifice Controls 0.53 cfs @ 2.71 fps)

**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC


NOAA 24-hr D 50-yr Rainfall=6.92"

Printed 9/25/2024

Page 149

**Pond 18P: Water Quality Basin #5**

Hydrograph



**New Conditions**

NOAA 24-hr D 50-yr Rainfall=6.92"

Prepared by Loureiro Engineering Assoc, Inc

Printed 9/25/2024

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

Page 150

**Summary for Pond 20P: Water Quality Basin #3.1**

Inflow Area = 405,402 sf, 16.44% Impervious, Inflow Depth = 4.29" for 50-yr event  
 Inflow = 25.18 cfs @ 12.39 hrs, Volume= 145,066 cf  
 Outflow = 7.93 cfs @ 13.09 hrs, Volume= 145,066 cf, Atten= 69%, Lag= 41.8 min  
 Discarded = 0.59 cfs @ 13.09 hrs, Volume= 59,197 cf  
 Primary = 7.34 cfs @ 13.09 hrs, Volume= 85,869 cf  
 Routed to Link 4L : West Wetlands (POC 1)

Routing by Stor-Ind method, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 Peak Elev= 22.41' @ 13.09 hrs Surf.Area= 16,471 sf Storage= 71,537 cf

Plug-Flow detention time= 651.8 min calculated for 145,066 cf (100% of inflow)  
 Center-of-Mass det. time= 651.8 min ( 1,497.1 - 845.4 )

Volume	Invert	Avail.Storage	Storage Description			
#1	16.00'	81,518 cf	<b>Custom Stage Data (Irregular)</b> Listed below (Recalc)			
Elevation (feet)	Surf.Area (sq-ft)	Perim. (feet)	Inc.Store (cubic-feet)	Cum.Store (cubic-feet)	Wet.Area (sq-ft)	
16.00	6,336	450.0	0	0	6,336	
17.00	7,722	474.0	7,018	7,018	8,160	
18.00	9,180	498.0	8,440	15,458	10,079	
19.00	10,710	522.0	9,935	25,393	12,093	
20.00	12,312	546.0	11,502	36,895	14,201	
21.00	13,986	570.0	13,140	50,035	16,405	
22.00	15,732	594.0	14,850	64,886	18,703	
23.00	17,550	618.0	16,633	81,518	21,095	

Device	Routing	Invert	Outlet Devices	
#1	Primary	16.00'	<b>30.0" Round Culvert</b> L= 202.0' Ke= 0.500 Inlet / Outlet Invert= 16.00' / 13.80' S= 0.0109 '/' Cc= 0.900 n= 0.013 Corrugated PE, smooth interior, Flow Area= 4.91 sf	
#2	Device 1	22.00'	<b>48.0" W x 36.0" H Vert. Orifice/Grate X 2.00</b> C= 0.600 Limited to weir flow at low heads	
#3	Discarded	16.00'	<b>0.500 in/hr Exfiltration over Wetted area</b> Conductivity to Groundwater Elevation = 14.00'	
#4	Device 1	16.50'	<b>2.0" Vert. Orifice/Grate</b> C= 0.600 Limited to weir flow at low heads	
#5	Device 1	17.00'	<b>2.0" Vert. Orifice/Grate</b> C= 0.600 Limited to weir flow at low heads	

**Discarded OutFlow** Max=0.59 cfs @ 13.09 hrs HW=22.41' (Free Discharge)  
 ↳ **3=Exfiltration** ( Controls 0.59 cfs)

**Primary OutFlow** Max=7.31 cfs @ 13.09 hrs HW=22.41' (Free Discharge)  
 ↳ **1=Culvert** (Passes 7.31 cfs of 53.06 cfs potential flow)  
 ↳ **2=Orifice/Grate** (Orifice Controls 6.82 cfs @ 2.06 fps)  
 ↳ **4=Orifice/Grate** (Orifice Controls 0.25 cfs @ 11.63 fps)  
 ↳ **5=Orifice/Grate** (Orifice Controls 0.24 cfs @ 11.12 fps)

**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC


NOAA 24-hr D 50-yr Rainfall=6.92"

Printed 9/25/2024

Page 151

**Pond 20P: Water Quality Basin #3.1**

Hydrograph



**New Conditions**

NOAA 24-hr D 50-yr Rainfall=6.92"

Prepared by Loureiro Engineering Assoc, Inc

Printed 9/25/2024

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

Page 152

**Summary for Pond 21P: Water Quality Basin #2**

Inflow Area = 542,887 sf, 2.45% Impervious, Inflow Depth = 1.45" for 50-yr event  
 Inflow = 7.49 cfs @ 12.70 hrs, Volume= 65,580 cf  
 Outflow = 1.37 cfs @ 15.41 hrs, Volume= 65,580 cf, Atten= 82%, Lag= 162.9 min  
 Discarded = 0.17 cfs @ 15.41 hrs, Volume= 15,166 cf  
 Primary = 1.20 cfs @ 15.41 hrs, Volume= 50,414 cf  
 Routed to Link 4L : West Wetlands (POC 1)

Routing by Stor-Ind method, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 Peak Elev= 24.27' @ 15.41 hrs Surf.Area= 14,279 sf Storage= 28,052 cf

Plug-Flow detention time= 319.5 min calculated for 65,573 cf (100% of inflow)  
 Center-of-Mass det. time= 319.6 min ( 1,259.2 - 939.6 )

Volume	Invert	Avail.Storage	Storage Description		
#1	22.00'	74,350 cf	<b>Custom Stage Data (Irregular)</b> Listed below (Recalc)		
Elevation (feet)	Surf.Area (sq-ft)	Perim. (feet)	Inc.Store (cubic-feet)	Cum.Store (cubic-feet)	Wet.Area (sq-ft)
22.00	10,550	552.0	0	0	10,550
23.00	12,152	546.0	11,342	11,342	11,309
24.00	13,826	570.0	12,980	24,322	13,512
25.00	15,572	594.0	14,690	39,012	15,810
26.00	17,930	618.0	16,737	55,749	18,203
27.00	19,280	642.0	18,601	74,350	20,691

Device	Routing	Invert	Outlet Devices
#1	Primary	22.00'	<b>24.0" Round Culvert</b> L= 56.0' Ke= 0.500 Inlet / Outlet Invert= 22.00' / 21.00' S= 0.0179 '/ Cc= 0.900 n= 0.013 Corrugated PE, smooth interior, Flow Area= 3.14 sf
#2	Device 1	26.80'	<b>48.0" W x 36.0" H Vert. Orifice/Grate X 2.00</b> C= 0.600 Limited to weir flow at low heads
#3	Discarded	22.00'	<b>0.500 in/hr Exfiltration over Surface area</b>
#4	Device 1	22.40'	<b>6.0" Vert. Orifice/Grate</b> C= 0.600 Limited to weir flow at low heads

**Discarded OutFlow** Max=0.17 cfs @ 15.41 hrs HW=24.27' (Free Discharge)  
 ↑**3=Exfiltration** (Exfiltration Controls 0.17 cfs)

**Primary OutFlow** Max=1.20 cfs @ 15.41 hrs HW=24.27' (Free Discharge)  
 ↑**1=Culvert** (Passes 1.20 cfs of 17.02 cfs potential flow)  
 ↑**2=Orifice/Grate** ( Controls 0.00 cfs)  
 ↑**4=Orifice/Grate** (Orifice Controls 1.20 cfs @ 6.12 fps)

**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC


NOAA 24-hr D 50-yr Rainfall=6.92"

Printed 9/25/2024

Page 153

**Pond 21P: Water Quality Basin #2**

Hydrograph



**New Conditions**

NOAA 24-hr D 50-yr Rainfall=6.92"

Prepared by Loureiro Engineering Assoc, Inc

Printed 9/25/2024

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

Page 154

**Summary for Pond 22P: Water Quality Basin #3.2**

Inflow Area = 150,383 sf, 12.20% Impervious, Inflow Depth = 2.64" for 50-yr event  
 Inflow = 7.19 cfs @ 12.27 hrs, Volume= 33,139 cf  
 Outflow = 1.47 cfs @ 13.16 hrs, Volume= 33,139 cf, Atten= 80%, Lag= 53.2 min  
 Discarded = 0.14 cfs @ 13.16 hrs, Volume= 9,050 cf  
 Primary = 1.32 cfs @ 13.16 hrs, Volume= 24,089 cf  
 Routed to Link 4L : West Wetlands (POC 1)

Routing by Stor-Ind method, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 Peak Elev= 37.76' @ 13.16 hrs Surf.Area= 5,127 sf Storage= 12,992 cf  
 Flood Elev= 39.00' Surf.Area= 6,400 sf Storage= 20,137 cf

Plug-Flow detention time= 276.2 min calculated for 33,139 cf (100% of inflow)  
 Center-of-Mass det. time= 276.1 min ( 1,150.7 - 874.5 )

Volume	Invert	Avail.Storage	Storage Description		
#1	34.00'	20,137 cf	<b>Custom Stage Data (Irregular)</b> Listed below (Recalc)		
Elevation (feet)	Surf.Area (sq-ft)	Perim. (feet)	Inc.Store (cubic-feet)	Cum.Store (cubic-feet)	Wet.Area (sq-ft)
34.00	1,960	236.0	0	0	1,960
35.00	2,704	260.0	2,322	2,322	2,939
36.00	3,520	284.0	3,103	5,425	4,013
37.00	4,408	308.0	3,956	9,381	5,182
38.00	5,368	332.0	4,880	14,261	6,445
39.00	6,400	356.0	5,876	20,137	7,804

Device	Routing	Invert	Outlet Devices
#1	Primary	34.00'	<b>24.0" Round Culvert</b> L= 838.0' Ke= 0.500 Inlet / Outlet Invert= 34.00' / 22.00' S= 0.0143 '/ Cc= 0.900 n= 0.013 Corrugated PE, smooth interior, Flow Area= 3.14 sf
#2	Device 1	38.50'	<b>48.0" W x 36.0" H Vert. Orifice/Grate X 2.00</b> C= 0.600 Limited to weir flow at low heads
#3	Discarded	34.00'	<b>0.500 in/hr Exfiltration over Wetted area</b> Conductivity to Groundwater Elevation = 32.00'
#4	Device 1	35.25'	<b>2.0" Vert. Orifice/Grate</b> C= 0.600 Limited to weir flow at low heads
#5	Device 1	36.00'	<b>6.0" Vert. Orifice/Grate</b> C= 0.600 Limited to weir flow at low heads

**Discarded OutFlow** Max=0.14 cfs @ 13.16 hrs HW=37.76' (Free Discharge)  
 ↑ **3=Exfiltration** ( Controls 0.14 cfs)

**Primary OutFlow** Max=1.32 cfs @ 13.16 hrs HW=37.76' (Free Discharge)  
 ↑ **1=Culvert** (Passes 1.32 cfs of 25.12 cfs potential flow)  
 ↑ **2=Orifice/Grate** ( Controls 0.00 cfs)  
 ↑ **4=Orifice/Grate** (Orifice Controls 0.16 cfs @ 7.50 fps)  
 ↑ **5=Orifice/Grate** (Orifice Controls 1.16 cfs @ 5.91 fps)



**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC


NOAA 24-hr D 50-yr Rainfall=6.92"

Printed 9/25/2024

Page 155

**Pond 22P: Water Quality Basin #3.2**

Hydrograph



**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 50-yr Rainfall=6.92"

Printed 9/25/2024

Page 156


**Summary for Link 2L: Northeast Wetland**

Inflow Area = 359,530 sf, 0.00% Impervious, Inflow Depth = 0.46" for 50-yr event  
Inflow = 1.22 cfs @ 12.42 hrs, Volume= 13,694 cf  
Primary = 1.22 cfs @ 12.42 hrs, Volume= 13,694 cf, Atten= 0%, Lag= 0.0 min  
Routed to Link 4L : West Wetlands (POC 1)

Primary outflow = Inflow, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs

**Link 2L: Northeast Wetland**

Hydrograph



**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 50-yr Rainfall=6.92"

Printed 9/25/2024

Page 157


**Summary for Link 3L: South Off-Site (POC 3)**

Inflow Area = 625,838 sf, 0.00% Impervious, Inflow Depth = 4.40" for 50-yr event  
Inflow = 33.40 cfs @ 12.53 hrs, Volume= 229,595 cf  
Primary = 33.40 cfs @ 12.53 hrs, Volume= 229,595 cf, Atten= 0%, Lag= 0.0 min

Primary outflow = Inflow, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs

**Link 3L: South Off-Site (POC 3)**

Hydrograph



**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 50-yr Rainfall=6.92"

Printed 9/25/2024

Page 158


**Summary for Link 4L: West Wetlands (POC 1)**

Inflow Area = 2,306,339 sf, 7.36% Impervious, Inflow Depth = 1.63" for 50-yr event  
Inflow = 22.29 cfs @ 13.11 hrs, Volume= 312,381 cf  
Primary = 22.29 cfs @ 13.11 hrs, Volume= 312,381 cf, Atten= 0%, Lag= 0.0 min

Primary outflow = Inflow, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs

**Link 4L: West Wetlands (POC 1)**

Hydrograph



**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 50-yr Rainfall=6.92"

Printed 9/25/2024

Page 159


**Summary for Link 5L: West Off-Site (POC 2)**

Inflow Area = 351,134 sf, 0.00% Impervious, Inflow Depth = 1.45" for 50-yr event  
Inflow = 6.16 cfs @ 12.46 hrs, Volume= 42,417 cf  
Primary = 6.16 cfs @ 12.46 hrs, Volume= 42,417 cf, Atten= 0%, Lag= 0.0 min

Primary outflow = Inflow, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs

**Link 5L: West Off-Site (POC 2)**

Hydrograph



## New Conditions

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 100-yr Rainfall=7.74"

Printed 9/25/2024

Page 160

Time span=0.00-96.00 hrs, dt=0.01 hrs, 9601 points  
Runoff by SCS TR-20 method, UH=SCS, Weighted-CN  
Reach routing by Stor-Ind+Trans method - Pond routing by Stor-Ind method

**Subcatchment1: Subcat 1** Runoff Area=121,732 sf 0.00% Impervious Runoff Depth=1.32"  
Flow Length=1,013' Tc=23.3 min CN=42 Runoff=1.93 cfs 13,381 cf

**Subcatchment2: Subcat 2** Runoff Area=150,383 sf 12.20% Impervious Runoff Depth=3.25"  
Flow Length=296' Tc=17.5 min UI Adjusted CN=61 Runoff=8.92 cfs 40,700 cf

**Subcatchment3: Subcat 3** Runoff Area=542,887 sf 2.45% Impervious Runoff Depth=1.89"  
Flow Length=936' Tc=44.3 min UI Adjusted CN=48 Runoff=10.40 cfs 85,652 cf

**Subcatchment4: Subcat 4** Runoff Area=480,934 sf 13.66% Impervious Runoff Depth=5.61"  
Flow Length=633' Tc=36.3 min UI Adjusted CN=82 Runoff=34.34 cfs 224,968 cf

**Subcatchment5: Subcat 5** Runoff Area=625,838 sf 0.00% Impervious Runoff Depth=5.15"  
Flow Length=1,037' Tc=40.7 min CN=78 Runoff=38.98 cfs 268,652 cf

**Subcatchment6: Subcat 6** Runoff Area=405,402 sf 16.44% Impervious Runoff Depth=5.04"  
Flow Length=280' Tc=29.1 min UI Adjusted CN=77 Runoff=29.46 cfs 170,147 cf

**Subcatchment7: Subcat 7** Runoff Area=351,134 sf 0.00% Impervious Runoff Depth=1.89"  
Flow Length=815' Tc=28.4 min CN=48 Runoff=8.53 cfs 55,399 cf

**Subcatchment8: Subcat 8** Runoff Area=109,129 sf 0.00% Impervious Runoff Depth=1.41"  
Flow Length=261' Slope=0.0150 '/' Tc=18.5 min CN=43 Runoff=2.16 cfs 12,838 cf

**Subcatchment9: Subcat 9** Runoff Area=209,524 sf 2.74% Impervious Runoff Depth=1.60"  
Flow Length=651' Tc=22.1 min UI Adjusted CN=45 Runoff=4.57 cfs 27,951 cf

**Subcatchment10: Subcat 10** Runoff Area=48,549 sf 0.00% Impervious Runoff Depth=1.51"  
Flow Length=335' Tc=16.8 min CN=44 Runoff=1.11 cfs 6,091 cf

**Subcatchment11: Subcat 11** Runoff Area=237,799 sf 0.00% Impervious Runoff Depth=0.36"  
Flow Length=138' Tc=17.2 min CN=30 Runoff=0.34 cfs 7,088 cf

**Pond 12P: Water Quality Basin #4** Peak Elev=27.23' Storage=98,492 cf Inflow=34.34 cfs 224,968 cf  
Discarded=0.80 cfs 80,493 cf Primary=17.68 cfs 144,475 cf Outflow=18.48 cfs 224,968 cf

**Pond 13P: Water Quality Basin #1** Peak Elev=15.09' Storage=10,927 cf Inflow=4.57 cfs 27,951 cf  
Discarded=0.13 cfs 10,822 cf Primary=0.63 cfs 17,129 cf Outflow=0.75 cfs 27,951 cf

**Pond 18P: Water Quality Basin #5** Peak Elev=21.30' Storage=2,809 cf Inflow=2.16 cfs 12,838 cf  
Discarded=0.03 cfs 2,047 cf Primary=0.76 cfs 10,791 cf Outflow=0.80 cfs 12,838 cf

**Pond 20P: Water Quality Basin #3.1** Peak Elev=22.62' Storage=74,968 cf Inflow=29.46 cfs 170,147 cf  
Discarded=0.61 cfs 60,891 cf Primary=13.04 cfs 109,256 cf Outflow=13.65 cfs 170,147 cf

**Pond 21P: Water Quality Basin #2** Peak Elev=25.02' Storage=39,346 cf Inflow=10.40 cfs 85,652 cf  
Discarded=0.18 cfs 16,928 cf Primary=1.46 cfs 68,724 cf Outflow=1.64 cfs 85,652 cf

**New Conditions**

NOAA 24-hr D 100-yr Rainfall=7.74"

Prepared by Loureiro Engineering Assoc, Inc

Printed 9/25/2024

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

Page 161

**Pond 22P: Water Quality Basin #3.2** Peak Elev=38.40' Storage=16,468 cf Inflow=8.92 cfs 40,700 cf  
Discarded=0.17 cfs 9,604 cf Primary=1.57 cfs 31,096 cf Outflow=1.74 cfs 40,700 cf

**Link 2L: Northeast Wetland** Inflow=2.02 cfs 20,469 cf  
Primary=2.02 cfs 20,469 cf

**Link 3L: South Off-Site (POC 3)** Inflow=38.98 cfs 268,652 cf  
Primary=38.98 cfs 268,652 cf

**Link 4L: West Wetlands (POC 1)** Inflow=35.89 cfs 408,031 cf  
Primary=35.89 cfs 408,031 cf

**Link 5L: West Off-Site (POC 2)** Inflow=8.53 cfs 55,399 cf  
Primary=8.53 cfs 55,399 cf

**Total Runoff Area = 3,283,311 sf Runoff Volume = 912,866 cf Average Runoff Depth = 3.34"**  
**94.83% Pervious = 3,113,537 sf 5.17% Impervious = 169,774 sf**

**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 100-yr Rainfall=7.74"

Printed 9/25/2024

Page 162

**Summary for Subcatchment 1: Subcat 1**

Runoff = 1.93 cfs @ 12.40 hrs, Volume= 13,381 cf, Depth= 1.32"  
 Routed to Link 2L : Northeast Wetland

Runoff by SCS TR-20 method, UH=SCS, Weighted-CN, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 NOAA 24-hr D 100-yr Rainfall=7.74"

Area (sf)	CN	Description
700	48	Brush, Good, HSG B
14,806	55	Woods, Good, HSG B
1,211	55	Woods, Good, HSG B
24	39	>75% Grass cover, Good, HSG A
1,022	72	Dirt roads, HSG A
9,987	30	Brush, Good, HSG A
13,422	30	Woods, Good, HSG A
21,799	77	Woods, Good, HSG D
58,761	30	Woods, Good, HSG A
121,732	42	Weighted Average
121,732	42	100.00% Pervious Area

Tc (min)	Length (feet)	Slope (ft/ft)	Velocity (ft/sec)	Capacity (cfs)	Description
13.3	100	0.2400	0.13		<b>Sheet Flow,</b> Woods: Dense underbrush n= 0.800 P2= 3.46"
10.0	913	0.0920	1.52		<b>Shallow Concentrated Flow,</b> Woodland Kv= 5.0 fps
23.3	1,013	Total			



**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC


NOAA 24-hr D 100-yr Rainfall=7.74"

Printed 9/25/2024

Page 163

**Subcatchment 1: Subcat 1**

Hydrograph



**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 100-yr Rainfall=7.74"

Printed 9/25/2024

Page 164

**Summary for Subcatchment 2: Subcat 2**

Runoff = 8.92 cfs @ 12.27 hrs, Volume= 40,700 cf, Depth= 3.25"

Routed to Pond 22P : Water Quality Basin #3.2

Runoff by SCS TR-20 method, UH=SCS, Weighted-CN, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 NOAA 24-hr D 100-yr Rainfall=7.74"

Area (sf)	CN	Adj	Description
72,676	39		>75% Grass cover, Good, HSG A
18,352	98		Unconnected pavement, HSG A
995	96		Gravel surface, HSG A
6	30		Woods, Good, HSG A
4,992	77		Woods, Good, HSG D
35,625	86		Woods/grass comb., Poor, HSG D
17,737	80		>75% Grass cover, Good, HSG D
150,383	64	61	Weighted Average, UI Adjusted
132,031	59	59	87.80% Pervious Area
18,352	98	98	12.20% Impervious Area
18,352			100.00% Unconnected

Tc (min)	Length (feet)	Slope (ft/ft)	Velocity (ft/sec)	Capacity (cfs)	Description
14.6	62	0.0730	0.07		<b>Sheet Flow, sheet</b> Woods: Dense underbrush n= 0.800 P2= 3.46"
2.0					<b>Direct Entry, rock crossing</b>
0.9	234	0.0100	4.26	17.02	<b>Channel Flow, swale</b> Area= 4.0 sf Perim= 8.0' r= 0.50' n= 0.022 Earth, clean & straight
17.5	296	Total			

**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC


NOAA 24-hr D 100-yr Rainfall=7.74"

Printed 9/25/2024

Page 165

**Subcatchment 2: Subcat 2**

Hydrograph



**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 100-yr Rainfall=7.74"

Printed 9/25/2024

Page 166

**Summary for Subcatchment 3: Subcat 3**

Runoff = 10.40 cfs @ 12.66 hrs, Volume= 85,652 cf, Depth= 1.89"

Routed to Pond 21P : Water Quality Basin #2

Runoff by SCS TR-20 method, UH=SCS, Weighted-CN, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 NOAA 24-hr D 100-yr Rainfall=7.74"

Area (sf)	CN	Adj	Description
185,176	39		>75% Grass cover, Good, HSG A
238,754	39		>75% Grass cover, Good, HSG A
15,049	96		Gravel surface, HSG A
13,325	98		Unconnected pavement, HSG D
55,139	80		>75% Grass cover, Good, HSG D
9,578	77		Woods, Good, HSG D
25,866	86		Woods/grass comb., Poor, HSG D
542,887	49	48	Weighted Average, UI Adjusted
529,562	48	48	97.55% Pervious Area
13,325	98	98	2.45% Impervious Area
13,325			100.00% Unconnected

Tc (min)	Length (feet)	Slope (ft/ft)	Velocity (ft/sec)	Capacity (cfs)	Description
2.0					<b>Direct Entry,</b>
28.7	100	0.0350	0.06		<b>Sheet Flow, sheet</b> Woods: Dense underbrush n= 0.800 P2= 3.46"
2.1	246	0.0813	2.00		<b>Shallow Concentrated Flow, scf</b> Short Grass Pasture Kv= 7.0 fps
11.5	590	0.0150	0.86		<b>Shallow Concentrated Flow, scf grass</b> Short Grass Pasture Kv= 7.0 fps
44.3	936	Total			

**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC


NOAA 24-hr D 100-yr Rainfall=7.74"

Printed 9/25/2024

Page 167

**Subcatchment 3: Subcat 3**

Hydrograph



**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc  
 HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 100-yr Rainfall=7.74"

Printed 9/25/2024

Page 168

**Summary for Subcatchment 4: Subcat 4**

Runoff = 34.34 cfs @ 12.47 hrs, Volume= 224,968 cf, Depth= 5.61"  
 Routed to Pond 12P : Water Quality Basin #4

Runoff by SCS TR-20 method, UH=SCS, Weighted-CN, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 NOAA 24-hr D 100-yr Rainfall=7.74"

Area (sf)	CN	Adj	Description
414	96		Gravel surface, HSG A
9,603	39		>75% Grass cover, Good, HSG A
0	77		Woods, Good, HSG D
0	77		Woods, Good, HSG D
2	77		Woods, Good, HSG D
5,250	77		Woods, Good, HSG D
0	77		Woods, Good, HSG D
23,224	77		Woods, Good, HSG D
249,238	80		>75% Grass cover, Good, HSG D
65,690	98		Unconnected pavement, HSG D
127,513	86		Woods/grass comb., Poor, HSG D
480,934	83	82	Weighted Average, UI Adjusted
415,244	81	81	86.34% Pervious Area
65,690	98	98	13.66% Impervious Area
65,690			100.00% Unconnected

Tc (min)	Length (feet)	Slope (ft/ft)	Velocity (ft/sec)	Capacity (cfs)	Description
30.6	100	0.0300	0.05		<b>Sheet Flow, sheet</b> Woods: Dense underbrush n= 0.800 P2= 3.46"
0.7	50	0.1988	1.11		<b>Shallow Concentrated Flow, scf</b> Forest w/Heavy Litter Kv= 2.5 fps
2.0					<b>Direct Entry, rock crossing</b>
3.0	483	0.1500	2.71		<b>Shallow Concentrated Flow, scf grass</b> Short Grass Pasture Kv= 7.0 fps
36.3	633	Total			

**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC


NOAA 24-hr D 100-yr Rainfall=7.74"

Printed 9/25/2024

Page 169

**Subcatchment 4: Subcat 4**

Hydrograph



**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc  
 HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 100-yr Rainfall=7.74"

Printed 9/25/2024

Page 170

**Summary for Subcatchment 5: Subcat 5**

Runoff = 38.98 cfs @ 12.53 hrs, Volume= 268,652 cf, Depth= 5.15"  
 Routed to Link 3L : South Off-Site (POC 3)

Runoff by SCS TR-20 method, UH=SCS, Weighted-CN, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 NOAA 24-hr D 100-yr Rainfall=7.74"

Area (sf)	CN	Description
0	98	Unconnected pavement, HSG D
14,987	73	Brush, Good, HSG D
1,504	91	Gravel roads, HSG D
39,327	91	Gravel roads, HSG D
18,528	91	Gravel roads, HSG D
2,922	89	Dirt roads, HSG D
2,214	73	Brush, Good, HSG D
7,635	77	Woods, Good, HSG D
137,134	77	Woods, Good, HSG D
10,652	77	Woods, Good, HSG D
291,847	77	Woods, Good, HSG D
34,529	77	Woods, Good, HSG D
23,786	77	Woods, Good, HSG D
1,988	73	Brush, Good, HSG D
357	91	Gravel roads, HSG D
38,427	73	Brush, Good, HSG D
625,838	78	Weighted Average
625,838	78	100.00% Pervious Area
0	98	0.00% Impervious Area
0		100.00% Unconnected

Tc (min)	Length (feet)	Slope (ft/ft)	Velocity (ft/sec)	Capacity (cfs)	Description
26.0	100	0.0450	0.06		<b>Sheet Flow, sheet</b> Woods: Dense underbrush n= 0.800 P2= 3.46"
6.1	225	0.0600	0.61		<b>Shallow Concentrated Flow, scf woods</b> Forest w/Heavy Litter Kv= 2.5 fps
0.7	112	0.1560	2.76		<b>Shallow Concentrated Flow, scfbrush</b> Short Grass Pasture Kv= 7.0 fps
0.5	140	0.0820	4.61		<b>Shallow Concentrated Flow, scf unpaved</b> Unpaved Kv= 16.1 fps
7.4	460	0.1740	1.04		<b>Shallow Concentrated Flow, scf woods</b> Forest w/Heavy Litter Kv= 2.5 fps
40.7	1,037	Total			



**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC


NOAA 24-hr D 100-yr Rainfall=7.74"

Printed 9/25/2024

Page 171

**Subcatchment 5: Subcat 5**

Hydrograph



**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc  
 HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 100-yr Rainfall=7.74"

Printed 9/25/2024

Page 172

**Summary for Subcatchment 6: Subcat 6**

Runoff = 29.46 cfs @ 12.39 hrs, Volume= 170,147 cf, Depth= 5.04"  
 Routed to Pond 20P : Water Quality Basin #3.1

Runoff by SCS TR-20 method, UH=SCS, Weighted-CN, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 NOAA 24-hr D 100-yr Rainfall=7.74"

Area (sf)	CN	Adj	Description
1,758	73		Brush, Good, HSG D
66,656	98		Unconnected pavement, HSG D
1,257	77		Woods, Good, HSG D
34,488	77		Woods, Good, HSG D
49,599	39		>75% Grass cover, Good, HSG A
43,447	77		Woods, Good, HSG D
129,391	86		Woods/grass comb., Poor, HSG D
28	73		Brush, Good, HSG D
78,778	80		>75% Grass cover, Good, HSG D
405,402	79	77	Weighted Average, UI Adjusted
338,746	76	76	83.56% Pervious Area
66,656	98	98	16.44% Impervious Area
66,656			100.00% Unconnected

Tc (min)	Length (feet)	Slope (ft/ft)	Velocity (ft/sec)	Capacity (cfs)	Description
24.9	100	0.0500	0.07		<b>Sheet Flow, sheet</b> Woods: Dense underbrush n= 0.800 P2= 3.46"
2.2	180	0.3000	1.37		<b>Shallow Concentrated Flow, scf</b> Forest w/Heavy Litter Kv= 2.5 fps
2.0					<b>Direct Entry, rock crossing</b>
29.1	280	Total			

**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC


NOAA 24-hr D 100-yr Rainfall=7.74"

Printed 9/25/2024

Page 173

**Subcatchment 6: Subcat 6**

Hydrograph



**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc  
 HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 100-yr Rainfall=7.74"

Printed 9/25/2024

Page 174

**Summary for Subcatchment 7: Subcat 7**

Runoff = 8.53 cfs @ 12.44 hrs, Volume= 55,399 cf, Depth= 1.89"  
 Routed to Link 5L : West Off-Site (POC 2)

Runoff by SCS TR-20 method, UH=SCS, Weighted-CN, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 NOAA 24-hr D 100-yr Rainfall=7.74"

Area (sf)	CN	Description
8,651	91	Gravel roads, HSG D
11,645	73	Brush, Good, HSG D
8,819	73	Brush, Good, HSG D
23	77	Woods, Good, HSG D
338	77	Woods, Good, HSG D
7	77	Woods, Good, HSG D
9,853	76	Gravel roads, HSG A
17,832	30	Brush, Good, HSG A
195,049	30	Woods, Good, HSG A
1,207	30	Woods, Good, HSG A
7,262	77	Woods, Good, HSG D
47,566	77	Woods, Good, HSG D
39,066	73	Brush, Good, HSG D
1	91	Gravel roads, HSG D
3,817	91	Gravel roads, HSG D
351,134	48	Weighted Average
351,134	48	100.00% Pervious Area

Tc (min)	Length (feet)	Slope (ft/ft)	Velocity (ft/sec)	Capacity (cfs)	Description
18.9	100	0.1000	0.09		<b>Sheet Flow, sheet</b> Woods: Dense underbrush n= 0.800 P2= 3.46"
9.5	715	0.2500	1.25		<b>Shallow Concentrated Flow, scf</b> Forest w/Heavy Litter Kv= 2.5 fps
28.4	815	Total			

**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC


NOAA 24-hr D 100-yr Rainfall=7.74"

Printed 9/25/2024

Page 175

**Subcatchment 7: Subcat 7**

Hydrograph



**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc  
 HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 100-yr Rainfall=7.74"

Printed 9/25/2024

Page 176

**Summary for Subcatchment 8: Subcat 8**

Runoff = 2.16 cfs @ 12.31 hrs, Volume= 12,838 cf, Depth= 1.41"  
 Routed to Pond 18P : Water Quality Basin #5


Runoff by SCS TR-20 method, UH=SCS, Weighted-CN, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 NOAA 24-hr D 100-yr Rainfall=7.74"

Area (sf)	CN	Description
8,265	96	Gravel surface, HSG A
10,542	39	>75% Grass cover, Good, HSG A
90,322	39	>75% Grass cover, Good, HSG A
109,129	43	Weighted Average
109,129	43	100.00% Pervious Area

Tc (min)	Length (feet)	Slope (ft/ft)	Velocity (ft/sec)	Capacity (cfs)	Description
15.4	100	0.0150	0.11		<b>Sheet Flow, sheet</b>
					Grass: Dense n= 0.240 P2= 3.46"
3.1	161	0.0150	0.86		<b>Shallow Concentrated Flow, scf</b>
					Short Grass Pasture Kv= 7.0 fps
18.5	261	Total			

**Subcatchment 8: Subcat 8**

Hydrograph



**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 100-yr Rainfall=7.74"

Printed 9/25/2024

Page 177

**Summary for Subcatchment 9: Subcat 9**

Runoff = 4.57 cfs @ 12.36 hrs, Volume= 27,951 cf, Depth= 1.60"

Routed to Pond 13P : Water Quality Basin #1

Runoff by SCS TR-20 method, UH=SCS, Weighted-CN, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 NOAA 24-hr D 100-yr Rainfall=7.74"

Area (sf)	CN	Adj	Description
5,751	98		Unconnected pavement, HSG A
10,904	96		Gravel surface, HSG A
181,704	39		>75% Grass cover, Good, HSG A
11,165	86		Woods/grass comb., Poor, HSG D
209,524	46	45	Weighted Average, UI Adjusted
203,773	45	45	97.26% Pervious Area
5,751	98	98	2.74% Impervious Area
5,751			100.00% Unconnected

Tc (min)	Length (feet)	Slope (ft/ft)	Velocity (ft/sec)	Capacity (cfs)	Description
15.4	100	0.0150	0.11		<b>Sheet Flow, sheet</b> Grass: Dense n= 0.240 P2= 3.46"
5.7	291	0.0150	0.86		<b>Shallow Concentrated Flow, scf</b> Short Grass Pasture Kv= 7.0 fps
1.0	260	0.0100	4.26	17.02	<b>Channel Flow, swale</b> Area= 4.0 sf Perim= 8.0' r= 0.50' n= 0.022 Earth, clean & straight
22.1	651	Total			

**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC


NOAA 24-hr D 100-yr Rainfall=7.74"

Printed 9/25/2024

Page 178

**Subcatchment 9: Subcat 9**

Hydrograph





**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 100-yr Rainfall=7.74"

Printed 9/25/2024

Page 179

**Summary for Subcatchment 10: Subcat 10**

Runoff = 1.11 cfs @ 12.29 hrs, Volume= 6,091 cf, Depth= 1.51"

Routed to Link 4L : West Wetlands (POC 1)


Runoff by SCS TR-20 method, UH=SCS, Weighted-CN, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 NOAA 24-hr D 100-yr Rainfall=7.74"

Area (sf)	CN	Description
15,200	39	>75% Grass cover, Good, HSG A
29,317	39	>75% Grass cover, Good, HSG A
4,025	96	Gravel surface, HSG A
5	30	Woods, Good, HSG A
1	30	Woods, Good, HSG A
2	30	Woods, Good, HSG A
0	30	Woods, Good, HSG A
48,549	44	Weighted Average
48,549	44	100.00% Pervious Area

Tc (min)	Length (feet)	Slope (ft/ft)	Velocity (ft/sec)	Capacity (cfs)	Description
15.4	100	0.0150	0.11		<b>Sheet Flow, sheet</b> Grass: Dense n= 0.240 P2= 3.46"
1.4	235	0.1500	2.71		<b>Shallow Concentrated Flow, scf</b> Short Grass Pasture Kv= 7.0 fps
16.8	335	Total			

**Subcatchment 10: Subcat 10**

Hydrograph



**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 100-yr Rainfall=7.74"

Printed 9/25/2024

Page 180

**Summary for Subcatchment 11: Subcat 11**

Runoff = 0.34 cfs @ 13.05 hrs, Volume= 7,088 cf, Depth= 0.36"  
 Routed to Link 2L : Northeast Wetland

Runoff by SCS TR-20 method, UH=SCS, Weighted-CN, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 NOAA 24-hr D 100-yr Rainfall=7.74"

Area (sf)	CN	Description
3,394	48	Brush, Good, HSG B
72	39	>75% Grass cover, Good, HSG A
3	96	Gravel surface, HSG A
29	39	>75% Grass cover, Good, HSG A
24	39	>75% Grass cover, Good, HSG A
48,779	30	Brush, Good, HSG A
185,489	30	Woods, Good, HSG A
8	30	Woods, Good, HSG A
237,799	30	Weighted Average
237,799	30	100.00% Pervious Area

Tc (min)	Length (feet)	Slope (ft/ft)	Velocity (ft/sec)	Capacity (cfs)	Description
16.5	100	0.1400	0.10		<b>Sheet Flow, sheet</b>
					Woods: Dense underbrush n= 0.800 P2= 3.46"
0.7	38	0.1369	0.93		<b>Shallow Concentrated Flow, scf</b>
					Forest w/Heavy Litter Kv= 2.5 fps
17.2	138	Total			

**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC


NOAA 24-hr D 100-yr Rainfall=7.74"

Printed 9/25/2024

Page 181

**Subcatchment 11: Subcat 11**

Hydrograph



**New Conditions**

NOAA 24-hr D 100-yr Rainfall=7.74"

Prepared by Loureiro Engineering Assoc, Inc

Printed 9/25/2024

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

Page 182

**Summary for Pond 12P: Water Quality Basin #4**

Inflow Area = 480,934 sf, 13.66% Impervious, Inflow Depth = 5.61" for 100-yr event  
 Inflow = 34.34 cfs @ 12.47 hrs, Volume= 224,968 cf  
 Outflow = 18.48 cfs @ 12.92 hrs, Volume= 224,968 cf, Atten= 46%, Lag= 27.1 min  
 Discarded = 0.80 cfs @ 12.92 hrs, Volume= 80,493 cf  
 Primary = 17.68 cfs @ 12.92 hrs, Volume= 144,475 cf  
 Routed to Link 4L : West Wetlands (POC 1)

Routing by Stor-Ind method, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 Peak Elev= 27.23' @ 12.92 hrs Surf.Area= 21,303 sf Storage= 98,492 cf

Plug-Flow detention time= 534.6 min calculated for 224,945 cf (100% of inflow)  
 Center-of-Mass det. time= 534.8 min ( 1,368.7 - 833.9 )

Volume	Invert	Avail.Storage	Storage Description		
#1	21.00'	115,489 cf	<b>Custom Stage Data (Irregular)</b> Listed below (Recalc)		
Elevation (feet)	Surf.Area (sq-ft)	Perim. (feet)	Inc.Store (cubic-feet)	Cum.Store (cubic-feet)	Wet.Area (sq-ft)
21.00	10,788	488.0	0	0	10,788
22.00	12,288	512.0	11,530	11,530	12,762
23.00	13,860	536.0	13,066	24,596	14,831
24.00	15,504	560.0	14,674	39,270	16,995
25.00	17,220	584.0	16,354	55,625	19,253
26.00	19,008	608.0	18,107	73,731	21,607
27.00	20,868	632.0	19,931	93,662	24,055
28.00	22,800	656.0	21,827	115,489	26,598

Device	Routing	Invert	Outlet Devices	
#1	Primary	21.00'	<b>30.0" Round Culvert</b> L= 184.0' Ke= 0.500 Inlet / Outlet Invert= 21.00' / 19.10' S= 0.0103 '/' Cc= 0.900 n= 0.012 Corrugated PP, smooth interior, Flow Area= 4.91 sf	
#2	Device 1	26.50'	<b>48.0" W x 36.0" H Vert. Orifice/Grate X 2.00</b> C= 0.600 Limited to weir flow at low heads	
#3	Discarded	21.00'	<b>0.500 in/hr Exfiltration over Wetted area</b> Conductivity to Groundwater Elevation = 19.00'	
#4	Device 1	21.30'	<b>2.0" Vert. Orifice/Grate</b> C= 0.600 Limited to weir flow at low heads	
#5	Device 1	24.70'	<b>6.0" Vert. Orifice/Grate</b> C= 0.600 Limited to weir flow at low heads	

**Discarded OutFlow** Max=0.80 cfs @ 12.92 hrs HW=27.23' (Free Discharge)  
 ↳ **3=Exfiltration** ( Controls 0.80 cfs)

**Primary OutFlow** Max=17.66 cfs @ 12.92 hrs HW=27.23' (Free Discharge)  
 ↳ **1=Culvert** (Passes 17.66 cfs of 52.74 cfs potential flow)  
     ↳ **2=Orifice/Grate** (Orifice Controls 15.98 cfs @ 2.74 fps)  
     ↳ **4=Orifice/Grate** (Orifice Controls 0.25 cfs @ 11.64 fps)  
     ↳ **5=Orifice/Grate** (Orifice Controls 1.43 cfs @ 7.27 fps)

**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC


NOAA 24-hr D 100-yr Rainfall=7.74"

Printed 9/25/2024

Page 183

**Pond 12P: Water Quality Basin #4**

Hydrograph



**New Conditions**

NOAA 24-hr D 100-yr Rainfall=7.74"

Prepared by Loureiro Engineering Assoc, Inc

Printed 9/25/2024

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

Page 184

**Summary for Pond 13P: Water Quality Basin #1**

Inflow Area = 209,524 sf, 2.74% Impervious, Inflow Depth = 1.60" for 100-yr event  
 Inflow = 4.57 cfs @ 12.36 hrs, Volume= 27,951 cf  
 Outflow = 0.75 cfs @ 14.28 hrs, Volume= 27,951 cf, Atten= 84%, Lag= 115.5 min  
 Discarded = 0.13 cfs @ 14.28 hrs, Volume= 10,822 cf  
 Primary = 0.63 cfs @ 14.28 hrs, Volume= 17,129 cf  
 Routed to Link 4L : West Wetlands (POC 1)

Routing by Stor-Ind method, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 Peak Elev= 15.09' @ 14.28 hrs Surf.Area= 10,853 sf Storage= 10,927 cf

Plug-Flow detention time= 294.6 min calculated for 27,951 cf (100% of inflow)  
 Center-of-Mass det. time= 294.5 min ( 1,214.4 - 919.9 )

Volume	Invert	Avail.Storage	Storage Description		
#1	14.00'	66,060 cf	<b>Custom Stage Data (Irregular)</b> Listed below (Recalc)		
Elevation (feet)	Surf.Area (sq-ft)	Perim. (feet)	Inc.Store (cubic-feet)	Cum.Store (cubic-feet)	Wet.Area (sq-ft)
14.00	9,180	498.0	0	0	9,180
15.00	10,710	522.0	9,935	9,935	11,194
16.00	12,312	546.0	11,502	21,437	13,302
17.00	13,986	570.0	13,140	34,577	15,505
18.00	15,732	594.0	14,850	49,427	17,803
19.00	17,550	618.0	16,633	66,060	20,196

Device	Routing	Invert	Outlet Devices
#1	Primary	14.00'	<b>30.0" Round Culvert</b> L= 107.0' Ke= 0.500 Inlet / Outlet Invert= 14.00' / 12.50' S= 0.0140 '/ Cc= 0.900 n= 0.012 Corrugated PP, smooth interior, Flow Area= 4.91 sf
#2	Device 1	18.00'	<b>48.0" W x 36.0" H Vert. Orifice/Grate X 2.00</b> C= 0.600 Limited to weir flow at low heads
#3	Discarded	14.00'	<b>0.500 in/hr Exfiltration over Surface area</b>
#4	Device 1	14.40'	<b>6.0" Vert. Orifice/Grate</b> C= 0.600 Limited to weir flow at low heads

**Discarded OutFlow** Max=0.13 cfs @ 14.28 hrs HW=15.09' (Free Discharge)  
 ↳ **3=Exfiltration** (Exfiltration Controls 0.13 cfs)

**Primary OutFlow** Max=0.63 cfs @ 14.28 hrs HW=15.09' (Free Discharge)  
 ↳ **1=Culvert** (Passes 0.63 cfs of 7.33 cfs potential flow)  
 ↳ **2=Orifice/Grate** ( Controls 0.00 cfs)  
 ↳ **4=Orifice/Grate** (Orifice Controls 0.63 cfs @ 3.20 fps)

**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC


NOAA 24-hr D 100-yr Rainfall=7.74"

Printed 9/25/2024

Page 185

**Pond 13P: Water Quality Basin #1**

Hydrograph



**New Conditions**

NOAA 24-hr D 100-yr Rainfall=7.74"

Prepared by Loureiro Engineering Assoc, Inc

Printed 9/25/2024

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

Page 186

**Summary for Pond 18P: Water Quality Basin #5**

Inflow Area = 109,129 sf, 0.00% Impervious, Inflow Depth = 1.41" for 100-yr event  
 Inflow = 2.16 cfs @ 12.31 hrs, Volume= 12,838 cf  
 Outflow = 0.80 cfs @ 12.95 hrs, Volume= 12,838 cf, Atten= 63%, Lag= 38.3 min  
 Discarded = 0.03 cfs @ 12.95 hrs, Volume= 2,047 cf  
 Primary = 0.76 cfs @ 12.95 hrs, Volume= 10,791 cf  
 Routed to Link 4L : West Wetlands (POC 1)

Routing by Stor-Ind method, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 Peak Elev= 21.30' @ 12.95 hrs Surf.Area= 2,608 sf Storage= 2,809 cf

Plug-Flow detention time= 106.5 min calculated for 12,836 cf (100% of inflow)  
 Center-of-Mass det. time= 106.6 min ( 1,031.6 - 925.0 )

Volume	Invert	Avail.Storage	Storage Description			
#1	20.00'	18,040 cf	<b>Custom Stage Data (Irregular)</b> Listed below (Recalc)			
Elevation (feet)	Surf.Area (sq-ft)	Perim. (feet)	Inc.Store (cubic-feet)	Cum.Store (cubic-feet)	Wet.Area (sq-ft)	
20.00	1,720	212.0	0	0	1,720	
21.00	2,392	236.0	2,047	2,047	2,604	
22.00	3,136	260.0	2,756	4,802	3,584	
23.00	3,952	284.0	3,536	8,339	4,658	
24.00	4,840	308.0	4,389	12,727	5,826	
25.00	5,800	332.0	5,313	18,040	7,090	

Device	Routing	Invert	Outlet Devices
#1	Primary	20.00'	<b>18.0" Round Culvert</b> L= 25.0' Ke= 0.500 Inlet / Outlet Invert= 20.00' / 19.50' S= 0.0200 '/' Cc= 0.900 n= 0.013 Corrugated PE, smooth interior, Flow Area= 1.77 sf
#2	Device 1	24.00'	<b>48.0" W x 36.0" H Vert. Orifice/Grate X 2.00</b> C= 0.600 Limited to weir flow at low heads
#3	Discarded	20.00'	<b>0.500 in/hr Exfiltration over Surface area</b>
#4	Device 1	20.40'	<b>6.0" Vert. Orifice/Grate</b> C= 0.600 Limited to weir flow at low heads

**Discarded OutFlow** Max=0.03 cfs @ 12.95 hrs HW=21.30' (Free Discharge)  
 ↑ **3=Exfiltration** (Exfiltration Controls 0.03 cfs)

**Primary OutFlow** Max=0.77 cfs @ 12.95 hrs HW=21.30' (Free Discharge)  
 ↑ **1=Culvert** (Passes 0.77 cfs of 6.35 cfs potential flow)  
 ↑ **2=Orifice/Grate** ( Controls 0.00 cfs)  
 ↑ **4=Orifice/Grate** (Orifice Controls 0.77 cfs @ 3.90 fps)



**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC


NOAA 24-hr D 100-yr Rainfall=7.74"

Printed 9/25/2024

Page 187

**Pond 18P: Water Quality Basin #5**

Hydrograph



**New Conditions**

NOAA 24-hr D 100-yr Rainfall=7.74"

Prepared by Loureiro Engineering Assoc, Inc

Printed 9/25/2024

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

Page 188

**Summary for Pond 20P: Water Quality Basin #3.1**

Inflow Area = 405,402 sf, 16.44% Impervious, Inflow Depth = 5.04" for 100-yr event  
 Inflow = 29.46 cfs @ 12.39 hrs, Volume= 170,147 cf  
 Outflow = 13.65 cfs @ 12.85 hrs, Volume= 170,147 cf, Atten= 54%, Lag= 27.1 min  
 Discarded = 0.61 cfs @ 12.85 hrs, Volume= 60,891 cf  
 Primary = 13.04 cfs @ 12.85 hrs, Volume= 109,256 cf  
 Routed to Link 4L : West Wetlands (POC 1)

Routing by Stor-Ind method, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 Peak Elev= 22.62' @ 12.85 hrs Surf.Area= 16,846 sf Storage= 74,968 cf

Plug-Flow detention time= 574.7 min calculated for 170,129 cf (100% of inflow)  
 Center-of-Mass det. time= 575.0 min ( 1,415.3 - 840.3 )

Volume	Invert	Avail.Storage	Storage Description			
#1	16.00'	81,518 cf	<b>Custom Stage Data (Irregular)</b> Listed below (Recalc)			
Elevation (feet)	Surf.Area (sq-ft)	Perim. (feet)	Inc.Store (cubic-feet)	Cum.Store (cubic-feet)	Wet.Area (sq-ft)	
16.00	6,336	450.0	0	0	6,336	
17.00	7,722	474.0	7,018	7,018	8,160	
18.00	9,180	498.0	8,440	15,458	10,079	
19.00	10,710	522.0	9,935	25,393	12,093	
20.00	12,312	546.0	11,502	36,895	14,201	
21.00	13,986	570.0	13,140	50,035	16,405	
22.00	15,732	594.0	14,850	64,886	18,703	
23.00	17,550	618.0	16,633	81,518	21,095	

Device	Routing	Invert	Outlet Devices	
#1	Primary	16.00'	<b>30.0" Round Culvert</b> L= 202.0' Ke= 0.500 Inlet / Outlet Invert= 16.00' / 13.80' S= 0.0109 '/' Cc= 0.900 n= 0.013 Corrugated PE, smooth interior, Flow Area= 4.91 sf	
#2	Device 1	22.00'	<b>48.0" W x 36.0" H Vert. Orifice/Grate X 2.00</b> C= 0.600 Limited to weir flow at low heads	
#3	Discarded	16.00'	<b>0.500 in/hr Exfiltration over Wetted area</b> Conductivity to Groundwater Elevation = 14.00'	
#4	Device 1	16.50'	<b>2.0" Vert. Orifice/Grate</b> C= 0.600 Limited to weir flow at low heads	
#5	Device 1	17.00'	<b>2.0" Vert. Orifice/Grate</b> C= 0.600 Limited to weir flow at low heads	

**Discarded OutFlow** Max=0.61 cfs @ 12.85 hrs HW=22.62' (Free Discharge)  
 ↳ **3=Exfiltration** ( Controls 0.61 cfs)

**Primary OutFlow** Max=13.01 cfs @ 12.85 hrs HW=22.62' (Free Discharge)  
 ↳ **1=Culvert** (Passes 13.01 cfs of 53.94 cfs potential flow)  
 ↳ **2=Orifice/Grate** (Orifice Controls 12.51 cfs @ 2.53 fps)  
 ↳ **4=Orifice/Grate** (Orifice Controls 0.26 cfs @ 11.83 fps)  
 ↳ **5=Orifice/Grate** (Orifice Controls 0.25 cfs @ 11.33 fps)

**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC


NOAA 24-hr D 100-yr Rainfall=7.74"

Printed 9/25/2024

Page 189

**Pond 20P: Water Quality Basin #3.1**

Hydrograph



**New Conditions**

NOAA 24-hr D 100-yr Rainfall=7.74"

Prepared by Loureiro Engineering Assoc, Inc

Printed 9/25/2024

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

Page 190

**Summary for Pond 21P: Water Quality Basin #2**

Inflow Area = 542,887 sf, 2.45% Impervious, Inflow Depth = 1.89" for 100-yr event  
 Inflow = 10.40 cfs @ 12.66 hrs, Volume= 85,652 cf  
 Outflow = 1.64 cfs @ 15.53 hrs, Volume= 85,652 cf, Atten= 84%, Lag= 172.2 min  
 Discarded = 0.18 cfs @ 15.53 hrs, Volume= 16,928 cf  
 Primary = 1.46 cfs @ 15.53 hrs, Volume= 68,724 cf  
 Routed to Link 4L : West Wetlands (POC 1)

Routing by Stor-Ind method, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 Peak Elev= 25.02' @ 15.53 hrs Surf.Area= 15,621 sf Storage= 39,346 cf

Plug-Flow detention time= 354.2 min calculated for 85,652 cf (100% of inflow)  
 Center-of-Mass det. time= 354.1 min ( 1,283.4 - 929.3 )

Volume	Invert	Avail.Storage	Storage Description		
#1	22.00'	74,350 cf	<b>Custom Stage Data (Irregular)</b> Listed below (Recalc)		
Elevation (feet)	Surf.Area (sq-ft)	Perim. (feet)	Inc.Store (cubic-feet)	Cum.Store (cubic-feet)	Wet.Area (sq-ft)
22.00	10,550	552.0	0	0	10,550
23.00	12,152	546.0	11,342	11,342	11,309
24.00	13,826	570.0	12,980	24,322	13,512
25.00	15,572	594.0	14,690	39,012	15,810
26.00	17,930	618.0	16,737	55,749	18,203
27.00	19,280	642.0	18,601	74,350	20,691

Device	Routing	Invert	Outlet Devices
#1	Primary	22.00'	<b>24.0" Round Culvert</b> L= 56.0' Ke= 0.500 Inlet / Outlet Invert= 22.00' / 21.00' S= 0.0179 '/ Cc= 0.900 n= 0.013 Corrugated PE, smooth interior, Flow Area= 3.14 sf
#2	Device 1	26.80'	<b>48.0" W x 36.0" H Vert. Orifice/Grate X 2.00</b> C= 0.600 Limited to weir flow at low heads
#3	Discarded	22.00'	<b>0.500 in/hr Exfiltration over Surface area</b>
#4	Device 1	22.40'	<b>6.0" Vert. Orifice/Grate</b> C= 0.600 Limited to weir flow at low heads

**Discarded OutFlow** Max=0.18 cfs @ 15.53 hrs HW=25.02' (Free Discharge)  
 ↑ **3=Exfiltration** (Exfiltration Controls 0.18 cfs)

**Primary OutFlow** Max=1.46 cfs @ 15.53 hrs HW=25.02' (Free Discharge)  
 ↑ **1=Culvert** (Passes 1.46 cfs of 21.51 cfs potential flow)  
 ↑ **2=Orifice/Grate** ( Controls 0.00 cfs)  
 ↑ **4=Orifice/Grate** (Orifice Controls 1.46 cfs @ 7.41 fps)

**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC


NOAA 24-hr D 100-yr Rainfall=7.74"

Printed 9/25/2024

Page 191

**Pond 21P: Water Quality Basin #2**

Hydrograph



**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 100-yr Rainfall=7.74"

Printed 9/25/2024

Page 192

**Summary for Pond 22P: Water Quality Basin #3.2**

Inflow Area = 150,383 sf, 12.20% Impervious, Inflow Depth = 3.25" for 100-yr event  
 Inflow = 8.92 cfs @ 12.27 hrs, Volume= 40,700 cf  
 Outflow = 1.74 cfs @ 13.17 hrs, Volume= 40,700 cf, Atten= 81%, Lag= 54.0 min  
 Discarded = 0.17 cfs @ 13.17 hrs, Volume= 9,604 cf  
 Primary = 1.57 cfs @ 13.17 hrs, Volume= 31,096 cf  
 Routed to Link 4L : West Wetlands (POC 1)

Routing by Stor-Ind method, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs  
 Peak Elev= 38.40' @ 13.17 hrs Surf.Area= 5,766 sf Storage= 16,468 cf  
 Flood Elev= 39.00' Surf.Area= 6,400 sf Storage= 20,137 cf

Plug-Flow detention time= 249.4 min calculated for 40,696 cf (100% of inflow)  
 Center-of-Mass det. time= 249.6 min ( 1,117.5 - 867.8 )

Volume	Invert	Avail.Storage	Storage Description			
#1	34.00'	20,137 cf	<b>Custom Stage Data (Irregular)</b> Listed below (Recalc)			
Elevation (feet)	Surf.Area (sq-ft)	Perim. (feet)	Inc.Store (cubic-feet)	Cum.Store (cubic-feet)	Wet.Area (sq-ft)	
34.00	1,960	236.0	0	0	1,960	
35.00	2,704	260.0	2,322	2,322	2,939	
36.00	3,520	284.0	3,103	5,425	4,013	
37.00	4,408	308.0	3,956	9,381	5,182	
38.00	5,368	332.0	4,880	14,261	6,445	
39.00	6,400	356.0	5,876	20,137	7,804	

Device	Routing	Invert	Outlet Devices	
#1	Primary	34.00'	<b>24.0" Round Culvert</b> L= 838.0' Ke= 0.500 Inlet / Outlet Invert= 34.00' / 22.00' S= 0.0143 '/ Cc= 0.900 n= 0.013 Corrugated PE, smooth interior, Flow Area= 3.14 sf	
#2	Device 1	38.50'	<b>48.0" W x 36.0" H Vert. Orifice/Grate X 2.00</b> C= 0.600 Limited to weir flow at low heads	
#3	Discarded	34.00'	<b>0.500 in/hr Exfiltration over Wetted area</b> Conductivity to Groundwater Elevation = 32.00'	
#4	Device 1	35.25'	<b>2.0" Vert. Orifice/Grate</b> C= 0.600 Limited to weir flow at low heads	
#5	Device 1	36.00'	<b>6.0" Vert. Orifice/Grate</b> C= 0.600 Limited to weir flow at low heads	

**Discarded OutFlow** Max=0.17 cfs @ 13.17 hrs HW=38.40' (Free Discharge)  
 ↳ **3=Exfiltration** ( Controls 0.17 cfs)

**Primary OutFlow** Max=1.57 cfs @ 13.17 hrs HW=38.40' (Free Discharge)  
 ↳ **1=Culvert** (Passes 1.57 cfs of 27.68 cfs potential flow)  
 ↳ **2=Orifice/Grate** ( Controls 0.00 cfs)  
 ↳ **4=Orifice/Grate** (Orifice Controls 0.18 cfs @ 8.43 fps)  
 ↳ **5=Orifice/Grate** (Orifice Controls 1.39 cfs @ 7.05 fps)

**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC


NOAA 24-hr D 100-yr Rainfall=7.74"

Printed 9/25/2024

Page 193

**Pond 22P: Water Quality Basin #3.2**

Hydrograph



**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 100-yr Rainfall=7.74"

Printed 9/25/2024

Page 194


**Summary for Link 2L: Northeast Wetland**

Inflow Area = 359,530 sf, 0.00% Impervious, Inflow Depth = 0.68" for 100-yr event  
Inflow = 2.02 cfs @ 12.42 hrs, Volume= 20,469 cf  
Primary = 2.02 cfs @ 12.42 hrs, Volume= 20,469 cf, Atten= 0%, Lag= 0.0 min  
Routed to Link 4L : West Wetlands (POC 1)

Primary outflow = Inflow, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs

**Link 2L: Northeast Wetland**

Hydrograph





**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 100-yr Rainfall=7.74"

Printed 9/25/2024

Page 195


**Summary for Link 3L: South Off-Site (POC 3)**

Inflow Area = 625,838 sf, 0.00% Impervious, Inflow Depth = 5.15" for 100-yr event  
Inflow = 38.98 cfs @ 12.53 hrs, Volume= 268,652 cf  
Primary = 38.98 cfs @ 12.53 hrs, Volume= 268,652 cf, Atten= 0%, Lag= 0.0 min

Primary outflow = Inflow, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs

**Link 3L: South Off-Site (POC 3)**

Hydrograph



**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 100-yr Rainfall=7.74"

Printed 9/25/2024

Page 196


**Summary for Link 4L: West Wetlands (POC 1)**

Inflow Area = 2,306,339 sf, 7.36% Impervious, Inflow Depth = 2.12" for 100-yr event  
Inflow = 35.89 cfs @ 12.89 hrs, Volume= 408,031 cf  
Primary = 35.89 cfs @ 12.89 hrs, Volume= 408,031 cf, Atten= 0%, Lag= 0.0 min

Primary outflow = Inflow, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs

**Link 4L: West Wetlands (POC 1)**

Hydrograph



**New Conditions**

Prepared by Loureiro Engineering Assoc, Inc

HydroCAD® 10.20-2g s/n 06006 © 2022 HydroCAD Software Solutions LLC

NOAA 24-hr D 100-yr Rainfall=7.74"

Printed 9/25/2024

Page 197


**Summary for Link 5L: West Off-Site (POC 2)**

Inflow Area = 351,134 sf, 0.00% Impervious, Inflow Depth = 1.89" for 100-yr event  
Inflow = 8.53 cfs @ 12.44 hrs, Volume= 55,399 cf  
Primary = 8.53 cfs @ 12.44 hrs, Volume= 55,399 cf, Atten= 0%, Lag= 0.0 min

Primary outflow = Inflow, Time Span= 0.00-96.00 hrs, dt= 0.01 hrs

**Link 5L: West Off-Site (POC 2)**

Hydrograph



## **APPENDIX E**

### **Water Quality Volume and Water Quality Flow Calculations**

## Water Quality Volume and Water Quality Flow Worksheet

Watershed: Developed Site (DA-2, DA-3, DA-4, DA-6, DA-8, DA-9, DA-10)  
 Condition: Post-Construction


**Water Quality Volume**

Design Precipitation, P:	1.3	<i>in</i>
Percent Impervious Cover, I:	0%	
Volumetric Runoff Coefficient, R:	0.050	
Area, A:	44.69	acres
Water Quality Volume, WQV:	<b>10,545</b>	C.F.

**Water Quality Flow**

Runoff Depth, Q:	0.065	<i>in</i>
Runoff Curve Number, CN:	72	
Time of Concentration, T <sub>c</sub> : (>=10 min)	10.0	<i>min</i>
Time of Concentration, T <sub>c</sub> :	0.167	<i>hr</i>
Initial Abstraction, I <sub>a</sub> :	0.778	<i>in</i>
I <sub>a</sub> /P:	0.598461538	
Unit Peak Discharge, q <sub>u</sub> :	400	<i>csm/in</i> (from Exhibit 4-111 below)
Area, A:	0.06983	<i>mi</i> <sup>2</sup>
Water Quality Flow, WQF:	<b>1.82</b>	<i>cfs</i>

**Exhibit 4-111 Unit peak discharge (q<sub>u</sub>) for NRCS (SCS) type III rainfall distribution**



## Water Quality Volume and Water Quality Flow Worksheet

Watershed: 

DA 2
------

Condition: 

Post-Construction
-------------------


**Water Quality Volume**

Design Precipitation, P:	1.3	in
Percent Impervious Cover, I:	0%	
Volumetric Runoff Coefficient, R:	0.050	
Area, A:	3.45	acres
Water Quality Volume, WQV:	<b>814</b>	C.F.

**Water Quality Flow**

Runoff Depth, Q:	0.065	in
Runoff Curve Number, CN:	72	
Time of Concentration, T <sub>c</sub> : (>=10 min)	17.5	min
Time of Concentration, T <sub>c</sub> :	0.292	hr
Initial Abstraction, I <sub>a</sub> :	0.778	in
I <sub>a</sub> /P:	0.598461538	
Unit Peak Discharge, q <sub>u</sub> :	250	csm/in (from Exhibit 4-111 below)
Area, A:	0.00539	mi <sup>2</sup>
Water Quality Flow, WQF:	<b>0.09</b>	cfs

**Exhibit 4-111 Unit peak discharge (q<sub>u</sub>) for NRCS (SCS) type III rainfall distribution**



## Water Quality Volume and Water Quality Flow Worksheet

Watershed: 

DA 3
------

Condition: 

Post-Construction
-------------------


**Water Quality Volume**

Design Precipitation, P:	1.3	in
Percent Impervious Cover, I:	0%	
Volumetric Runoff Coefficient, R:	0.050	
Area, A:	12.46	acres
Water Quality Volume, WQV:	<b>2,941</b>	C.F.

**Water Quality Flow**

Runoff Depth, Q:	0.065	in
Runoff Curve Number, CN:	72	
Time of Concentration, T <sub>c</sub> : (>=10 min)	10.0	min
Time of Concentration, T <sub>c</sub> :	0.167	hr
Initial Abstraction, I <sub>a</sub> :	0.778	in
I <sub>a</sub> /P:	0.598461538	
Unit Peak Discharge, q <sub>u</sub> :	260	csm/in (from Exhibit 4-111 below)
Area, A:	0.01947	mi <sup>2</sup>
Water Quality Flow, WQF:	<b>0.33</b>	cfs

**Exhibit 4-111 Unit peak discharge (q<sub>u</sub>) for NRCS (SCS) type III rainfall distribution**



## Water Quality Volume and Water Quality Flow Worksheet

Watershed: DA 4


Condition: Post-Construction

**Water Quality Volume**

Design Precipitation, P:	1.3	<i>in</i>
Percent Impervious Cover, I:	0%	
Volumetric Runoff Coefficient, R:	0.050	
Area, A:	11.04	acres
Water Quality Volume, WQV:	<b>2,605</b>	C.F.

**Water Quality Flow**

Runoff Depth, Q:	0.065	<i>in</i>
Runoff Curve Number, CN:	72	
Time of Concentration, T <sub>c</sub> : (>=10 min)	10.0	<i>min</i>
Time of Concentration, T <sub>c</sub> :	0.167	<i>hr</i>
Initial Abstraction, I <sub>a</sub> :	0.778	<i>in</i>
I <sub>a</sub> /P:	0.598461538	
Unit Peak Discharge, q <sub>u</sub> :	260	<i>csm/in</i> (from Exhibit 4-111 below)
Area, A:	0.01725	<i>mi</i> <sup>2</sup>
Water Quality Flow, WQF:	<b>0.29</b>	<i>cfs</i>





## Water Quality Volume and Water Quality Flow Worksheet

Watershed: 

DA 6
------

Condition: 


Post-Construction
-------------------

**Water Quality Volume**

Design Precipitation, P:	1.3	in
Percent Impervious Cover, I:	0%	
Volumetric Runoff Coefficient, R:	0.050	
Area, A:	9.30	acres
Water Quality Volume, WQV:	<b>2,194</b>	<b>C.F.</b>

**Water Quality Flow**

Runoff Depth, Q:	0.065	in
Runoff Curve Number, CN:	72	
Time of Concentration, T <sub>c</sub> : (>=10 min)	10.0	min
Time of Concentration, T <sub>c</sub> :	0.167	hr
Initial Abstraction, I <sub>a</sub> :	0.778	in
I <sub>a</sub> /P:	0.598461538	
Unit Peak Discharge, q <sub>u</sub> :	260	csm/in (from Exhibit 4-111 below)
Area, A:	0.01453	mi <sup>2</sup>
Water Quality Flow, WQF:	<b>0.25</b>	<b>cfs</b>



## Water Quality Volume and Water Quality Flow Worksheet

Watershed: 

DA 8
------

Condition: 


Post-Construction
-------------------

**Water Quality Volume**

Design Precipitation, P:	1.3	in
Percent Impervious Cover, I:	0%	
Volumetric Runoff Coefficient, R:	0.050	
Area, A:	2.50	acres
Water Quality Volume, WQV:	<b>590</b>	C.F.

**Water Quality Flow**

Runoff Depth, Q:	0.065	in
Runoff Curve Number, CN:	72	
Time of Concentration, T <sub>c</sub> : (>=10 min)	10.0	min
Time of Concentration, T <sub>c</sub> :	0.167	hr
Initial Abstraction, I <sub>a</sub> :	0.778	in
I <sub>a</sub> /P:	0.598461538	
Unit Peak Discharge, q <sub>u</sub> :	260	csm/in (from Exhibit 4-111 below)
Area, A:	0.00391	mi <sup>2</sup>
Water Quality Flow, WQF:	<b>0.07</b>	cfs



## Water Quality Volume and Water Quality Flow Worksheet

Watershed: DA 9


Condition: Post-Construction

**Water Quality Volume**

Design Precipitation, P:	1.3	<i>in</i>
Percent Impervious Cover, I:	0%	
Volumetric Runoff Coefficient, R:	0.050	
Area, A:	4.80	acres
Water Quality Volume, WQV:	<b>1,133</b>	C.F.

**Water Quality Flow**

Runoff Depth, Q:	0.065	<i>in</i>
Runoff Curve Number, CN:	72	
Time of Concentration, T <sub>c</sub> : (>=10 min)	10.0	<i>min</i>
Time of Concentration, T <sub>c</sub> :	0.167	<i>hr</i>
Initial Abstraction, I <sub>a</sub> :	0.778	<i>in</i>
I <sub>a</sub> /P:	0.598461538	
Unit Peak Discharge, q <sub>u</sub> :	260	<i>csm/in</i> (from Exhibit 4-111 below)
Area, A:	0.00750	<i>mi</i> <sup>2</sup>
Water Quality Flow, WQF:	<b>0.13</b>	<i>cfs</i>



## Water Quality Volume and Water Quality Flow Worksheet

### EQUATIONS (CTDEEP Connecticut Stormwater Quality Manual)

$$WQV = \frac{(1')(R)(A)}{12}$$

where:  $WQV$  = water quality volume (ac-ft)  
 $R$  = volumetric runoff coefficient  
 =  $0.05 + 0.009(I)$   
 $I$  = percent impervious cover  
 $A$  = site area in acres

Compute the NRCS Runoff Curve Number (CN) using the following equation, or graphically using **Figure 2-1** from TR-55 (USDA, 1986) (reproduced below):

$$CN = \frac{1000}{[10 + 5P + 10Q - 10(Q^2 + 1.25QP)^{1/2}]}$$

where:  $CN$  = Runoff Curve Number  
 $P$  = design precipitation, inches  
 (1" for water quality storm)  
 $Q$  = runoff depth (in watershed inches)  
 =  $\frac{[WQV(\text{acre} - \text{feet}) \times 12(\text{inches/foot})]}{\text{Drainage Area (acres)}}$

- Read initial abstraction ( $I_a$ ) from Table 4-1 in Chapter 4 of TR-55 (reproduced below); compute  $I_a/P$

**Table 4-1  $I_a$  values for runoff curve numbers**

Curve number	$I_a$ (in)	Curve number	$I_a$ (in)	Curve number	$I_a$ (in)	Curve number	$I_a$ (in)
40	3.000	55	1.636	70	0.857	85	0.353
41	2.878	56	1.571	71	0.817	86	0.326
42	2.762	57	1.509	72	0.778	87	0.299
43	2.651	58	1.448	73	0.740	88	0.273
44	2.545	59	1.390	74	0.703	89	0.247
45	2.444	60	1.333	75	0.667	90	0.222
46	2.348	61	1.279	76	0.632	91	0.198
47	2.255	62	1.226	77	0.597	92	0.174
48	2.167	63	1.175	78	0.564	93	0.151
49	2.082	64	1.125	79	0.532	94	0.128
50	2.000	65	1.077	80	0.500	95	0.105
51	1.922	66	1.030	81	0.469	96	0.083
52	1.846	67	0.985	82	0.439	97	0.062
53	1.774	68	0.941	83	0.410	98	0.041
54	1.704	69	0.899	84	0.381		

$$WQF = (q_u)(A)(Q)$$

where:  $WQF$  = water quality flow (cfs)  
 $q_u$  = unit peak discharge (cfs/mi<sup>2</sup>/inch)  
 $A$  = drainage area (mi<sup>2</sup>)  
 $Q$  = runoff depth (in watershed inches)  
 =  $\frac{[WQV(\text{acre} - \text{feet}) \times 12(\text{inches/foot})]}{\text{Drainage Area (acres)}}$

## **APPENDIX F**

### **Temporary Sediment Basin Calculations**

## Cashman Industrial Site Preparation Plan

"Newly Graded Area" cover type used  
TC=5.0 min

### Phase 1:

Peak flow 25 year storm = 1.94 cfs  
Total 10 hour volume = 5,359 cf  
Peak flow 10 year storm = 0.73 cfs

### Phase 2:

Peak flow 25 year storm = 5.07 cfs  
Total 10 hour volume = 18,666 cf  
Peak flow 10 year storm = 2.43 cfs

### Phase 3.1 (Western):

Peak flow 25 year storm = 21.21 cfs  
Total 10 hour volume = 75,432 cf  
Peak flow 10 year storm = 15.99 cfs

### Phase 3.2 (Eastern):

Peak flow 25 year storm = 5.63 cfs  
Total 10 hour volume = 13,873cf  
Peak flow 10 year storm = 3.69 cfs

### Phase 4:

Peak flow 25 year storm = 25.45cfs  
Total 10 hour volume = 106,069 cf  
Peak flow 10 year storm = 19.76 cfs

### Phase 5:

Peak flow 25 year storm = 0.80 cfs  
Total 10 hour volume = 2,159 cf  
Peak flow 10 year storm = 0.25 cfs

Phase I

**Universal Soil Loss**

Drainage area (ac)	DA	9.2
Avg Erosion (SB-1)	A	50
Deliv Ratio (SB-12)	DR	0.4
Trap Eff.	TE	0.8
Sed Density (SB-2)	~	85

Volume (acft/yr)= 0.079512

**Residence Time**

RT (hrs)= RT 10

Residence volume (CF) 5,359 input from hydrograph

Wet Storage (CF)= 8822.529

**Basin Width**

Q5 (CFS) Q5 25.67

Width (ft)= 50.66557

**Basin Length**

Length (ft)= 101.3311 minimum

234' x 75' x 5'

**Outlet**

Q25 (CFS) Q25 33

Outlet Area (SF) A 16.5

Adjusted A (SF)= 16.73428 4' x 5'

**Barrel Size**

Q25 (CFS) Q25 33

Pipe D (FT from Gohi Culvert Seelye) 30"

**Spillway**

Q25 (CFS) Q25 33 Assume 50% plugged w/trash

Cw coeff C 1.7

H (FT) H 1

L of spillway required (FT)= 9.705882

Phase II

**Universal Soil Loss**

Drainage area (ac)	DA	10
Avg Erosion (SB-1)	A	50
Deliv Ratio (SB-12)	DR	0.4
Trap Eff.	TE	0.8
Sed Density (SB-2)	~	85

Volume (acft/yr)= 0.086426

**Residence Time**

RT (hrs)= RT 10

Residence volume (CF) 18,666 input from hydrograph

Wet Storage (CF)= 22430.71

**Basin Width**

Q5 (CFS) Q5 28.15

Width (ft)= 53.05657

**Basin Length**

Length (ft)= 106.1131 minimum

241' x 80' x 5'

**Outlet**

Q25 (CFS) Q25 28

Outlet Area (SF) A 14

Adjusted A (SF)= 14.19878 3.5' x 4'

**Barrel Size**

Q25 (CFS) Q25 28

Pipe D (FT from Gohi Culvert Seelye) 30"

**Spillway**

Q25 (CFS) Q25 28 Assume 50% plugged w/trash

Cw coeff C 1.7

H (FT) H 1

L of spillway required= 8.235294



Phase III (1)

**Universal Soil Loss**

Drainage area (ac)	DA	6.2
Avg Erosion (SB-1)	A	50
Deliv Ratio (SB-12)	DR	0.4
Trap Eff.	TE	0.8
Sed Density (SB-2)	~	85

Volume (acft/yr)= 0.053584

**Residence Time**

RT (hrs)= RT 10

Residence volume (CF) 75,432 input from hydrograph

Wet Storage (CF)= 77766.12

**Basin Width**

Q5 (CFS) Q5 25.28

Width (ft)= 50.27922 minimum

**Basin Length**

Length (ft)= 100.5584 minimum

234' x 75' x 5'

**Outlet**

Q25 (CFS) Q25 25

Outlet Area (SF) A 12.5

Adjusted A (SF)= 12.67748 4' x 3'

**Barrel Size**

Q25 (CFS) Q25 25

Pipe D (FT from Gohi Culvert Seelye) 30"

**Spillway**

Q25 (CFS) Q25 25 Assume 50% plugged w/trash

Cw coeff C 1.7

H (FT) H 1

L of spillway required= 7.352941

Phase III (2)

**Universal Soil Loss**

Drainage area (ac)	DA	3.5
Avg Erosion (SB-1)	A	50
Deliv Ratio (SB-12)	DR	0.4
Trap Eff.	TE	0.8
Sed Density (SB-2)	~	85

Volume (acft/yr)= 0.030249

**Residence Time**

RT (hrs)= RT 10

Residence volume (CF) 13,873 input from hydrograph

Wet Storage (CF)= 15190.65

**Basin Width**

Q5 (CFS) Q5 9.42

Width (ft)= 30.69202

**Basin Length**

Length (ft)= 61.38404 minimum

128' x 50' x 5'

**Outlet**

Q25 (CFS) Q25 9.4

Outlet Area (SF) A 4.7

Adjusted A (SF)= 4.766734 3' x 2'

**Barrel Size**

Q25 (CFS) Q25 9.4

Pipe D (FT from Gohi Culvert Seelye) 24"

**Spillway**

Q25 (CFS) Q25 9.4 Assume 50% plugged w/trash

Cw coeff C 1.7

H (FT) H 1

L of spillway required= 2.764706

Phase IV

**Universal Soil Loss**

Drainage area (ac)	DA	9.8
Avg Erosion (SB-1)	A	50
Deliv Ratio (SB-12)	DR	0.4
Trap Eff.	TE	0.8
Sed Density (SB-2)	~	85

Volume (acft/yr)= 0.084697

**Residence Time**

RT (hrs)= RT 10

Residence volume (CF) 106,069 input from hydrograph

Wet Storage (CF)= 109758.4

**Basin Width**

Q5 (CFS) Q5 40.04

Width (ft)= 63.27717

**Basin Length**

Length (ft)= 126.5543 minimum

228' x 100' x 6'

**Outlet**

Q25 (CFS) Q25 40

Outlet Area (SF) A 20

Adjusted A (SF)= 20.28398 5' x 5'

**Barrel Size**

Q25 (CFS) Q25 40

Pipe D (FT from Gohi Culvert Seelye) 36"

**Spillway**

Q25 (CFS) Q25 40 Assume 50% plugged w/trash

Cw coeff C 1.7

H (FT) H 1

L of spillway required= 11.76471

Phase V

**Universal Soil Loss**

Drainage area (ac)	DA	3
Avg Erosion (SB-1)	A	50
Deliv Ratio (SB-12)	DR	0.4
Trap Eff.	TE	0.8
Sed Density (SB-2)	~	85

Volume (acft/yr)= 0.025928

**Residence Time**

RT (hrs)= RT 10

Residence volume (CF) 2,159 input from hydrograph

Wet Storage (CF)= 3288.412

**Basin Width**

Q5 (CFS) Q5 8.55

Width (ft)= 29.24038

**Basin Length**

Length (ft)= 58.48077 minimum

116' x 50' x 5'

**Outlet**

Q25 (CFS) Q25 8.5

Outlet Area (SF) A 4.25

Adjusted A (SF)= 4.310345 30" diameter CMP

**Barrel Size**

Q25 (CFS) Q25 8.5

Pipe D (FT from Gohi Culvert Seelye) 18"

**Spillway**

Q25 (CFS) Q25 8.5 Assume 50% plugged w/trash

Cw coeff C 1.7

H (FT) H 1

L of spillway required= 2.5

## Sediment Basin Outlet Design

### Phase I

Outlet Structure Size (FT)	5'x4'x5'	LxWxH
Outlet Pipe Diameter (FT)	30"	
Spillway Width (FT)	10'	

### Phase II

Outlet Structure Size (FT)	4'x3.5'x5'	LxWxH
Outlet Pipe Diameter (FT)	30"	
Spillway Width (FT)	8.5'	

### Phase III (1)

Outlet Structure Size (FT)	4'x3'x5'	LxWxH
Outlet Pipe Diameter (FT)	30"	
Spillway Width (FT)	7.5'	

### Phase III (2)

Outlet Structure Size (FT)	3'x2'x5'	LxWxH
Outlet Pipe Diameter (FT)	24"	
Spillway Width (FT)	3'	

### Phase IV

Outlet Structure Size (FT)	5'x5'x6'	LxWxH
Outlet Pipe Diameter (FT)	36"	
Spillway Width (FT)	12'	

### Phase V

Outlet Structure Size (FT)	30"	Diameter
Outlet Pipe Diameter (FT)	18"	
Spillway Width (FT)	2.5'	

**APPENDIX G**

**Stormwater Management Maintenance Program and Inspection Checklist**

## Stormwater Management System Maintenance Program

---

There shall be periodic maintenance of the stormwater systems on the property after installation. In order to ensure effective performance of the system, the following stormwater maintenance program has been established. The property owner will be responsible for implementation of this program. A log and schedule of all inspections, cleanings, and repairs shall be maintained by the property owner. All maintenance documents shall be transferred to any future owners upon sale or transfer of the property.

### A. Catch basins/Manholes

Catch basins are designed with sumps for the purpose of collecting coarse sediment. All catch basins should be inspected two times per year, specifically during times for high levels of maintenance around the site. Sediment should be removed when it extends to within 6 inches of the outlet pipe invert or not less than once per year. Cleanout should be facilitated via vacuum truck or other means that accomplish sediment removal. The sediment shall be disposed of in an approved off-site location in accordance with town and state requirements.

### B. Asphalt

Asphalt areas should be swept annually. Ideal sweeping timeframe is in the spring after winter sanding or salting for deicing. Deicing chemicals should be kept to a minimum during the winter months.

### C. Stormwater basin

The stormwater basin shall be inspected twice per year. Inspections shall include the following:

- Check for sediment accumulation, trash, and debris.
- Check for blockages, structural integrity, and evidence of erosion at inlets, outlets, and overflow spillways;
- Check that the trash rack at the low-level outlet is clear and the outlet is functioning properly;

Regular maintenance includes the following:

- Prune trees and shrubs as needed.
- Inspect soil and repair eroded areas seasonally or as necessary.
- Remove any invasive species (including roots) that have become established within the basin and embankments.
- Sediment removal should occur at a minimum of every five years or before the sediment storage capacity has been filled.

### D. Lawn and vegetated areas

Vegetated cover shall be maintained on all earth surfaces to minimize soil erosion. Fertilizer use should be minimized and applied using careful application processes. Vehicles shall be prohibited from driving or parking on vegetated areas to prevent compaction of soils.

## Stormwater Management System Maintenance Checklist

---

### E. Hydrodynamic Separator (Stormceptor)

The hydrodynamic separator shall be inspected and maintained during catch basin inspections and cleaning. An inspection is made by checking the depth of sediment in each manhole with a grade stick or similar device. Maintenance is required when the sediment depth exceeds 20 inches. Minimum inspection is recommended twice a year to maintain operation and function of the unit.

#### Maintenance Instructions:

1. Remove the manhole cover to provide access to the pollutant storage. Pollutants are stored in the sump, below the bowl assembly visible from the surface. Access this area through the 10" diameter access cylinder.
2. Use a vacuum truck or other similar equipment to remove all water, debris, oils and sediment.
3. Use a high-pressure hose to clean the manhole of all the remaining sediment and debris. Then, use the vacuum truck to remove the water.
4. Fill the cleaned manhole with water until the level reaches the invert of the outlet pipe.
5. Replace the manhole cover.
6. Dispose of the polluted water, oils, sediment and trash at an approved facility.
  - Check with the local sewer authority for authority to discharge the liquid.



## Stormwater Management System Maintenance Checklist

Inspection Date: \_\_\_\_\_

Inspector: \_\_\_\_\_

Maintenance Item	Satisfactory	Unsatisfactory	Comments
<b>Drainage Structures</b>			
Sedimentation Accumulation			
Large Floating Debris			
Inlet/Outlet			
Structure walls			
Riser			
Frame and Cover			
<b>Infiltration System</b>			
Settling Over System			
Sedimentation Accumulation			
Large Floating Debris			
Inspection Structure Integrity			
Inspection Inlets/Outlets			
<b>Surrounding Lawn and Vegetated Areas</b>			
Signs of Erosion			
Ponding/Settling			
Overgrowth			

Additional Comments: \_\_\_\_\_

\_\_\_\_\_  
\_\_\_\_\_