

**Town of Ledyard  
Highlands W.W.T.F.  
Plant Supervisor's Report  
Meeting Date: November 26, 2024**

The goal of the plant staff is to efficiently collect and treat the wastewater and to produce the best quality effluent possible while maintaining the equipment and protecting the Town's assets.

- Rotary Drum Thickener panel has arrived. Installation will begin on 12-3-24.
- DB Electric here to go over installation plan for RDT panel.
- Andy Sincali is working with Oak Hill Controls on SCADA for new panel.
- Solar Company will be here 11-26 for scheduled maintenance.
- Montville WPCA will be here on 11-26 to look at Smith & Loveless pump station. They are interested in purchasing one.
- Working with Russell Associates troubleshooting leak on screen compactor.
- Influent pump station solenoid valve replaced on pump #2. Unit is back up and running well.
- Green Mountain here on 11-18 to jet flush and clean 3500' on collection system.
- Manhole covers/ frames #38,42, and #45 need to be replaced. These are located on Meetinghouse Lane.
- Gerber Construction is completing phase 1 and will begin phase III sewer force main soon.
- Diane Johnson (CTRWVA) here for Operator math tutoring on 11-21.

**Respectfully submitted,**

**Stephen W. Banks**

