

DEEP TEST PIT DATA

AS RECORDED BY WENDY BROWN-ARNOLD, RS & DANIELLE HOLMES, REHS/RS LEDGE LIGHT HEALTH DISTRICT ON DECEMBER 5 & 13 2017 AND WITNESSED BY DAN QUINN.
& TEST PITS 4A, 5A & 5B, 19-34, 36A, 36B AND 38A AS RECORDED BY DANIELLE HOLMES, REHS/RS LEDGE LIGHT HEALTH DISTRICT ON FEBRUARY 5 & 6 2018 AND WITNESSED BY DAN QUINN.

1 MARTY'S WAY
TP 47
13" TOPSOIL
29" YELLOW-BR. FINE SANDY LOAM
37" ORANGE-GRAY SILTY FINE SAND, INCONSISTENT STAINING
94" LT. TAN FINE SAND, W/GRAVEL, SOME COBBLES

NO MOTTLING
NO GW
NO LEDGE
ROOTS TO 30"

TP 48
9" TOPSOIL
22" LT. BR. FINE SANDY LOAM
93" LT. TAN FINE TO MED. SAND, W/GRAVEL, SOME COBBLES
INCONSISTENT SILTY LAYERS 27" TO 37" W/STAINING

NO MOTTLING
NO GW
NO LEDGE
ROOTS TO 20"

2 MARTY'S WAY
TP 1
8" TOPSOIL
20" LT. BR. FINE SANDY LOAM
35" LT. BR. SILTY DEPOSIT, INCOSISTENT, STAINED
99" LT. TAN/GRAY MEDIUM SAND, GRAVEL, COBBLES, STONES

NO GW
NO REDOX
NO REF.

TP 1A
4" TOPSOIL
32" BR. FINE SANDY LOAM
53" LT. TAN-GRAY MED. SAND AND GRAVEL, SOME LOAM

NO GW
NO REDOX
LEDGE 30-53"

TP 2
10" TOPSOIL
31" BR. FINE SANDY LOAM
48" LT. BR. TO GRAY SILT DEPOSIT W/STAINING
96" LT. BR.-GRAY MEDIUM SAND, W/GRAVEL, COBBLES, STONES

NO GW
NO REDOX
NO REF.

3 MARTY'S WAY
TP 43
0-10" LEAF LITTER & TOPSOIL
10-24" ORANGE BROWN FINE SANDY LOAM
24-49" POCKET OF STRATIFIED VERY FINE SILTY SAND, MOTTLED
49-91" LIGHT GRAY BROWN FINE-MEDIUM SANDY LOAM

MOTTLING @ 32"
NO GW
NO LEDGE
ROOTS TO 29"

TP 46
0-7" LEAF LITTER & TOPSOIL
7-28" ORANGE BROWN FINE SANDY LOAM
28-90" LIGHT GRAY BROWN FINE-MEDIUM COARSE SAND, TRACE GRAVEL

MOTTLING POSSIBLE @ 54"
COMPACT @ 49"
NO GW
NO LEDGE
ROOTS TO 50"

4 MARTY'S WAY
TP 3
10" TOPSOIL
35" LT. BR. VERY FINE SANDY LOAM, W/SILT
75" LT. GRAY MEDIUM SAND, W/GRAVEL, COBBLES
94" DK. GRAY MED. SAND

NO GW
MOTTLING AT 32" (CONSISTENT AROUND HOLE)
NO REF.

TP 4
10" TOPSOIL
24" LT. BR. FINE SANDY LOAM
42" BR. TO GRAY SILTY DEPOSIT W/STAINING, INCONSISTENT
75" LT. GRAY MED. SAND, W/GRAVEL, COBBLES
99" DK. GRAY MED. SAND

NO GW
NO REDOX
NO REF.

TP 4A
0-10" LEAF LITTER & TOPSOIL
10-46" YELLOW TO GRAY BROWN MEDIUM COARSE SANDY LOAM, W/GRAVEL, DAMP
46-80" COULD NOT READ DUE TO GROUNDWATER

STANDING WATER @ 46"
MOTTLING @ 35"
GW 46"
NO LEDGE
ROOTS 34"

5 MARTY'S WAY
TP 43
0-7" LEAF LITTER & TOPSOIL
7-25" ORANGE BROWN FINE SANDY LOAM
25-91" STRATIFIED LIGHT GRAY BROWN FINE-MEDIUM SANDY LOAM

MOTTLING POSSIBLE @ 54"
NO GW
NO LEDGE
ROOTS TO 28"

TP 44
0-7" LEAF LITTER & TOPSOIL
7-34" ORANGE BROWN MEDIUM COARSE SANDY LOAM, TRACE GRAVEL, LOOSE
34-93" LIGHT GRAY BROWN MEDIUM COARSE SAND & GRAVEL, MODERATELY COMPACT

MOTTLING @ 38"
NO GW
NO LEDGE
ROOTS TO 34"

7 MARTY'S WAY
TP 41
0-7" LEAF LITTER & TOPSOIL
7-35" ORANGE BROWN FINE SANDY LOAM
35-97" GRAY BROWN MEDIUM COARSE SANDY LOAM, TRACE GRAVEL W/SOME ORANGE BANDED DEPOSITS

MOTTLING @ 52"
NO GW
NO LEDGE
ROOTS TO 38"

TP 42
0-6" LEAF LITTER & TOPSOIL
6-37" ORANGE BROWN FINE SANDY LOAM, TRACE GRAVEL, LOOSE
37-96" GRAY BROWN MEDIUM COARSE SAND & GRAVEL

MOTTLING POSSIBLE @ 52"
NO GW
NO LEDGE
ROOTS TO 50"

9 MARTY'S WAY
TP 39
9" TOPSOIL
25" BR. FINE SANDY LOAM
101" BR. TO GRAY FINE TO MED. SAND W/GRAVEL, SOME ROCKS

REDOX @ 66"
NO GW
NO LEDGE
ROOTS TO 30"

TP 40
7" TOPSOIL
32" LT. BR. FINE SANDY LOAM
100" LT. TAN-GRAY MED. SAND W/GRAVEL, FEW COBBLES

POSSIBLE REDOX @ 90"
NO GW
NO LEDGE
ROOTS TO 30"

11 MARTY'S WAY
TP 37
11" TOPSOIL
47" YELLOW-BR. TO GRAY SILTY LOAM, SOME FINE SAND
89" GRAY FINE TO MED. SAND, SOME GRAVEL

GW 38"
REDOX AT 24"
NO REF.

TP 38
14" TOPSOIL
26" LT. TAN-GRAY SILTY LOAM, SOME FINE SAND
71" GRAY-TAN FINE SANDY LOAM W/SILT

GW 56"
REDOX AT 27"
NO REF
ROOTS TO 15"

TP 38A
GW @ 16"

TP 38B
9" LEAF LITTER & TOPSOIL
24" LIGHT ORANGE BROWN MEDIUM-COARSE SANDY LOAM, DAMP
49" STRATIFIED GRAY BROWN MEDIUM COARSE SANDY LOAM, SATURATED, MOTTLED
78" COULD NOT READ DUE TO STANDING WATER

MOTTLING @ 34"
GW 28"
NO LEDGE
ROOTS TO 47"

13 MARTY'S WAY
TP 27
0-6" LEAF LITTER & TOPSOIL
6-27" ORANGE BROWN MEDIUM COARSE SANDY LOAM
27-40" STRATIFIED GRAY BROWN COARSE SAND & GRAVEL
40-80" DECOMPOSED/ROTTEN ROCK

NO MOTTLING
NO GW
LEDGE @ 40"
ROOTS 30"

TP 28
0-7" LEAF LITTER & TOPSOIL
7-24" STRAITED YELLOW BROWN MEDIUM COARSE SANDY LOAM
24-81" STRATIFIED GRAY BROWN COARSE SAND & GRAVEL, VERY ROCKY

NO MOTTLING
NO GW
LEDGE POSSIBLE @ 81"
ROOTS 36"

TP 58
6" LEAF LITTER & TOPSOIL
24" LIGHT ORANGE BROWN FINE-MEDIUM SANDY LOAM
92" LIGHT GRAY BROWN FINE-MEDIUM SAND, TRACE GRAVEL, ROCKY

MOTTLING @ 36"
NO GW
LEDGE @ 62"
ROOTS TO 40"

15 MARTY'S WAY
TP 25
0-10" LEAF LITTER & TOPSOIL
10-33" ORANGE BROWN MEDIUM COARSE SANDY LOAM
33-45" FRAGMENTED LEDGE ROCK

NO MOTTLING
NO GW
LEDGE @ 45"
ROOTS 31"

TP 25A
0-5" LEAF LITTER & TOPSOIL
5-14" ORANGE BROWN MEDIUM COARSE SANDY LOAM
14-43" YELLOW BROWN VERY FINE SILTY SAND
43-93" LIGHT GRAY BROWN COARSE SAND & GRAVEL, DENSE, ROCKY
POSSIBLE FRAGMENTED LEDGE ROCK @ 80"

MOTTLING @ 40"
NO GW
LEDGE POSSIBLE @ 80"
ROOTS 42"

TP 26
0-11" LEAF LITTER & TOPSOIL
11-52" ORANGE BROWN MEDIUM COARSE SANDY LOAM, DAMP, MANY ROCKS
52-84" PARTIALLY DECOMPOSED, DENSE LEDGE ROCK, DIGGABLE

NO MOTTLING
NO GW
LEDGE @ 52"
ROOTS 52"

TP 58
6" LEAF LITTER & TOPSOIL
31" LIGHT ORANGE BROWN VERY FINE SILTY LOAM
80" LIGHT GRAY COARSE, COMPACT, MANY ROCKS

NO MOTTLING
NO GW
LEDGE @ 80"
ROOTS TO 48"

16 MARTY'S WAY
TP 8
8" TOPSOIL
24" LT. BR. FINE SANDY LOAM, TR. SILT
96" LT. TAN MED. SAND, W/GRAVEL, SOME COBBLES

NO GW
NO REDOX
NO REF.

TP 8
9" TOPSOIL
22" BR. FINE SANDY LOAM
90" LT. TAN MED. SAND, W/GRAVEL, SOME COBBLES

TP 8
9" TOPSOIL
22" BR. FINE SANDY LOAM
90" LT. TAN MED. SAND, W/GRAVEL, SOME COBBLES

NO GW
NO REDOX
NO REF.

17 MARTY'S WAY
TP 36
4" TOPSOIL
23" BR. FINE SANDY LOAM, SOME SILT
40" GRAY FINE SANDY LOAM, DAMP
91" GRAY MED. SAND W/GRAVEL, COBBLES

GW 68"
REDOX AT 34"
NO REF.
ROOTS TO 36"

TP 36A
0-10" LEAF LITTER & TOPSOIL
10-25" ORANGE BROWN MEDIUM COARSE SANDY LOAM, DAMP
25-55" GRAY BROWN VERY FINE SILTY SAND
55-80" COULD NOT READ DUE TO GW

STANDING WATER @ 55"
MOTTLING @ 27"
GW 58"
NO LEDGE
ROOTS 32"

TP 36B
0-11" LEAF LITTER & TOPSOIL
11-30" ORANGE BROWN FINE SANDY LOAM, DAMP
30-58" STRATIFIED GRAY BROWN VERY FINE SILTY SAND, DAMP
58-83" COULD NOT READ DUE TO GW

STANDING WATER @ 58"
MOTTLING @ 42"
GW 58"
NO LEDGE
ROOTS 38"

18 MARTY'S WAY
TP 11
9" TOPSOIL
30" LT. BR. FINE SANDY LOAM
40" TAN TO GRAY SILTY FINE SAND
98" OLIVE GRAY MED. SAND, W/GRAVEL, COBBLES

NO GW
NO REDOX
NO REF.

TP 12
5" TOPSOIL
18" LT. BR. FINE SANDY LOAM
36" LT. BR. TO GRAY SILTY FINE SAND, INCONSISTENT STAINING
96" LT. OLIVE BR. MED. SAND, GRAVEL, SOME SILT

NO GW
NO REDOX
NO REF.

TP 16
9" TOPSOIL
36" BR. FINE SANDY LOAM
68" GRAY TO TAN-FINE-MED SAND W/GRAVEL, FEW ROCKS

98" LT. TAN FINE MED-SAND, W/GRAVEL, MOD. COMPACT IN PLACE

NO GW
NO REDOX
NO REF.

TEST PITS 32A, 38B, 49-53, 55, 56, 58 & 59 AS RECORDED BY DANIELLE HOLMES, REHS/RS LEDGE LIGHT HEALTH DISTRICT ON MARCH 3, 2018.

19 MARTY'S WAY
TP 33
0-8" LEAF LITTER & TOPSOIL
8-24" LIGHT ORANGE/YELLOW BROWN FINE-MEDIUM COARSE SANDY LOAM
24-94" LIGHT GRAY COARSE SAND & GRAVEL OVER DECOMPOSED/FRAGMENTED DIGGABLE LEDGE ROCK
46-94" NON-TYPICAL ROCK

STANDING WATER @ 94"
NO MOTTLING
GW 94"
LEDGE POSSIBLE @ 94"
ROOTS NONE NOTED

TP 34
0-6" LEAF LITTER & TOPSOIL
6-12" YELLOW BROWN FINE SANDY LOAM
12-93" GRAY BROWN COARSE SAND & GRAVEL

STANDING WATER @ 77"
MOTTLING @ 38"
GW 70"
NO LEDGE
ROOTS 35"

TP 35
10" TOPSOIL
17" LT. BR. FINE SANDY LOAM, SOME SILT
51" GRAY VERY FINE SILTY SAND
87" GRAY MED. SAND W/GRAVEL, COBBLES

NO GW
REDOX AT 34"
NO REF.
ROOTS TO 30"

20 MARTY'S WAY
TP 15
8" TOPSOIL
26" YELLOW BR. FINE SANDY LOAM, TR. SILT
49" LT. BR.-GRAY SILTY DEPOSITS, LIGHT STAINING
92" LT. OLIVE-BR. MED. SAND, W/GRAVEL, FEW ROCKS

NO GW
NO REDOX
NO REF.

TP 14
7" TOPSOIL
28" YELLOW-BR. FINE SANDY LOAM, TR. SILT
35" LT. BR.-GRAY SILTY DEPOSIT, INCONSISTENT STAINING
92" LT. OLIVE-BR. SAND, W/GRAVEL, SILT

NO GW
NO REDOX
NO REF.

21 MARTY'S WAY
TP 31
0-11" LEAF LITTER & TOPSOIL
11-31" ORANGE BROWN MEDIUM COARSE SANDY LOAM
31-38" STRATIFIED YELLOW GRAY VERY FINE SANDY LOAM
38-99" LIGHT GRAY MEDIUM COARSE SAND & GRAVEL
99-104" COULD NOT READ DUE TO GW

STANDING WATER @ 99"
MOTTLING @ 50"
GW 99"
NO LEDGE
ROOTS 37"

NO MOTTLING
NO GW
LEDGE @ 41"
ROOTS 30"

TP 32
0-11" LEAF LITTER & TOPSOIL
11-26" LIGHT ORANGE BROWN FINE-MEDIUM SANDY LOAM
26-100" LIGHT GRAY BROWN COARSE SAND & GRAVEL OVER DECOMPOSED/FRAGMENTED DIGGABLE LEDGE ROCK
41-100" NON-TYPICAL ROCK

NO MOTTLING
NO GW
LEDGE @ 41"
ROOTS 30"

TP 32A
9" LEAF LITTER & TOPSOIL
45" ORANGE BROWN VERY FINE SILTY SAND
89" STRATIFIED GRAY BROWN COARSE SAND & GRAVEL POCKET OF DECOMPOSED/FRAGMENTED LEDGE @ 50"

MOTTLING @ 40"
GW 83"
NO LEDGE
ROOTS TO 29"

TP 49
6" LEAF LITTER & TOPSOIL
24" LIGHT ORANGE BROWN FINE SANDY LOAM
103" STRATIFIED LIGHT GRAY BROWN COARSE SAND & GRAVEL

MOTTLING @ 46"
GW 96"
NO LEDGE
ROOTS TO 42"

TP 50
9" LEAF LITTER & TOPSOIL
23" YELLOW BROWN COARSE SANDY LOAM
102" STRATIFIED GRAY BROWN COARSE SAND & GRAVEL

MOTTLING @ 43"
GW 89"
NO LEDGE
ROOTS TO 45"

22 MARTY'S WAY
TP 15
9" TOPSOIL
24" BR. FINE SANDY LOAM
100" LT. TAN FINE-MED SAND, W/GRAVEL COBBLES, ROCKS

NO GW
NO REDOX
NO REF.

TP 16
9" TOPSOIL
36" BR. FINE SANDY LOAM
68" GRAY TO TAN-FINE-MED SAND W/GRAVEL, FEW ROCKS

98" LT. TAN FINE MED-SAND, W/GRAVEL, MOD. COMPACT IN PLACE

NO GW
NO REDOX
NO REF.

TEST PITS 200-203 WITNESSED BY EDWARD NOLAN DIETER & GARDNER, INC. AND RECORDED BY WENDY BROWN-ARNOLD RS, LEDGE LIGHT HEALTH DISTRICT JUNE 6, 2018.

22 MARTY'S WAY CONTINUED
TP 22
10" TOPSOIL
15" LT. BR. FINE SANDY LOAM
39" LT. BR.-GRAY SILTY DEPOSIT, INCONSISTENT STAINING
100" LT. OLIVE-BR. MEDIUM SAND, W/GRAVEL

NO GW
NO REDOX
NO REF.

TP 18
10" TOPSOIL
31" LT. BR. FINE SANDY LOAM
48" LT. BR.-GRAY SILTY DEPOSIT, SOME STAINING-INCONSISTENT
107" LT. OLIVE-BR.-GRAY MEDIUM SAND, W/GRAVEL

NO GW
NO REDOX
NO REF.

23 MARTY'S WAY
TP 29
0-7" LEAF LITTER & TOPSOIL
7-24" STRAITED YELLOW BROWN FINE-MEDIUM SANDY LOAM
24-108" LIGHT GRAY MEDIUM COARSE SAND

MOTTLING @ 30"
NO GW
LEDGE @ 24"
ROOTS 24"

TP 30
0-9" LEAF LITTER & TOPSOIL
9-44" LIGHT YELLOW BROWN FINE-MEDIUM SANDY LOAM
44-82" GRAY BROWN FINE-MEDIUM SANDY LOAM

MOTTLING @ 41"
NO GW
NO LEDGE
ROOTS 45"

24 MARTY'S WAY
AS RECORDED BY WENDY ARNOLD-BROWN LEDGE LIGHT HEALTH DISTRICT ON JUNE 6, 2018.

TP 202
0-7" TOPSOIL
7-28" LIGHT BROWN FINE SANDY LOAM
28-81" LIGHT TAN/GRAY VERY FINE SAND WITH SOME SILT
81-97" LIGHT TAN/GRAY MED SAND WITH GRAVEL & COBBLES

NO MOTTLING
NO GW
NO LEDGE

TP 203
0-4" TOPSOIL
4-26" LIGHT BROWN FINE SANDY LOAM
26-46" LIGHT TAN/GRAY WITH FINE SAND WITH SOME SILT, SLIGHTLY STAINING
46-98" LIGHT TAN/GRAY MED. SAND WITH GRAVEL & COBBLES
MODERATELY COMPACT IN PLACES

NO MOTTLING
NO GW
NO LEDGE

25 MARTY'S WAY
TP 23
0-7" LEAF LITTER & TOPSOIL
7-30" ORANGE BROWN MEDIUM COARSE SANDY LOAM
30-60" STRATIFIED GRAY BROWN COARSE SAND & GRAVEL, VERY ROCKY, DENSE
60-77" FRAGMENTED LEDGE ROCK

NO MOTTLING
NO GW
LEDGE @ 60"
ROOTS 25"

TP 24
0-7" LEAF LITTER & TOPSOIL
7-21" LIGHT ORANGE BROWN FINE-MEDIUM COARSE SANDY LOAM, ROCKY
21-36" YELLOW BROWN VERY FINE SILTY LOAM
36-75" LIGHT GRAY BROWN MEDIUM COARSE SAND & GRAVEL, DENSE, ROCKY
75-82" FRAGMENTED LEDGE ROCK

NO MOTTLING
NO GW
LEDGE @ 75"
ROOTS 40"

26 MARTY'S WAY
AS RECORDED BY WENDY ARNOLD-BROWN LEDGE LIGHT HEALTH DISTRICT ON JUNE 6, 2018.

TP 200
0-7" TOPSOIL
7-26" LIGHT BROWN FINE SANDY LOAM
26-37" LIGHT TAN FINE SAND WITH GRAVEL, COBBLES, STONES

NO MOTTLING
NO GW
NO LEDGE

TP 201
0-4" TOPSOIL
4-21" LIGHT BROWN FINE SANDY LOAM
21-31" LIGHT BROWN/LIGHT TAN FINE SAND
31-90" LIGHT TAN/BROWN MED-COARSE SAND WITH GRAVEL & COBBLES

NO MOTTLING
NO GW
NO LEDGE

27 MARTY'S WAY
TP 21
0-5" LEAF LITTER & TOPSOIL
5-29" ORANGE BROWN VERY FINE SANDY LOAM, VERY ROCKY
29-93" LIGHT GRAY COARSE SAND & GRAVEL OVER DECOMPOSED/FRAGMENTED DIGGABLE LEDGE ROCK
MANY LARGE ROCKS/BOULDERS THROUGHOUT

NO MOTTLING
NO GW
LEDGE @ 38"
ROOTS 28"

CONTINUED 27 MARTY'S WAY
TP 22
0-8" LEAF LITTER & TOPSOIL
8-17" ORANGE BROWN FINE SANDY LOAM, W/COBBLES
17-28" YELLOW BROWN VERY FINE SILTY SAND
28-69" STRATIFIED GRAY BROWN COARSE SAND & GRAVEL, VERY ROCKY, DENSE

NO MOTTLING
NO GW
LEDGE @ 69"
ROOTS 29"

TP 55
6" LEAF LITTER & TOPSOIL
26" LIGHT ORANGE BROWN FINE SANDY LOAM
62" GRAY BROWN COARSE SAND & GRAVEL, ROCKY

NO MOTTLING
NO GW
LEDGE @ 62"
ROOTS TO 44"

TP 59
6" LEAF LITTER & TOPSOIL
42" LIGHT ORANGE BROWN FINE-MEDIUM SANDY LOAM, ROCKY
82" LIGHT GRAY BROWN COARSE SAND & GRAVEL ROCKY

NO MOTTLING
NO GW
LEDGE @ 82"
ROOTS TO 44"

28 MARTY'S WAY
TP 19
0-9" LEAF LITTER & TOPSOIL
9-28" ORANGE BROWN MEDIUM COARSE SANDY LOAM
28-63" STRATIFIED GRAY BROWN VERY FINE SILTY SAND

STANDING WATER @ 63"
MOTTLING POSSIBLE @ 36"
GW 63"
LEDGE @ 63"
ROOTS 33"

SANITARY DESIGN CRITERIA.

- A. ALL PRIMARY AND SEPTIC SYSTEM DESIGNS ARE DESIGNED FOR THREE-BEDROOM HOMES. NO TUBS OVER 100 GALLONS IN SIZE OR GARBAGE DISPOSAL INTO SEPTIC SYSTEM PLANNED.
B. THREE BEDROOM HOMES AT A PERC RATE OF 10.0 MIN/INCH OR LESS REQUIRES 495 S.F. OF EFFECTIVE LEACHING AREA.
MANTIS 536-8 LEACHING SYSTEM SELECTED FOR LEACHING SYSTEM DESIGN. CREDIT PER L.F. IS 11.0 S.F.
C. MINIMUM REQUIRED AREA IS 495 S.F./ 11 S.F./L.F. = 45' UNLESS MLSS GOVERNS.

HF = HYDRAULIC FACTOR BASED ON GRODIENT AND DEPTH TO AVERAGE RESTRICTION
FF = FLOW FACTOR, 1.5 FOR THREE BEDROOM HOME DESIGN
PF = PERC FACTOR, 1.0 FOR PERC RATE UP TO & 10.0 MIN/INCH

ALL MANTIS SYSTEMS 536-8 MLSS TABLE										
STREET ADDRESS	DESIGN PITS	GRADIENT %	RESTRICTION	HF	FF	PF	MLSS PRIMARY	MLSS RESERVE	SYSTEM	
1 MARTY'S WAY	47 & 48	•	> 60"		1.5	1.0	45'		••	
2 MARTY'S WAY	1 & 2	•	> 60"		1.5	1.0	45'		••	
3 MARTY'S WAY	46	1.0 – 2.0	48.1 – 60.0	28	1.5	1.0	42'	42'	••	
4 MARTY'S WAY	3 & 4	3.1 – 4.0	30.1 – 36.0	30	1.5	1.0	45'	45'	••	
5 MARTY'S WAY	44	4.1 – 6.0	36.1 – 42.0	26	1.5	1.0	39'	39'	••	
7 MARTY'S WAY	41 & 42	4.1 – 6.0	48.1 – 60.0	30	1.5	1.25	56.25'	45'	60'	
9 MARTY'S WAY	39 & 40	•	> 60"		1.5		45'		••	
11 MARTY'S WAY	38 & 38B	6.1 – 8.0	26.1 – 30.0	28	1.5		42'		••	
13 MARTY'S WAY	28	•	> 60"		1.5		45'		••	
15 MARTY'S WAY	25A & 58	> 15	36.1 – 40.0	16	1.5		24'		••	
16 MARTY'S WAY	7 & 8	•	> 60"		1.5		24'		••	
17 MARTY'S WAY	36 & 36B	3.1 – 4.0	30.1 – 36.0	30	1.5		45'		••	
18 MARTY'S WAY	11 & 12	•	> 60"		1.5		45'		••	
19 MARTY'S WAY	34 & 35	8.1 – 10.0	30.1 – 36.0	24	1.5		36'		••	
20 MARTY'S WAY	13 & 14	•	> 60"		1.5		36'		••	
21 MARTY'S WAY	31 & 49	3.1 – 4.0	42.1 – 48	26	1.5		39'		••	
22 MARTY'S WAY	17 & 18	•	NONE		1.5		39'		••	
23 MARTY'S WAY	30	4.1 – 6.0	36.1 – 42.0	26	1.5		39'	45'	••	
24 MARTY'S WAY	202 & 203	•			1.5		45'		••	
25 MARTY'S WAY	24	•	> 60"		1.5		45'		••	
26 MARTY'S WAY	200 & 201	•			1.5		45'		••	
27 MARTY'S WAY	59	•	> 60"		1.5		45'	45'	••	
28 MARTY'S WAY	19 & 19A	2.1 – 3.0	30.1 – 36.0	34	1.5		51'	45'	••	
29 MARTY'S WAY	51 & 52	4.1 – 6.0	36.1 – 42.0	26	1.5		39'	45'		