

**Town of Ledyard
Highlands W.W.T.F.
Plant Supervisor's Report
Meeting December 16, 2025**

The goal of the plant staff is to efficiently collect and treat the wastewater and to produce the best quality effluent possible while maintaining the equipment and protecting the Town's assets.

- **Waiting on G.U. to clean up material (asphalt) left at 82 Town Farm Road.**
- **Letter received from G.U. regarding possible lead water service at 82 Town Farm Road? There are no lead service lines here as the system was installed using copper and plastic pipe and fittings.**
- **Working on getting sand filters back in operation following maintenance requirements.**
- **Blowers have faulted on low oil pressure during colder temperatures. Working with Oak Hills on SCADA adjustments.**
- **Adding polymer to help the settling in Sequencing Batch Reactors.**
- **DB Electric repairing heaters in all buildings.**

Respectfully

submitted,

**Stephen W.
Banks**