

**Town of Ledyard  
Highlands W.W.T.F.  
Plant Supervisor's Report  
Meeting October 28, 2025**

The goal of the plant staff is to efficiently collect and treat the wastewater and to produce the best quality effluent possible while maintaining the equipment and protecting the Town's assets.

- Basin # 1 is back in service. Building up solids every day. Plant is back in two basin operation and running well.
- Beaver activity on property is being addressed. Public works is clearing a path for trapper.
- Lakeside pumps are running well after rebuilding pump 1. Will have to upgrade pumps and controls in a few years.
- GU is working on a water main upgrade on Thompson. They are storing material for the project at the plant. Will clean up after the job is completed.
- Town Council needs to appoint a liaison for the WPCA.
- Town Council needs to be made aware that they oversee the water department budget with advisement from the WPCA.
- Skips Wastewater service has performed well so far removing solids and transporting sludge to Mattabassett.
- Polymer system is down for maintenance.
- Flows have increased slightly as groundwater levels have increased.
- In-situ relining of sanitary sewer collection system will allow for more flows into the facility.

**Respectfully**

**submitted,**

**Stephen W.  
Banks**

