

**Town of Ledyard
Highlands W.W.T.F.
Plant Supervisor's Report
Meeting November 25, 2025**

The goal of the plant staff is to efficiently collect and treat the wastewater and to produce the best quality effluent possible while maintaining the equipment and protecting the Town's assets.

- Plant is back in two basin operation and running OK. Settling is up on both basins. Monitoring closely.
- Beaver activity on property has been addressed. Trapper removed (3) beavers.
- GU has completed the main water replacement on Thompson. They are storing material for the project at the plant. They are cleaning up material left at 82 Town Farm Road.
- Flows have continued to increase slightly as groundwater levels have increased.
- Connecticut Rural Water and Wastewater Association has invited us to a zoom session regarding possible funding for sewer pipe rehabilitation program. This is through U.S.D.A. Will set up a time and date soon.
- Letter received from G.U. regarding possible lead water service at 82 Town Farm Road? There are no lead service lines here as the system was installed using copper and plastic pipe and fittings.
- Working on getting sand filters back in operation following maintenance requirements.

Respectfully

submitted,

**Stephen W.
Banks**