

**Town of Ledyard
Highlands W.W.T.F.
Plant Supervisor's Report
Meeting January 27, 2026**

The goal of the plant staff is to efficiently collect and treat the wastewater and to produce the best quality effluent possible while maintaining the equipment and protecting the Town's assets.

- G.U. has completed clean up material (asphalt) left at 82 Town Farm Road from water main projects.
- Interfacing with G. U. regarding our requirements for Lead and copper regulations from DPH via EPA. Town Council needs to be in the loop on this.
- Sand filters are back in operation following maintenance requirements.
- Made some adjustments on blower variable frequency drives during colder temperatures. Blowers have faulted on low oil pressure during colder temperatures.
- The settling in the Sequencing Batch Reactors has decreased and the effluent is improving.
- Annual nitrogen trading report was received from DEEP. Our limit is 7 pounds per day, and we averaged 3 pounds per day. We will receive a check from DEEP this July.
- Waste activated sludge pump # 2 flow has decreased. Will check valve for debris.
- Preparing for another snow storm coming this weekend.

Respectfully

submitted,

**Stephen W.
Banks**