

**Town of Ledyard  
Highlands W.W.T.F.  
Plant Supervisor's Report  
Meeting May 26, 2026**

The goal of the plant staff is to efficiently collect and treat the wastewater and to produce the best quality effluent possible while maintaining the equipment and protecting the Town's assets.

- Sand filters maintenance requirements have been completed. Units are back online.
- Dean Lautenbach passed the Class II DEEP/ABC operator exam.
- Water service restored after GU installed a valve in the Highland/ Meetinghouse intersection.
- Azuria Company (Insituform) will be giving a presentation to the WPCA on 5-26-26 about relining the sewer pipes in the Ledyard Highlands. This work is essential to allow development of Ledyard Center and extend sewer service.
- Dana Discuillo has been hired as a Tab Tech/ Operator.
- Richard White assisted us with the cleaning at Lakeside and Grit pit on 5-19-26.
- 13 Amos Stanton called us out on 5-17-26 @ 1 am for sewer back up. We responded and notified the owners that the E-1 grinder pump that failed was their responsibility to maintain/repair/replace. Letters will be sent out to all homes with grinder pumps to remind them of this. This policy was established when Amos Stanton was built in 2004.
- Montville WPCA took 9000 gallons of our MLSS to help improve their process.

**Respectfully,**

**Stephen W.**

**Banks**