

**Town of Ledyard
Highlands W.W.T.F.
Plant Supervisor's Report
Meeting July 28, 2026**

The goal of the plant staff is to efficiently collect and treat the wastewater and to produce the best quality effluent possible while maintaining the equipment and protecting the Town's assets.

- **Aquia Providence from CTRWWA will be giving a presentation on USDA funding and lead /copper rule at the next WPCA meeting.**
- **Closed out most of the PO's for FY 2026. Opened new PO's for FY 2027.**
- **Purchased new odor control system for solids thickening room. (Jim Seiler).**
- **Clow valve on backwash filters # 1 has been repaired. Valve is back in service.**
- **Trying to re-register the e-Catcher system for our mobile phones. The original registration through Xylem has expired. This allows us to see the SCADA system of the facility on our phones.**
- **Scheduling a date with CT DEEP for sanitary sewer collection inspection.**
- **Need to replace hose on Truck loading truck (thickened sludge) pump.**
- **Recent rain events caused high influent flow alarms at the plant.**

Respectfully,

**Stephen W.
Banks**