

From: [water pollution control authority](#)
To: [Elizabeth Burdick](#)
Subject: Cashman blast report and the affects on utilities
Date: Thursday, October 24, 2024 3:12:38 PM

liz - just a heads up. Both the WPCA commissioners and GU have reviewed the blast report and have no major concerns. However, we both would like to see a leak test done on the water mains surrounding the area before any blasting is done and then after normal blasting activities (pre-blasting testing does not need leak tests to be performed). Also - it would be nice if Cashman would help pay for the water meter pit we need to install on the water line going into the plant. The original design of the water main was for emergencies only and not for operational use thus we need to install a meter. The WPCA is a non-profit entity, and we have very limited capital funds for such an installation.

Thanks!

Ed Lynch, WPCA
Mobile 646-732-9224