

FD#2



RECEIVED

JUL 30 2026

Promoting
healthy
communities

Date: 7/16/2026

To: Jacob Faulise, P.E.

Subject Property: 611 Lantern Hill Road, Ledyard

Land Use Department

Plan Designed by: **Jacob Faulise, P.E.** Plan Date: **6/30/2026** Last Revision Date: --- Date Paid: **7/2/2026**. The plan and associated information submitted to our office on 7/2/2026 for a proposed **4-bedroom residential** building with private well water and private septic at the above stated property, in the Town of Ledyard, is:

☒ **Approved w/conditions: Complies with the requirements of Section 19-13-B103 of the Connecticut Public Health Code; See conditions below.**

Conditions:

1. A well abandonment permit will need to be submitted for the existing dug well.
2. Strip inspection required. Please contact me in advance to schedule inspection.
3. Benchmark adjacent to proposed building and sewage disposal system. Installer should not be required to transfer benchmarks when considerable difference (more than 10' to 15') exist between the benchmark and leaching area. If the benchmark is disturbed prior to construction, the engineer should set another one for construction purposes.
4. A walkthrough upon completion of the construction of the house will be required prior to the issuance of the permit to discharge.
5. All tanks requiring risers shall maintain the original covers on the tanks, have riser covers that weigh at least 100lbs., or install a secondary safety device below the riser to prevent individuals from falling into a tank. All below grade tank or riser cover handles shall contain or be fitted with a material that can be located with a metal detector.
6. Tank and Leach field to maintain 5' from proposed deck.

The following are not currently required by CT Public Health Code and/or LLHD Plan Review Policies but are encouraged/recommended to protect the proposed structures, onsite septic system, water treatment discharge system and/or water supply/groundwater.

1. All proposed well arcs should be kept on the property they serve (to allow neighbors full use of their properties) and all well casings should be located at least 10' from driving surfaces and/or structures to prevent future damage and allow for future maintenance of the wells.
2. It is strongly encouraged to keep the original tank covers on all tanks requiring risers to prevent the escape of sewer gases and prevent individuals from falling into tanks.
3. The designer should take into consideration the location of potential future water treatment discharge systems, rain gardens and footing/gutter drain discharge locations.

Additional Requirements and Recommendations:

Installer to submit scaled and/or tied as-built to LLHD upon 30 days of completion with distances to flow line at house, inlet and outlet cover of tank, d-boxes, cleanouts and ends of leaching rows, well, footing/curtain drains and between tie points. In addition, provide the name of installer, date, house location and street/directional arrow.



Promoting
healthy
communities

***Please note that soils testing indicated on this plan are representative of actual soils conditions and additional deep test pits and percolation tests may be required by the Ledge Light Health District if the building or system location is altered and/or the suitable septic area is limited. Applicant should be aware that subdivision approval IS NOT sufficient for individual lot approval. Each lot must be reviewed by the Ledge Light Health District at the time of building permit application in order to obtain lot approval and issue a septic/well permit.**

Please call me at 860-448-4882 ext 1383 with any questions regarding this matter.

A handwritten signature in blue ink that reads "Odalys Reyes Morales".

Sincerely,
Odalys Reyes Morales